

ASME PVHO-1-2023
(Revision of ASME PVHO-1-2019)

Safety Standard for Pressure Vessels for Human Occupancy

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1-2023

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME PVHO-1-2023
(Revision of ASME PVHO-1-2019)

Safety Standard for Pressure Vessels for Human Occupancy

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1-2023

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: December 11, 2023

The next edition of this Standard is scheduled for publication in 2026.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

“ASME” and the above ASME symbol are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved

CONTENTS

Foreword	viii
Committee Roster	ix
Correspondence With the PVHO Committee	xii
Summary of Changes	xiv
Section 1	
General Requirements	1
1-1 Introduction	1
1-2 Scope	1
1-3 Exclusions	1
1-4 User Requirements	1
1-5 Manufacturer's Data Report	1
1-6 Materials	2
1-7 Design and Fabrication Requirements	2
1-8 Pressure Relief Devices	5
1-9 Marking	5
1-10 Nonmetallic Materials and Toxicity Off-Gas Testing	6
1-11 Risk Analysis	7
1-12 Lithium Batteries	7
1-13 Automatic Control and Software Safety	9
1-14 Operational Pressure Cycle	9
Section 2	
Viewports	18
2-1 General	18
2-2 Design	19
2-3 Material	28
2-4 Fabrication	31
2-5 Inspection	32
2-6 Marking	33
2-7 Pressure Testing	34
2-8 Installation of Windows in Chambers	35
2-9 Repair of Damaged Windows Prior to Being Placed in Service	35
2-10 Guidelines for Application of the Requirements of Section 2	36
2-11 Nonstandard Window Geometries and Standard Window Geometries With Lower Conversion Factors	38
Section 3	
Quality Assurance for PVHO Manufacturers	91
3-1 General	91
3-2 Responsibilities	91
Section 4	
Piping Systems	92
4-1 General	92
4-2 Material Requirements	93

4-3	Design of Components	94
4-4	Selection and Limitations of Piping Components	95
4-5	Selection and Limitations of Piping Joints	96
4-6	Supports	97
4-7	Inspection	97
4-8	Testing	98
4-9	Systems	98
Section 5	Medical Hyperbaric Systems	106
5-1	General	106
5-2	PVHO System Design	107
5-3	Gas Systems	107
5-4	Control Systems and Instrumentation	107
5-5	Environmental Systems	107
5-6	Installation Testing	108
Section 6	Diving Systems	109
6-1	General	109
6-2	Design	110
6-3	Pressure Boundary	111
6-4	Systems	113
6-5	Handling Systems	117
6-6	Hyperbaric Evacuation Systems	118
6-7	Testing and Trials	120
Section 7	Submersibles	123
7-1	General	123
7-2	Pressure Boundary	124
7-3	Piping	125
7-4	Electrical Systems	126
7-5	Life Support	126
7-6	Fire Protection	127
7-7	Navigation	127
7-8	Communications	128
7-9	Instrumentation	128
7-10	Buoyancy, Stability, Emergency Ascent, and Entanglement	128
7-11	Emergency Equipment	129
7-12	Hadal-Zone Submersibles	130
Mandatory Appendices		
I	Reference Codes, Standards, and Specifications	131
II	Definitions	133
Nonmandatory Appendices		
A	Design of Supports and Lifting Attachments	139
B	Recommendations for the Design of Through-Pressure Boundary Penetrations	140
C	Recommended Practices for Color Coding and Labeling	143

D	Guidelines for the Submission of a Case for the Use of Nonstandard Designs, Materials, and Construction for Non-Flexible PVHO Chamber Fabrication	144
E	Guidelines for Preparing a Performance-Based Case for Flexible PVHO Chambers and Systems	151
F	Useful References	181
G	Alternative Design Rules for External Pressure Vessels	183

Figures

1-7.1-1	Spherical Intermediate Head Attachment	12
1-9.1-1	Form of Nameplate, U.S. Customary Units	15
1-9.1-2	Form of Nameplate, SI Units	15
1-9.2-1	Form of Nameplate With Systems Integrator, U.S. Customary Units	16
1-9.2-2	Form of Nameplate With Systems Integrator, SI Units	16
2-2.2.1-1	Standard Window Geometries — Part 1	44
2-2.2.1-2	Standard Window Geometries — Part 2	45
2-2.2.1-3	Standard Window Geometries — Part 3	46
2-2.2.1-4	Standard Window Geometries — Part 4	47
2-2.5.1-1	Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 1	50
2-2.5.1-2	Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 2	51
2-2.5.1-3	Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 3	52
2-2.5.1-4	Short-Term Critical Pressure of Conical Frustum Acrylic Windows — Part 1	53
2-2.5.1-5	Short-Term Critical Pressure of Conical Frustum Acrylic Windows — Part 2	54
2-2.5.1-6	Short-Term Critical Pressure of Spherical Sector Acrylic Windows — Part 1	55
2-2.5.1-7	Short-Term Critical Pressure of Spherical Sector Acrylic Windows — Part 2	56
2-2.5.1-8	Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Internally — Part 1	57
2-2.5.1-9	Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Internally — Part 2	58
2-2.5.1-10	Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Externally	59
2-2.5.1-11	Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure — Part 1	60
2-2.5.1-12	Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure — Part 2	61
2-2.5.1-13	Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure — Part 3	62
2-2.5.1-14	Short-Term Critical Pressure of Hyperhemispherical and NEMO-Type Acrylic Windows — Part 1	63
2-2.5.1-15	Short-Term Critical Pressure of Hyperhemispherical and NEMO-Type Acrylic Windows — Part 2	64
2-2.9.1-1	Seat Cavity Requirements — Conical Frustum Window, Spherical Sector Window With Conical Edge, and Flat Disk Window	65
2-2.9.1-2	Seat Cavity Requirements — Double-Beveled Disk Window	66
2-2.9.1-3	Seat Cavity Requirements — Spherical Sector Window With Square Edge	67
2-2.9.1-4	Seat Cavity Requirements — Hemispherical Window With Equatorial Flange	68
2-2.9.1-5	Seat Cavity Requirements — Cylindrical Window	69
2-2.9.1-6	Seat Cavity Requirements — Hyperhemispherical Window	70
2-2.9.1-7	Seat Cavity Requirements — NEMO Window (Standard Seat)	71
2-2.9.1-8	Seat Cavity Requirements — NEMO Window (Seat With Extended Cyclic Fatigue Life)	72

2-2.10.10-1	Bevels on Window Edges — Flat Disk Windows, Conical Frustum Windows, Spherical Sector Windows, Hyperhemispheres	73
2-2.10.10-2	Bevels on Window Edges — Flanged Hemispherical Window, Spherical Sector Window With Square Edge, External Pressure and Internal Pressure of Cylindrical Windows	74
2-2.10.11-1	Acceptable Configurations for Clear Viewport Retaining Covers	75
2-2.13.11-1	Dimensional Tolerances for Penetrations in Acrylic Windows	76
2-2.13.15-1	Dimensional Tolerances for Inserts in Acrylic Windows	78
2-2.13.16-1	Typical Shapes of Inserts	79
2-2.13.22-1	Seal Configurations for Inserts in Acrylic Windows	80
2-2.13.24-1	Restraints for Inserts in Acrylic Windows	81
2-11.5.2-1	Alternative Long-Term Proof Pressure Test Acceptance Criteria	90
4-9.14.2-1	Flow Diagram of Apparatus for Measuring the Concentration of Hydrocarbons in a Stream of Air or Other Gas After It Has Passed Through a Test Hose	105
6-6.2.2-1	Placement and Design of Markings for Hyperbaric Evacuation Units Designed to Float in Water	121
6-6.2.2-2	Markings for Hyperbaric Evacuation Units Designed to Float in Water	122
B-2-1	Acceptable Weld Nozzle Penetrators	141
B-3-1	Acceptable Threads and Inserts	142
E-3.3.1-1	Cook's Diagram: Atmosphere of Increased Burning Rate	178
E-5.2.2.1-1	Number of Test Samples Required for Alternate Creep Test Procedure	179
E-5.2.5.1-1	Time Versus Test Temperature for Accelerated Aging Test	180
G-1-1	Geometry of Cylinders	188
G-1-2	Stiffener Geometry	189
G-1-3	Sections Through Rings	189
G-5-1	Values of t/R_o and L_c/R_o	190
Tables		
1-10-1	Conversion Factor, F_p (for PVHO Occupation Exceeding 8 hr)	17
2-2.3.1-1	Conversion Factors for Acrylic Flat Disk Windows	47
2-2.3.1-2	Conversion Factors for Acrylic Conical Frustum Windows and Double-Beveled Disk Windows	48
2-2.3.1-3	Conversion Factors for Acrylic Spherical Sector Windows With Conical Edge, Hyperhemispherical Windows With Conical Edge, and NEMO-Type Windows With Conical Edge	48
2-2.3.1-4	Conversion Factors for Acrylic Spherical Sector Windows With Square Edge and Hemispherical Windows With Equatorial Flange	49
2-2.3.1-5	Conversion Factors for Acrylic Cylindrical Windows	49
2-2.3.2-1	Conical Frustum Windows for Design Pressures in Excess of 10,000 psi (69 MPa)	49
2-2.13.13-1	Specified Values of Physical Properties for Polycarbonate Plastic	77
2-2.13.13-2	Specified Values of Physical Properties for Cast Nylon Plastic	77
2-3.4-1	Specified Values of Physical Properties for Each Lot	82
2-3.4-2	Specified Values of Physical Properties for Each Casting	84
2-4.5-1	Annealing Schedule for Acrylic Windows	86
2-11.5.2-1	ALTPP Test Options	89
4-2.1.1-1	Maximum Allowable Stress Values for Seamless Pipe and Tube Materials Not Listed in Nonmandatory Appendix A of ASME B31.1	104
4-7.1-1	Mandatory Minimum Nondestructive Examinations for Pressure Welds in Piping Systems for Pressure Vessels for Human Occupancy	104

4-9.14.2-1	Maximum Allowable Concentration of Hydrocarbons in Air Passing Through Hose	105
C-1	U.S. Navy Color Codes	143
C-2	IMO Color Codes	143
D-7.1-1	Tabulated Data for Performance of “W-Test” for Normality of Data Set	150
E-1.1-1	Compliance Matrix for ASME PVHO-1 Cases	164

Forms

PVHO-1 GR-1	Manufacturer’s Data Report for Pressure Vessels for Human Occupancy	10
PVHO-1 GR-1S	Manufacturer’s Data Report Supplementary Sheet	11
PVHO-1 GR-2	Systems Integrator Report for Pressure Vessels for Human Occupancy	13
PVHO-1 GR-2S	Systems Integrator Report Supplementary Sheet	14
PVHO-1 VP-1	Fabrication Certification for Acrylic Windows	42
PVHO-1 VP-2	Acrylic Window Design Certification	43
PVHO-1 VP-3	Material Manufacturer’s Certification for Acrylic	83
PVHO-1 VP-4	Material Testing Certification for Acrylic	85
PVHO-1 VP-5	Pressure Testing Certification	87
PVHO-1 VP-6	Acrylic Window Repair Certification	88

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

FOREWORD

Early in 1971, an ad hoc committee was formed by action of the ASME Codes and Standards Policy Board to develop design rules for pressure vessels for human occupancy. The importance of this task was soon recognized, and the ASME Safety Code Committee on Pressure Vessels for Human Occupancy (PVHO) was established in 1974 to continue the work of the ad hoc committee. Initially, this committee was to confine its activity to the pressure boundary of such systems. It was to reference existing ASME Boiler and Pressure Vessel Code (BPVC) Sections, insofar as practicable, adapting them for application to pressure vessels for human occupancy. The common practice hitherto had been to design such chambers in accordance with ASME BPVC, Section VIII, Division 1; however, a number of important considerations were not covered in those rules. Among these were requirements for viewports and the in-service use of pressure relief valves, and special material toughness requirements. This Standard provides the necessary rules to supplement that Section and also ASME BPVC, Section VIII, Division 2. The user is expected to be familiar with the principles and application of ASME BPVC Sections.

ASME BPVC criteria furnish the baseline for design. In ASME PVHO-1, design temperature is limited to 0°F to 150°F (–18°C to 66°C). Supporting structure and lifting loads are given special attention. Certain design details permitted by Section VIII are excluded. A major addition is the inclusion of design rules for acrylic viewports (Section 2). The formulation of rules for these vital and critical appurtenances was one of the reasons for establishing the PVHO Committee. Finally, all chambers designed for external pressure are required to be subjected to an external pressure hydrostatic test or pneumatic test.

The 2007 edition was completely rewritten and reformatted from the 2002 edition. Section 1, General Requirements, is intended to be used for all PVHOs, regardless of use. The rules for external pressure design were expanded to include unstiffened and ring-stiffened cylinders, in addition to spheres. Other additions included Sections pertaining to application-specific PVHOs. Sections were included for medical hyperbaric systems, diving systems, submersibles, and quality assurance. The Piping Systems Section was expanded. Where possible, Mandatory Appendices were incorporated into the body of the Standard. All forms were revised to reflect the document (PVHO-1), an abbreviation denoting the corresponding section (e.g., GR for General Requirements), and the form number within that Section. An example is PVHO-1 Form GR-1.

The 2012 edition included expansions made to the General Requirements, Viewports, and Diving Systems Sections.

The 2016 edition included additional expansions made to the General Requirements, Viewports, Medical Hyperbaric Systems, and Diving Systems Sections. It included a new Nonmandatory Appendix for preparing PVHO performance-based Cases for flexible chambers. There is continuing work being accomplished by the subcommittees in the areas of PVHOs using nonstandard materials, including nonmetallic PVHOs. A companion document (ASME PVHO-2) that covers in-service guidelines for PVHOs has been published.

The 2019 edition of ASME PVHO-1 continued to address complete PVHO systems and PVHOs made from nonstandard materials. In support of this work, definitions in Mandatory Appendix II and various forms were added or updated to reflect the differences in approach to documenting the entire PVHO system as a whole rather than as single or multiple pressure vessels/chambers. Additionally, changes were made to clarify several design standards and requirements for easier understanding and implementation by all users of this Standard.

The 2023 edition includes revisions to Section 1, specifically the addition of PVHO systems integrator documentation and marking requirements for PVHO systems in which the PVHO systems integrator differs from the PVHO manufacturer. Additionally, this edition develops a nomenclature list for Section 2 based on ASME PVHO-1–2016. Code Case 22 (Alternative Long-Term Proof Pressure Test Under PVHO-1) has been integrated into a new para. 2-11.5.2. Paragraph 4-9.4 has been revised and adds requirements for gauge scale, accuracy, calibration, and calibration verification. The subcommittee has decided to cite the requirements of ASME B40.1 and ASME B40.7 rather than summarizing and repeating the information. As required by para. 4-9.3, current monoplace chambers do not have hull valves. Additionally, hyperbaric evacuation units (HEUs) will be able to mate with every hyperbaric reception facility (HRF). Currently, the International Marine Contractors Association (IMCA) has a guidance document, IMCA D051, that addresses interface compatibility between HEUs and HRFs. Subsection 7-12 has been added to address the unique aspects associated with hadal-zone submersibles.

ASME PVHO-1–2023 was approved and adopted by the American National Standards Institute as meeting the criteria as an American National Standard on September 27, 2023. Previous editions were published in 1977, 1981, 1984, 1987, 1993, 1997, 2002, 2007, 2012, 2016, and 2019.

ASME PRESSURE VESSELS FOR HUMAN OCCUPANCY COMMITTEE

(The following is the roster of the committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

J. E. Crouch, *Chair*
M. A. Frey, *Vice Chair*
D. Wiener, *Secretary*

STANDARDS COMMITTEE PERSONNEL

G. Bryant, Consultant
F. Burman, Divers Alert Network
J. E. Crouch, Southwest Research Institute
T. Dingman, Healogics
R. K. Dixit, PCCI, Inc.
B. Faircloth, FMS Engineering, LLC
M. A. Frey, Naval Sea Systems Command
T. R. Galloway, Naval Sea Systems Command
D. R. Hurd, Atlantis Submarines International
B. Kemper, Kemper Engineering Services, LLC
W. Kohnen, Hydrospace Group, Inc.
D. Lawrence, U.S. Coast Guard
J. K. Martin, Lockheed Martin
G. Richards, Blanson, Ltd.
P. Selby, SOS Group Global, Ltd.

K. A. Smith, U.S. Coast Guard
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program
D. Talati, Sechrist Industries, Inc.
R. Thomas, American Bureau of Shipping
M. R. Walters, Oceaneering International, Inc.
D. Wiener, The American Society of Mechanical Engineers
G. Wolfe, Southwest Research Institute
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
W. F. Crowley, Jr., *Contributing Member*, Aerospace & Undersea Support Services, LLC
W. Davison, *Contributing Member*, CutisCare, LLC
G. J. Jacob, *Contributing Member*, Navy Experimental Diving Unit
H. Pauli, *Contributing Member*, Germanischer Lloyd AG

HONORARY MEMBERS

F. T. Gorman
L. G. Malone, Plastic Supply & Fabric, Inc.

R. P. Swanson

SPECIAL PROJECTS TASK GROUP

G. Richards, *Chair*, Blanson, Ltd.
J. E. Crouch, Southwest Research Institute
E. G. Fink, Fink Engineering Pty, Ltd.
M. A. Frey, Naval Sea Systems Command
T. R. Galloway, Naval Sea Systems Command
B. Kemper, Kemper Engineering Services, LLC
W. Kohnen, Hydrospace Group, Inc.
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program

G. Wolfe, Southwest Research Institute
J. Bretzke, *Alternate*, U.S. Department of the Navy
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
S. Reimers, *Contributing Member*, Reimers Systems Division, PCCI, Inc.

TASK GROUP ON DESIGN BY ANALYSIS

B. Kemper, *Chair*, Kemper Engineering Services, LLC
R. K. Dixit, PCCI, Inc.
D. R. Hurd, Atlantis Submarines International
J. K. Martin, Lockheed Martin

G. Richards, Blanson, Ltd.
R. Thomas, American Bureau of Shipping
K. A. Williams, Lockheed Martin

TASK GROUP ON TUNNELING

R. K. Dixit, *Chair*, PCCI, Inc.
F. Burman, Divers Alert Network
G. Butler, Life Support Technologies, Inc.
K. Corson, Poseidon Safety
J. Costello, Consultant
G. L. East, ASI Marine
F. Gomez, Gomez International, Inc.
J. P. Hierholzer, DNV GL

D. R. Hurd, Atlantis Submarines International
B. Kemper, Kemper Engineering Services, LLC
D. A. Renear, Consultant
R. Thomas, American Bureau of Shipping
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
S. Reimers, *Contributing Member*, Reimers Systems Division, PCCI, Inc.

SUBCOMMITTEE ON DESIGN AND PIPING SYSTEMS

B. Faircloth, *Chair*, FMS Engineering, LLC
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
G. Bryant, Consultant
F. Burman, Divers Alert Network
R. K. Dixit, PCCI, Inc.
P. Forte, Woods Hole Oceanographic Institution
M. A. Frey, Naval Sea Systems Command
T. R. Galloway, Naval Sea Systems Command
D. R. Hurd, Atlantis Submarines International
B. Kemper, Kemper Engineering Services, LLC
D. A. Renear, Consultant
G. Richards, Blanson, Ltd.
P. Selby, SOS Group Global, Ltd.

R. Thomas, American Bureau of Shipping
M. R. Walters, Oceaneering International, Inc.
G. Wolfe, Southwest Research Institute
J. Bretzke, *Alternate*, U.S. Department of the Navy
J. N. Pollack, *Alternate*, U.S. Navy
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
W. F. Crowley, Jr., *Contributing Member*, Aerospace & Undersea Support Services, LLC
B. Humberstone, *Contributing Member*, Diving Technical Advisor
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
S. Reimers, *Contributing Member*, Reimers Systems Division, PCCI, Inc.

SUBCOMMITTEE ON DIVING SYSTEMS

R. Thomas, *Chair*, American Bureau of Shipping
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
G. Bryant, Consultant
F. Burman, Divers Alert Network
R. K. Dixit, PCCI, Inc.
B. Faircloth, FMS Engineering, LLC
T. R. Galloway, Naval Sea Systems Command
B. Humberstone, Diving Technical Advisor
B. Kemper, Kemper Engineering Services, LLC
D. Lawrence, U.S. Coast Guard
J. K. Martin, Lockheed Martin
P. Selby, SOS Group Global, Ltd.

K. A. Smith, U.S. Coast Guard
M. R. Walters, Oceaneering International, Inc.
E. G. Fink, *Delegate*, Fink Engineering Pty, Ltd.
J. Bretzke, *Alternate*, U.S. Department of the Navy
T. Gilman, *Alternate*, U.S. Coast Guard
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
W. F. Crowley, Jr., *Contributing Member*, Aerospace & Undersea Support Services, LLC
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
H. Pauli, *Contributing Member*, Germanischer Lloyd AG
D. A. Renear, *Contributing Member*, Consultant

SUBCOMMITTEE ON GENERAL REQUIREMENTS

M. A. Frey, *Chair*, Naval Sea Systems Command
B. Kemper, *Vice Chair*, Kemper Engineering Services, LLC
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
J. Bell, Fink Engineering Pty, Ltd.
J. E. Crouch, Southwest Research Institute
R. K. Dixit, PCCI, Inc.
T. R. Galloway, Naval Sea Systems Command
A. Garay, Hyperbaric Modular Systems, Inc.
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program

G. Wolfe, Southwest Research Institute
J. Bretzke, *Alternate*, U.S. Department of the Navy
J. N. Pollack, *Alternate*, U.S. Navy
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
G. J. Jacob, *Contributing Member*, Navy Experimental Diving Unit
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC

SUBCOMMITTEE ON MEDICAL HYPERBARIC SYSTEMS

T. Dingman, *Chair*, Healogics
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
J. Bell, Fink Engineering Pty, Ltd.
F. Burman, Divers Alert Network
R. K. Dixit, PCCI, Inc.
A. Garay, Hyperbaric Modular Systems, Inc.
B. Kemper, Kemper Engineering Services, LLC
G. Richards, Blanson, Ltd.
P. Selby, SOS Group Global, Ltd.
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program
D. Talati, Sechrist Industries, Inc.
H. Pauli, *Delegate*, Germanischer Lloyd AG
E. G. Fink, *Alternate*, Fink Engineering Pty, Ltd.
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
W. Davison, *Contributing Member*, CutisCare, LLC
K. W. Evans, *Contributing Member*, Perry Baromedical
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
J. C. Sheffield, *Contributing Member*, International ATMO, Inc.
N. To, *Contributing Member*, U.S. Food and Drug Administration

SUBCOMMITTEE ON POST CONSTRUCTION

D. Wiener, *Secretary*, The American Society of Mechanical Engineers
J. Bell, Fink Engineering Pty, Ltd.
G. Bryant, Consultant
F. Burman, Divers Alert Network
J. E. Crouch, Southwest Research Institute
T. Dingman, Healogics
R. K. Dixit, PCCI, Inc.
M. A. Frey, Naval Sea Systems Command
T. R. Galloway, Naval Sea Systems Command
D. R. Hurd, Atlantis Submarines International
B. Kemper, Kemper Engineering Services, LLC
W. Kohnen, Hydrospace Group, Inc.
D. Lawrence, U.S. Coast Guard
J. K. Martin, Lockheed Martin
G. Richards, Blanson, Ltd.
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program
D. Talati, Sechrist Industries, Inc.
G. Wolfe, Southwest Research Institute
J. Bretzke, *Alternate*, U.S. Department of the Navy
T. Gilman, *Alternate*, U.S. Coast Guard
J. N. Pollack, *Alternate*, U.S. Navy
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
W. F. Crowley, Jr., *Contributing Member*, Aerospace & Undersea Support Services, LLC
W. Davison, *Contributing Member*, CutisCare, LLC
P. Forte, *Contributing Member*, Woods Hole Oceanographic Institution
B. Humberstone, *Contributing Member*, Diving Technical Advisor
G. J. Jacob, *Contributing Member*, Navy Experimental Diving Unit
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
J. C. Sheffield, *Contributing Member*, International ATMO, Inc.

SUBCOMMITTEE ON SUBMERSIBLES

R. Thomas, *Chair*, American Bureau of Shipping
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
G. Bryant, Consultant
J. P. Hierholzer, DNV GL
D. R. Hurd, Atlantis Submarines International
B. Kemper, Kemper Engineering Services, LLC
W. Kohnen, Hydrospace Group, Inc.
J. K. Martin, Lockheed Martin
G. Richards, Blanson, Ltd.
K. A. Smith, U.S. Coast Guard
M. R. Walters, Oceaneering International, Inc.
D. Lawrence, *Alternate*, U.S. Coast Guard
W. F. Crowley, Jr., *Contributing Member*, Aerospace & Undersea Support Services, LLC
T. R. Galloway, *Contributing Member*, Naval Sea Systems Command
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC
H. Pauli, *Contributing Member*, Germanischer Lloyd AG

SUBCOMMITTEE ON VIEWPORTS

B. Kemper, *Chair*, Kemper Engineering Services, LLC
D. Wiener, *Secretary*, The American Society of Mechanical Engineers
G. Bryant, Consultant
F. Burman, Divers Alert Network
R. K. Dixit, PCCI, Inc.
B. Faircloth, FMS Engineering, LLC
D. R. Hurd, Atlantis Submarines International
W. Kohnen, Hydrospace Group, Inc.
D. Lawrence, U.S. Coast Guard
D. A. Renear, Consultant
G. Richards, Blanson, Ltd.
R. C. Smith, Naval Facilities Engineering Command, Ocean Facilities Program
D. Talati, Sechrist Industries, Inc.
R. Thomas, American Bureau of Shipping
K. A. Williams, Lockheed Martin
M. W. Allen, *Contributing Member*, Microbaric Oxygen Systems, LLC
K. K. Kemper, *Contributing Member*, Kemper Engineering Services, LLC

CORRESPONDENCE WITH THE PVHO COMMITTEE

General. ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/PVHOcommittee>.

Revisions and Errata. The committee processes revisions to this Standard on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Standard is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number, the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number

(4) the editions of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

Interpretations. Upon request, the committee will issue an interpretation of any requirement of this Standard. An interpretation can be issued only in response to a request submitted through the online Interpretation Submittal Form at <https://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers can track the status of their requests at <https://go.asme.org/Interpretations>.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Interpretations are published in the ASME Interpretations Database at <https://go.asme.org/Interpretations> as they are issued.

Committee Meetings. The PVHO Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/PVHOcommittee>.

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

ASME PVHO-1-2023

SUMMARY OF CHANGES

Following approval by the ASME PVHO Committee and ASME, and after public review, ASME PVHO-1-2023 was approved by the American National Standards Institute on September 27, 2023.

In ASME PVHO-1-2023, paras. 1-7.13 and 2-2.6 have been revised and redesignated as Nonmandatory Appendix G and subsection 2-11, respectively. Subsequent paragraphs in subsections 1-7 and 2-2 have been redesignated, and cross-references have been updated. In addition, ASME PVHO-1-2023 includes the following changes identified by a margin note, **(23)**.

<i>Page</i>	<i>Location</i>	<i>Change</i>
1	1-5	Last paragraph added
2	1-7.1	Subparagraph (d) added
4	1-7.9	(1) Redesignated as 1-7.9.1, and last paragraph added (2) Paragraph 1-7.9.2 added
5	1-9	(1) Revised and redesignated as 1-9.1 (2) Paragraph 1-9.2 added
9	1-14	Revised
12	Figure 1-7.1-1	Added
13	PVHO-1 Form GR-2	Added
14	PVHO-1 Form GR-2S	Added
15	Figure 1-9.1-1	Former Figure 1-9-1 redesignated
15	Figure 1-9.1-2	Former Figure 1-9-2 redesignated
16	Figure 1-9.2-1	Added
16	Figure 1-9.2-2	Added
18	2-1.3.2	Subparagraph (c) revised
18	2-1.4	Added
24	2-2.10.10	Former para. 2-2.11.10 revised
25	2-2.11.4.1	Former para. 2-2.14.1(c) revised
29	2-3.7	Subparagraph (g) added
45	Figure 2-2.2.1-2	In illustration (a), definition of D_i added
46	Figure 2-2.2.1-3	Illustration (b) revised
47	Table 2-2.3.1-1	Editorially revised
48	Table 2-2.3.1-2	Editorially revised
48	Table 2-2.3.1-3	Editorially revised
49	Table 2-2.3.1-4	Editorially revised
49	Table 2-2.3.1-5	Editorially revised
69	Figure 2-2.9.1-5	In former Figure 2-2.10.1-5, illustration (b), M revised to M_c
70	Figure 2-2.9.1-6	Former Figure 2-2.10.1-6 revised
73	Figure 2-2.10.10-1	Former Figure 2-2.11.10-1 revised
76	Figure 2-2.13.11-1	Former Figure 2-2.14.11-1 revised
78	Figure 2-2.13.15-1	Former Figure 2-2.14.15-1 revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
79	Figure 2-2.13.16-1	Former Figure 2-2.14.16-1 revised
82	Table 2-3.4-1	Revised
89	Table 2-11.5.2-1	Added
90	Figure 2-11.5.2-1	Added
100	4-9.4	(1) Title and paras. 4-9.4.2 through 4-9.4.4 revised (2) First paragraph and paras. 4-9.4.4.1 through 4-9.4.7 added
107	5-2	(1) Revised and redesignated as 5-2.1 (2) Paragraph 5-2.2 added
107	5-3	Revised in its entirety
108	5-6	Added
114	6-4.1.6.1	Subparagraphs (b), (d), (e), and (f) revised
114	6-4.1.6.2	Subparagraphs (a), (b), and (d) revised
117	6-4.5.2	Revised
117	6-5.2	Second paragraph revised
118	6-6.1	First paragraph revised
120	6-6.5	Added
124	7-1.6	Subparagraphs (j)(1), (j)(2), (j)(2)(-a), and (j)(2)(-b) added
125	7-2.4.4	First paragraph revised
126	7-4.3	Paragraph 7-4.3.3 deleted and subsequent paragraphs redesignated
128	7-10.1	Revised
129	7-10.4	Subparagraph (c) revised in its entirety
130	7-12	Added
131	Mandatory Appendix I	Updated
133	Mandatory Appendix II	(1) Definition of <i>pressure vessel for human occupancy (PVHO)</i> revised (2) Definitions of <i>PVHO system</i> and <i>PVHO system boundary</i> added
181	Nonmandatory Appendix F	Updated
189	Figure G-1-3	In former Figure 1-7.13.1-3, nomenclature deleted from illustrations and set as Legend

INTENTIONALLY LEFT BLANK

Section 1

General Requirements

1-1 INTRODUCTION

This Standard defines the requirements that are applicable to all pressure vessels for human occupancy (PVHOs) fabricated to this Standard ([Sections 1 through 4](#)) and shall be used in conjunction with specific requirements in [Sections 5 through 7](#), as applicable, and Mandatory Appendices of this Standard. In the event of conflict between [Sections 1 through 4](#) and [Sections 5 through 7](#), the application-specific requirements from [Sections 5 through 7](#) shall govern.

PVHOs shall be designed, fabricated, inspected, tested, marked, and stamped in accordance with the requirements of this Standard and of the ASME Boiler and Pressure Vessel Code (ASME BPVC), Section VIII, Division 1 or Division 2, unless otherwise permitted within this Standard.

In-service requirements for PVHOs are found in ASME PVHO-2.

1-2 SCOPE

1-2.1 Application

This Standard applies to all pressure vessels that enclose a human within their pressure boundary while under internal or external pressure exceeding a differential pressure of 2 psi (15 kPa). PVHOs include, but are not limited to, submersibles, diving bells, and personnel transfer capsules, as well as decompression, recompression, hypobaric, and hyperbaric PVHOs.

1-2.2 Geometry

The scope of this Standard in relation to the geometry is the pressure boundary as defined in the User's Design Specification and shall include, but not be limited to, the following:

- (a) shells of revolution
- (b) openings and their reinforcements
- (c) nozzles and other connections
- (d) flat heads
- (e) quick-actuating closures
- (f) vessel penetrations
- (g) attachments and supports
- (h) access openings
- (i) viewports
- (j) pressure relief devices

- (k) pressure-retaining covers for vessel openings

1-2.3 Limitations

The pressure boundary of the PVHO shall be as follows:

- (a) welding end connection for the first circumferential joint for welded connections
- (b) the first threaded joint for screwed connections
- (c) the face of the first flange for bolted, flanged connections
- (d) the first sealing surface for proprietary connections or fittings

1-3 EXCLUSIONS

The following types of vessels are excluded from this Standard:

- (a) nuclear reactor containments
- (b) pressurized airplane cabins
- (c) aerospace vehicle cabins
- (d) caissons

1-4 USER REQUIREMENTS

It is the responsibility of the user, or an agent acting for the user who intends that a PVHO be designed, fabricated, inspected, tested, marked, stamped, and certified to be in compliance with this Standard, to provide or cause to be provided for such PVHO, a User's Design Specification. The User's Design Specification shall set forth the intended operating conditions of the PVHO to provide the basis for design. It shall identify the external environment to which the PVHO will be exposed, the intended function of the PVHO, mechanical loads imposed on the PVHO, specific installation requirements, and applicable codes and standards.

1-5 MANUFACTURER'S DATA REPORT

(23)

The manufacturer or a designated agent shall make design calculations and prepare a Manufacturer's Data Report stating that the design, as shown on the design drawings, complies with this Standard and the User's Design Specification.

A registered Professional Engineer, or the equivalent in other countries, shall certify that the Manufacturer's Data Report is in compliance with this Standard and the User's Design Specification.

If required by the owner, state, or jurisdictional authorities, the PVHO manufacturer shall register and file data reports and viewport forms with the National Board of Boiler and Pressure Vessel Inspectors (1055 Crupper Avenue, Columbus, OH 43229). The data reports for ASME PVHO-1 are [PVHO-1 Form GR-1](#) and [PVHO-1 Form GR-1S](#); the viewport forms are [PVHO-1 Form VP-1](#) and [PVHO-1 Form VP-2](#). As applicable, the data reports for ASME BPVC, Section VIII are Division 1 Forms U-1 and U-2 or Division 2 Forms A-1 and A-2.

1-6 MATERIALS

All PVHO materials shall meet the requirements of this Standard.

Pressure vessel metallic material shall meet the specified Division of Section VIII of the ASME BPVC. Nonstandard materials shall be qualified for use as defined in [Nonmandatory Appendix D](#). The following materials shall not be used for pressure parts: SA-36, SA-283, SA-515, and cast and ductile iron.

Ferrous materials for PVHOs shall also comply with the following requirements:

(a) Except as provided for in (b), (c), (d), or (e), drop-weight tests in accordance with ASTM E208 shall be made on all wrought and cast ferrous materials. For plates, one drop-weight test (two specimens) shall be made for each plate in the as-heat-treated condition. For product forms other than plate, one drop-weight test (two specimens) shall be made for each heat in any one treatment lot. The sampling procedure for each form of material shall comply with the requirements of the specifications listed in ASME BPVC, Section VIII, Division 1, Table UG-84.3 or Section VIII, Division 2, para. 3.10.4, as applicable. The test shall be conducted at a temperature 30°F (17°C) lower than the minimum temperature for seamless and postweld heat-treated vessels, and 50°F (28°C) lower for as-welded vessels. The two specimens shall both exhibit no-broke performance.

(b) When, due to the material thickness or configuration, drop-weight specimens cannot be obtained, Charpy V-notch tests shall be conducted. The Charpy V-notch test of each material shall comply with the requirements of the applicable material specification or, when none is given, shall comply in all respects with the requirements of the applicable product form specifications listed in ASME BPVC, Section VIII, Division 1, Table UG-84.3 or Section VIII, Division 2, para. 3.10.4, as applicable. For either case, the test temperature shall not be higher than that specified in (a).

(c) As an alternative to the requirements of (a), those materials listed in ASME BPVC, Section II, Part A, SA-20, Table A1.15 may be accepted on the basis of Charpy V-notch testing. Testing shall be in accordance with the procedures contained in the specified Division of ASME BPVC, Section VIII, except that the acceptance criteria for plate shall be from each plate as heat treated. The

test temperature shall not be higher than that specified in (a) regardless of the temperature shown in SA-20, Table A1.15.

(d) Ferrous materials that are 0.625 in. (16 mm) or less in thickness are exempt from the additional toughness tests of (a) through (c) provided these materials are either of the following:

(1) normalized, fully killed, and made in accordance with fine grain practice

(2) fully killed, made in accordance with fine grain practice with a grain size of 5 or finer and an operating temperature of 50°F (10°C) or higher

(e) The additional toughness tests of (a) through (c) may be waived for the 300 series stainless steels.

(f) When the material has a specified minimum yield strength exceeding 60 ksi (414 MPa), weld metal and heat-affected zone impact properties for weld procedure qualifications and weld production tests shall also meet the requirements of the specified Division of ASME BPVC, Section VIII at a test temperature 30°F (17°C) lower than the design temperature, regardless of the value of the minimum design metal temperature.

PVHOs constructed of ferrous materials that are exposed to the corrosive effects of marine environments shall have provisions made for the desired life by a suitable increase in the thickness of the material over that required by the design procedures, or by using some other suitable method of protection.

1-7 DESIGN AND FABRICATION REQUIREMENTS

1-7.1 Joint Design

(23)

The design and fabrication shall be in accordance with the specified Division of ASME BPVC, Section VIII and the following requirements common to all PVHOs, unless otherwise permitted within this Standard:

(a) All joints of Categories A through C shall be Type No. 1 of Table UW-12 for ASME BPVC, Section VIII, Division 1 vessels or shall be weld joint Type 1 of Table 4.2.2 and meet the requirements of para. 6.2.4.1 for ASME BPVC, Section VIII, Division 2 vessels.

(b) All joints of Category D shall be full-penetration welds extending through the entire thickness of the vessel or nozzle wall and shall be Type No. 1 or Type No. 7 of Table UW-12 for ASME BPVC, Section VIII, Division 1 vessels or weld joint Type 1 or Type 7 of Table 4.2.2 for ASME BPVC, Section VIII, Division 2 vessels. Backing strips shall be removed.

(c) Intermediate heads may be designed in accordance with Figure UW-13.1(e) for ASME BPVC, Section VIII, Division 1 vessels only when the following conditions are met:

(1) The allowable stress used in the calculations for the intermediate head and for the shell that the intermediate head is attached to shall be 70% or less of the allowable stress found in ASME BPVC, Section II, Part D. This reduced allowable stress shall apply to the

shell only for a distance measured parallel along the shell of $2.5(R_mt_s)^{1/2}$ from the centerline of the butt weld to either side (t_{s1} or t_{s2}) [reference ASME BPVC, Section VIII, Division 1, Figure UW-13.1(e)]. R_m and t_s are the shell mean radius and thickness (in inches or millimeters), respectively, for the shell section under consideration.

(2) The flange of the intermediate head shall be at least $1\frac{1}{2}$ in. (38 mm) long and shall be welded to the shell with a minimum fillet weld of $t_h/2$ or $\frac{1}{4}$ in. (6.4 mm), whichever is less.

(3) The allowable stress value for the butt weld shall be 70% or less of the allowable stress value for the vessel material. The allowable stress value for the fillet weld shall be 55% or less of the allowable stress value for the vessel material [reference ASME BPVC, Section VIII, Division 1, UW-13(c)(2)].

(4) In addition to the strength requirements of para. 1-7.1, stiffener rings or other attachments exposed to a corrosive environment shall be seal welded by welds that are continuous on all sides.

(d) A spherical head segment may be attached to a cylindrical shell section to form an intermediate head, as shown in Figure 1-7.1-1, for PVHOs constructed in accordance with ASME BPVC, Section VIII, Division 1, provided the following conditions are met:

(1) Head thickness shall be calculated in accordance with ASME BPVC, Section VIII, Division 1, Mandatory Appendix 1, 1-6(g)(1)(-a) and 1-6(g)(1)(-b) with P being the maximum pressure acting on either side. For pressure on the convex side of the head, ASME BPVC, Section VIII, Code Case 2286-6 may be used to determine the head thickness as an alternative to ASME BPVC, Section VIII, Division 1, Mandatory Appendix 1, section 1-6. For differential pressure design, see ASME BPVC, Section VIII, Division 1, UG-19(a). The maximum intermediate head dish radius, L , shall be limited to the shell inside diameter.

(2) The stresses in the area of the head-to-shell joint shall be evaluated in accordance with ASME BPVC, Section VIII, Division 2, Parts 5.2 and 5.3. ASME BPVC, Section VIII, Division 1 allowable stresses shall be used as the basis for stress categorization. The cyclic loading conditions shall be evaluated or exempted per ASME BPVC, Section VIII, Division 2, Part 5.5.

(3) The weld shall be full penetration through the head thickness (see Figure 1-7.1-1).

(4) When the shell base material is formed from plate, the region 9 in. (230 mm) or $(R_{ts})^{1/2}$, whichever is greater, above and below the weld centerline shall be ultrasonically examined in accordance with SA-578, and the Level C acceptance criteria shall apply. R and t_s are the shell radius and thickness, respectively. For all shell product forms, the completed weld shall be ultrasonically examined after any postweld heat treatment (PWHT) in accordance with ASME BPVC, Section VIII, Division 1, Mandatory Appendix 12.

(5) After welding and any PWHT, the weld joint shall be examined by magnetic particle examination in accordance with ASME BPVC, Section VIII, Division 1, Mandatory Appendix 6 or by liquid penetrant examination in accordance with ASME BPVC, Section VIII, Division 1, Mandatory Appendix 8.

1-7.2 Welding

Pressure vessel welding shall be performed in accordance with ASME BPVC, Section IX.

1-7.3 Nondestructive Testing

All nondestructive testing shall conform to ASME BPVC, Section V.

(a) All Type No. 1 butt welds shall be 100% radiographed. All Type No. 7 corner welds shall be 100% ultrasonically examined. Both the above radiographic and ultrasonic inspections shall be performed in accordance with the specified Division of ASME BPVC, Section VIII.

(b) PVHO vessels that incorporate an intermediate head per para. 1-7.1(c) shall be inspected as follows:

(1) The butt weld joint shall be 100% radiographed and 100% ultrasonic examined per the requirements of ASME BPVC, Section VIII, Division 1 or Division 2.

(2) The butt weld, fillet weld, and/or seal weld shall be examined after hydrostatic test in accordance with (d).

(c) The reverse side of the root pass of double-welded joints shall be sound. This shall be shown by magnetic particle (MT) or liquid penetrant (PT) examination. If necessary, chipping, grinding, or melting-out may be required to ensure sound metal. Weld metal shall then be applied from the reverse side.

(d) After hydrostatic tests, all pressure-retaining welds and/or seal welds shall be examined in accordance with the requirements for either MT examination (ASME BPVC, Section V, Article 7) or PT testing (ASME BPVC, Section V, Article 6). The acceptance criteria shall be those of the applicable requirements of the specified Division of ASME BPVC, Section VIII.

1-7.4 Electrical Outfitting

All electrical penetrators through the pressure boundary shall be suitable for the environment in which they will operate in order to minimize the risk of fire, explosion, electric shock, emission of toxic fumes to personnel, and galvanic action on the pressure boundary.

Electrical penetrators and equipment shall not be damaged by pressurization and depressurization of the PVHO to operating pressures.

1-7.5 Viewports

Viewports shall conform to Section 2.

1-7.6 Penetrations

Penetrations of the pressure boundary shall comply with the following:

(a) Penetrators shall be constructed of material suitable for the intended service and compatible with the vessel shell material.

(b) Penetrators shall be either of standard piping components or of a port and insert construction. See [Nonmandatory Appendix B, Figures B-2-1 and B-3-1](#).

(c) Where a penetrator is of the port and insert construction, the insert shall be constructed of ASME PVHO material.

(d) Sealing surfaces of elastomer-sealed penetrators shall be protected from corrosion effects.

(e) Penetrators incorporating piping or commercial components shall be rated by the manufacturer to be suitable for the intended design pressure and temperature, and meet the testing requirements of [para. 1-7.8](#).

(f) Penetrators and inserts shall be tested in accordance with [para. 1-7.8](#).

Portions of the insert that become part of the pressure boundary shall be tested to the same pressure required for the PVHO. Portions of the insert that are subject to greater pressure than the pressure boundary shall be tested in accordance with the requirements of [Section 4](#).

(g) Except as permitted in (e), penetrations of the pressure boundary including piping, windows, manways, and service locks shall conform to the reinforcement requirements of ASME BPVC, Section VIII, Division 1 or Division 2. Plate material used as reinforcement shall meet the requirements of ASME BPVC, Section VIII, Division 1, Mandatory Appendix 20 or Section VIII, Division 2, section 3.9.

1-7.7 Inspection

All PVHOs and processes used in their manufacture shall be inspected in accordance with the manufacturer's quality assurance system, in accordance with [Section 3](#).

1-7.8 Testing

All PVHOs and pressure-retaining components of PVHOs shall demonstrate structural integrity through testing as follows:

(a) All internally pressurized vessels shall be tested according to the applicable Section of this Standard and/or the specified Division of ASME BPVC, Section VIII.

(b) Unless otherwise stated in this Standard, all externally pressurized vessels, regardless of the design rules used, shall be subjected to an external pressure test to a differential pressure not less than 1.25 times the maximum allowable working pressure (MAWP). The test pressure shall be maintained for not less than 1 hr. The differential test pressure may be achieved by a combination of internal and external test pressures.

(c) For hydrotest of vacuum only, or altitude (hypobaric) chambers, per ASME BPVC (2017 Edition), Section VIII, Division 1, UG-99(f), a vacuum test of 1.25 times the maximum allowable altitude shall be conducted and maintained for a minimum of 1 hr, provided the following tests have been performed:

(1) The pressure vessel shall be tested in accordance with ASME BPVC (2017 Edition), Section VIII, Division 1, UG-99(f).

(2) Windows shall be tested according to [subsection 2-7](#).

1-7.9 Documentation

(23)

1-7.9.1 PVHO Pressure Vessel Manufacturer Documentation. The manufacturer (PVHO) shall provide the owner/user or designated agent a copy of the Manufacturer's Data Report [[PVHO-1 Form GR-1 \(PVHO-1 Form GR-1S\)](#)] and Forms U-1 and U-2 (Division 1) or Forms A-1 and A-2 (Division 2), as applicable, for PVHOs built to ASME BPVC, Section VIII. The manufacturer (PVHO) shall retain a copy of the Manufacturer's Data Report ([PVHO-1 Form GR-1](#)); applicable ASME BPVC, Section VIII forms; and all viewport-supporting documents per [Section 2](#) on file for at least 10 yr from the date of manufacture. Nondestructive testing documentation shall meet the requirements of ASME BPVC, Section V. In addition to the aforementioned documentation, the manufacturer (PVHO) shall furnish the following documentation to the user or designated agent:

(a) instructions critical to the maintenance of the PVHO
(b) instructions critical to the operation of the PVHO and subsystems (operating procedures)

(c) coating/painting information

(d) photocopy or equivalent of the PVHO data plate

(e) list of standards used

(f) seal and gasket sizes and materials

(g) User's Design Specification

(h) evidence of successful completion of any tests required in [para. 1-7.8](#)

(i) system schematics (life support, hydraulics, electrical, communications, etc.)

(j) system descriptions (life support, hydraulics, electrical, communications, etc.)

(k) assembly drawings, including viewport assembly drawings that provide the general dimensions, seat and seal configuration, and retainer ring and fastener details

(l) equipment documentation (technical manuals, catalog cuts, etc.)

In lieu of the manufacturer retaining the above data reports and viewport forms for 10 yr, the manufacturer may register and file the reports and forms with the National Board of Boiler and Pressure Vessel Inspectors (1055 Crupper Avenue, Columbus, OH 43229).

1-7.9.2 PVHO Systems Integrator Documentation.

Where the systems integrator is not the same as the pressure vessel manufacturer, complete [PVHO-1 Form GR-2](#) ([PVHO-1 Form GR-2S](#)).

1-7.10 Piping

Unless otherwise permitted within this Standard, piping shall conform to the requirements of [Section 4](#).

1-7.11 Opening Reinforcements

All opening reinforcements shall be integral with the nozzle and/or shell. Reinforcement pads are not permitted.

1-7.12 Brazed or Riveted Construction

Brazed or riveted construction is prohibited on the pressure boundary.

1-7.13 Hatch Design

Hatches that do not use bolts for attachment may be designed in accordance with the requirements of ASME BPVC, Section VIII, Division 1, Mandatory Appendix 1, 1-6(g) with the following conditions:

- (a) The circular centerline of the spherically dished head shall pass through the centroid of the flange.
- (b) The connection of the dished head to the flange shall include one or more fillets of radius not less than 10 mm.
- (c) If an O-ring seal is specified, it shall be located at the mean radius of the flange.
- (d) Hatch construction shall be from materials that meet ASME PVHO requirements.
- (e) If the hatch is convex to pressure, the minimum thickness of the head shall be the greater of that determined in ASME BPVC, Section VIII, Division 1, Mandatory Appendix 1, 1-6(g) or that calculated from [Nonmandatory Appendix G](#).
- (f) The design of doors and hatches shall have a safety interlock system if pressure acts to open or unseat the door or hatch. The safety interlock system shall not permit pressurization of the door or hatch unless the door/hatch closure is fully engaged.

1-7.14 Rectangular Door Design

If rectangular openings are employed in ASME BPVC, Section VIII, Division 1 or Division 2 construction, a detailed analysis of the interaction of the entire assembly (i.e., door, door frame, adjacent shell, and relative appurtenances) shall be performed to ensure the design is adequate for the intended application. For Division 2 vessels, the analysis shall be performed in accordance with ASME BPVC, Section VIII, Division 2, Part 5. For Division 1 vessels, see ASME BPVC, Section VIII, Division 1, U-2(g).

1-7.15 Supports and Attachments

Consideration shall be given to the following:

- (a) The design shall consider the external local forces transmitted to the PVHO.
- (b) Only those materials permitted for shells may be used for welded lifting attachments, and the material shall be compatible with that of the shell.

1-8 PRESSURE RELIEF DEVICES

Unless otherwise specified, the following requirements shall be met for pressure relief devices installed on PVHOs.

- (a) The applicable requirements of ASME BPVC, Section VIII, Division 1, UG-125 through UG-136 or Section VIII, Division 2, Part 9 shall be met.
- (b) A quick-operating manual shutoff valve shall be installed between the PVHO and the pressure relief valve, and shall be normally sealed open with a frangible seal as permitted in ASME BPVC, Section VIII, Division 1, UG-135(e) and Nonmandatory Appendix M, and Division 2, Annex 9.A. The valve shall be readily accessible to the attendant monitoring the operation of the PVHO.
- (c) Rupture disks shall not be used, except in series upstream of pressure relief valves to prevent gas leakage, and shall meet all other applicable requirements of the ASME BPVC.

1-9 MARKING

(23)

1-9.1 PVHO Pressure Vessel Manufacturer Marking

- (a) Each PVHO shall be marked with the following:
 - (1) designation of this Standard, PVHO-1
 - (2) name of the manufacturer of the pressure vessel, preceded by the words "Certified by"
 - (3) maximum allowable working pressure, psig (MPa gauge) (internal) and/or psig (MPa gauge) (external) at °F (°C) maximum and °F (°C) minimum
 - (4) manufacturer's serial number
 - (5) year built
 - (6) design criteria: PVHO-1-2023, Section (e.g., 5, 6, or 7 as applicable)
- (b) The marking described in (a) shall be on a nameplate substantially as shown in either [Figure 1-9.1-1](#) or [Figure 1-9.1-2](#), as applicable. It shall be of material suitable for the intended service and remain legible for the life of the vessel. Nameplates shall be located in a conspicuous place on the vessel.
- (c) Nameplates shall have markings produced by casting, etching, embossing, debossing, stamping, or engraving, except that the "PVHO-1" lettering shall be stamped on the nameplate.

(1) The required marking on the nameplate shall be in characters not less than $\frac{5}{32}$ in. (4.0 mm) high, except the lettering "PVHO-1" shall not be less than $\frac{3}{8}$ in. (9.5 mm) high and shall be legible.

(2) Characters for metallic nameplates shall be either indented or raised at least 0.004 in. (0.10 mm).

(d) The nameplate may be marked before it is affixed to the vessel, in which case the manufacturer shall ensure that the nameplate with the correct marking has been applied to the proper vessel.

(e) The nameplate shall be permanently attached to the vessel or to a pad, bracket, or structure that is welded or soldered directly to the vessel. The nameplate shall be located within 30 in. (76 cm) of the vessel. Removal shall require willful destruction of the nameplate or its attachment system.

(f) In addition to the requirements of (a) through (d), the applicable stamping requirement of the specified Division of ASME BPVC, Section VIII shall be met.

1-9.2 PVHO Systems Integrator Marking

(a) Where the systems integrator is not the same as the pressure vessel manufacturer, a second nameplate shall be attached as shown in Figure 1-9.2-1 or Figure 1-9.2-2.

(b) The Systems Integrator nameplate shall be of material suitable for the intended service, shall remain legible for the life of the vessel, and shall comply with paras. 1-9.1(c) through 1-9.1(f).

(c) In the ASME PVHO-1 systems section of the nameplate, stamp 5, 6, or 7 where applicable or stamp "Altitude" in the case of altitude systems.

1-10 NONMETALLIC MATERIALS AND TOXICITY OFF-GAS TESTING

(a) All nonmetallic materials off-gas volatile substances that may be toxic. The rate of off-gassing increases with increasing temperature and decreases with increasing age of the material (e.g., plastics and paint).

(b) In PVHOs whose primary means of life support is by ventilation of the atmosphere and/or by mask supply from an external gas source, off-gassed volatiles are continuously removed and are normally not of consequence, such that the procedures in (d) need not apply.

(c) In PVHOs where the primary means of life support is by addition of oxygen and removal of carbon dioxide (CO₂), off-gassed volatiles will accumulate. Thus, after fabrication and completion of all outfitting, the toxicity off-gas test procedures in (d) are required of any such PVHO that has internal paint or contains nonmetallic materials (other than acrylic windows).

(d) Toxicity Off-Gas Testing Procedures

(1) Internally pressurized PVHOs should be pressurized to MAWP at least once and then thoroughly ventilated prior to doing the off-gas testing.

(2) Where the normal duration of PVHO occupation is less than 8 hr, the PVHO shall be sealed and maintained at maximum operating temperature for at least 8 hr, after which time atmospheric gas samples shall be obtained from inside the PVHO and analyzed. The off-gassing test shall be performed with all openings sealed and with the PVHO at 1 atm (nominal), regardless of MAWP. However, a slight pressurization of the PVHO (prior to closing or sealing) may be used to aid in obtaining gas samples.

(3) The gas sample shall be analyzed using appropriate gas chromatography/mass spectrometry (GC/MS) methods. The concentration level of volatile compounds shall not exceed the threshold limit values (TLVs) set forth in the current edition of *ACGIH Threshold Limit Values for Chemical Substances* or the OSHA permissible exposure limits (PELs) set forth in 29 CFR 1910.1000, as stipulated by the user. If any of those limits are exceeded, the PVHO shall be well ventilated with clean air, and the procedure shall be repeated until satisfactory results are obtained.

(4) The use of higher temperatures and/or longer durations to "bake out" sources of contaminants prior to testing is permitted. Care shall be taken not to exceed the design temperature of components including acrylic windows.

(5) Where normal durations of PVHO occupation exceed 8 hr, the previous procedures apply with the exception that the PVHO shall be sealed and maintained at maximum operating temperature for at least the maximum duration of exposure anticipated. The ACGIH TLVs (or OSHA PEL values) used for evaluation shall be modified by multiplying them by a value of F_p as shown in Table 1-10-1 (linear interpolation is permitted).

(6) Where normal durations of PVHO occupation exceed 24 hr, the duration of off-gas may be less, provided that the quantification and reporting limits are less than the allowable limits divided by the ratio of occupation duration divided by test duration. And the results obtained would then be extrapolated by multiplying by the same ratio of occupation duration divided by test duration. For example, in the case of "screening" [see (10)], if the anticipated occupation duration is 5 days, the off-gas duration may be limited to 24 hr, with the results multiplied by 5, provided that the quantification and reporting limits were less than 5 parts per million (ppm) (vs. 25 ppm allowed) for total hydrocarbons and 2 ppm (vs. 10 ppm allowed) for total halogens. However, if the extrapolated results (after multiplying by 5) exceeded 25 ppm and/or 10 ppm, respectively, then the quantity of gas sample for GC/MS analysis would need to be sufficient to provide quantification and reporting limits of 20 parts per billion (ppb) (vs. 0.1 ppm). And if that were not practical, then the time ratio used in the testing would need to be appropriately less.

(7) For PVHOs that use hydroxide absorbents (e.g., LiOH, soda lime) for the removal of carbon dioxide (CO₂), the concentrations of trichloroethylene, vinylidene chloride, methyl chloroform, and acetylene dichloride shall not exceed 0.1 ppm, regardless of their ACGIH TLV (or OSHA PEL) or duration of occupation; i.e., Table 1-10-1 does not apply to those four compounds.

(8) Where reactive compounds (e.g., ammonia, chlorine, hydrogen sulfide, sulfur dioxide) are anticipated, on-site testing for the presence of these compounds should be done using appropriate color-change indicator tubes (e.g., Draeger, Gastec). Evaluation of the test results shall be in accordance with (3), (5), or (6), as applicable.

(9) Where potential sources of mercury vapor are anticipated, on-site testing for its presence should be done using either color-change indicator tubes with a sufficiently low detection limit or a gold-film-type analyzer. Evaluation of test results shall be in accordance with (3), (5), or (6), as applicable.

(10) If the total halogen concentration can be shown to be less than 10 ppm, and the total hydrocarbons (expressed as methane) can be shown to be less than 25 ppm, then the GC/MS analysis and evaluation need not be done. However, if either of those limits is exceeded, the GC/MS analysis and evaluation are required.

1-11 RISK ANALYSIS

The PVHO designer shall implement and document an established standard or procedure (such as a failure-modes, effects, and criticality analysis or a safety-hazards analysis) for evaluating and mitigating potential risks associated with the PVHO and associated systems. Potential hazards shall include both hardware failure and operator error. The risks identified shall be evaluated and mitigated to a level acceptable by the user or appropriate authority. Mitigation and protective measures may include design features that minimize the probability of occurrence, inspection and tests during and following fabrication, implementation of safety and/or warning devices, protective systems, and caution or warning procedures and labels. The risk analysis results shall be retained by the designer in accordance with para. 1-7.9.

1-12 LITHIUM BATTERIES

1-12.1 Scope

The requirements of this subsection apply to rechargeable and nonrechargeable lithium batteries that are used as the main or emergency source of power for the PVHO. These include, but are not limited to, lithium ion, lithium alloy, lithium metal, and lithium polymer type batteries, or other lithium battery chemistries that have the potential for self-sustaining energy release.

1-12.2 Exclusions

Lithium batteries used for portable equipment, e.g., laptops, cell phones, cameras, or other portable equipment, are not included under the scope of these requirements.

1-12.3 Certification

Lithium batteries shall be certified by a third-party independent agency, e.g., Underwriters Laboratories (UL) or Canadian Standards Association (CSA), as complying with the requirements of one of the following standards:

- (a) Section 38.3, UN Manual of Tests and Criteria
- (b) UL 1642, UL Standard for Safety of Lithium Batteries
- (c) other equivalent recognized national or international standards for lithium batteries

1-12.4 Installation

(a) Unless otherwise permitted by the jurisdictional authority, lithium batteries shall be installed outside the occupied pressure boundary of the PVHO.

(b) All installations shall include appropriate means to prevent inadvertent shorting between the terminals of lithium batteries (e.g., nonshorting caps).

(c) Prior to installation, a risk analysis shall be carried out for evaluating and mitigating potential risks associated with the lithium battery installation, as well as the normal and emergency operating procedures.

1-12.5 Battery Housings

Lithium batteries may be installed in either a 1-atm housing or a pressure-compensated housing.

(a) *General Requirements.* All battery installations housing lithium batteries shall meet the following general requirements:

(1) The housings shall be installed in locations that are as far away as practicable from sources of heat, compressed gas cylinders, and acrylic windows on PVHOs.

(2) The housings shall be mechanically protected from direct impact loads. For PVHOs that are transported while in service (e.g., diving bells or submersibles), the battery housing shall also be protected from acceleration shock loads.

(3) The housings shall be provided with means of pressure relief (such as blowout plugs or vents) in order to relieve any potential pressure buildup within the housing due to malfunctioning batteries. The discharge of the means of pressure relief shall be vented as far away as practicable from sources of heat, compressed gas cylinders, and acrylic windows on PVHOs.

(4) All electrical circuits shall be insulated and isolated from the structural elements of the housings.

(5) The housings shall be labeled appropriately and shall be provided with appropriate signs warning personnel against inadvertent abuse.

(b) *1-atm Housings.* When lithium batteries are installed in 1-atm housings, the following additional requirements shall be met:

(1) The housings shall be designed to permit purging and charging of the internal atmosphere with inert gas, so as to minimize the oxygen concentration below the flammable limit.

(2) All of the electrical equipment within the housings shall be of the explosion-proof type.

(3) Water intrusion sensors, fire detectors, and pressure and temperature sensors, as appropriate, shall be provided within the housings. These devices shall activate audiovisual alarms in order to alert the PVHO operator of an adverse event (e.g., a fire or water leakage) within the housing.

(4) When the battery housings are contiguous with the pressure boundary of the PVHO, these housings shall meet the “A60” structural fire protection rating as defined by the IMO International Code for Application of Fire Test Procedures (FTP Code), or equivalent recognized standards.

1-12.6 Battery Management System (BMS) for Rechargeable Batteries

Rechargeable lithium battery installations shall be provided with an electronic BMS.

(a) The BMS shall provide means for

(1) monitoring the state of charge and state of health of the batteries

(2) charge control to prevent overcharging/undercharging and voltage reversal

(3) discharge control to prevent overdischarging

(4) intermodule and intramodule balancing of the cells

(5) overcurrent (short circuit) protection to prevent overcurrent discharge

(b) The BMS shall provide real-time performance monitoring of the following parameters:

(1) voltages (cell level and module level)

(2) currents (cell level and module level)

(3) state of charge and state of health (module level)

(4) temperature (module level)

(c) Appropriate sensors and audiovisual alarms shall be provided to alert the PVHO operator when the parameters in (b) are outside their allowable limits.

1-12.7 Protection for Nonrechargeable Batteries

Nonrechargeable lithium battery installations shall be provided with the following:

(a) over-temperature protection

(b) overcurrent (short circuit) protection

(c) voltage reversal protection

1-12.8 Testing

(a) Lithium batteries exposed to ambient pressures exceeding 1 atm shall be hydrostatically pressure tested prior to being placed in service. The pressure testing shall be carried out to the maximum rated depth of the PVHO. Satisfactory operation of the batteries shall be demonstrated during this pressure testing.

(b) For rechargeable batteries, functional testing of the BMS (see para. 1-12.6) shall be carried out.

(c) For nonrechargeable batteries, functional testing of the battery protection devices (see para. 1-12.7) shall be carried out.

1-12.9 Charging

(a) For rechargeable lithium batteries, the charging procedures shall be documented in the operations and maintenance manuals of the PVHO.

(b) As a minimum, the charging procedures shall follow the battery manufacturer’s recommendations and specifications.

(c) Charging of lithium batteries shall be carried out while the PVHO is not in service, using the manufacturer-specified battery chargers.

1-12.10 Replacement

(a) Lithium batteries (including individual cells) shall be replaced, taking the following into consideration:

(1) manufacturer’s recommendations and specifications

(2) visual inspection

(3) deterioration of performance

(b) The replacement shall be carried out when the PVHO is not in service.

1-12.11 Manuals and Records

(a) The normal and emergency operating and maintenance procedures for the use of lithium batteries shall be documented in the operations and maintenance manuals of the PVHO.

(b) As a minimum, these procedures shall follow the battery manufacturer’s recommendations and specifications.

(c) The emergency procedures shall address events such as fires, thermal runaways, short circuits, leaks, hazardous gas buildup, low-temperature charging, electrical shocks, and stored energy hazards, as applicable.

(d) Any special measures taken for mitigating or eliminating potential risks [see para. 1-12.4(c)] shall be documented in the operations and/or maintenance manuals.

(e) A log shall be maintained to record vital information such as the installation dates and maintenance history of the batteries.

1-13 AUTOMATIC CONTROL AND SOFTWARE SAFETY

Software risk is a function of the potential severity of mishap in conjunction with the degree of autonomy exerted by the software. The risk mitigation consists of software (code) analysis, testing, and validation, with the level of rigor applied being commensurate with the potential level of risk. The following shall apply to PVHOs that employ software to monitor and/or control safety-critical systems or functions.

The PVHO designer shall implement and document a software safety analysis (including analysis, testing, and validation) that is in accordance with an established standard or procedure. Examples include (but are not limited to) the (DOD) Joint Software Systems Safety Engineering Handbook and (FDA) General Principles of Software Validation: Final Guidance for Industry and Staff.

This safety analysis shall be performed by a qualified person other than the software developer, and the results of the software safety analysis, testing, and/or validation shall be retained by the designer in accordance with [para. 1-7.9](#).

Additionally, there shall be an independent method of monitoring and manually controlling all life-critical systems. If applicable, the risk analysis should consider

risks potentially associated with connection to the Internet and/or third-party data centers.

1-14 OPERATIONAL PRESSURE CYCLE

(23)

Before a PVHO may be put into service, a registered Professional Engineer, or similar, knowledgeable about the design and intended usage of the PVHO system shall review the User Requirements and all other available design and usage information to assess the need to require tracking of pressure cycles during operation of the PVHO chamber, components, and system (e.g., for fatigue analysis, fracture mechanics analysis, and fitness-for-service assessments). If it is determined that tracking of operational pressure cycles is required, one or more definitions for "operational pressure cycle" shall be provided by a registered Professional Engineer, or similar, knowledgeable about the design and intended usage of the PVHO system. This definition shall include all relevant parameters (e.g., pressure, temperature, and time) that impact the minimum pressure differential that shall be recorded during usage to track available life for the PVHO chamber, components, and system. It should also include any threshold conditions beneath which an increase in pressure should not be counted as a pressure cycle. Various components may require their own unique definition of an operational pressure cycle.

PVHO-1 Form GR-1 Manufacturer's Data Report for Pressure Vessels for Human Occupancy
As Required by ASME PVHO-1

1. Design criteria _____
2. Manufactured and certified by _____
3. Manufactured for _____
4. Location of installation _____
5. Type _____
(drawing no.) (manufacturer's serial no.) (year built)
6. The chemical and physical properties of all parts meet the requirements of material specifications of ASME PVHO-1-_____(year)
and Addenda to _____ and Case nos. _____. In addition, the design, construction, and
(date)
workmanship conform to ASME Section VIII, Division _____, _____ and Addenda to _____ and
(1 or 2) (year) (date)
Code Case nos. _____.
7. Constructed for maximum allowable working pressure of _____ psi (internal) and/or _____ psi (external),
at a maximum temperature of _____ °F and/or minimum temperature of _____ °F, and hydrostatic test pressure
of _____ psi (internal) and/or _____ psi (external).
8. Service: Fatigue analysis required _____
(yes or no) (describe service)
9. Windows: Certification Reports, properly identified and signed by the window fabricator, are attached for the following items:

No.	Location	Type	Diameter or Size	Nominal Thickness	How Attached

10. Manufacturer's Data Report/Partial Data Reports, completed in accordance with ASME BPVC, Section VIII, Division _____
(1 or 2)
and properly identified and signed by Commissioned Inspectors, are attached for the following items (use PVHO-1 Form GR-1S for
additional items, if necessary):

Data Report	Remarks (Name of Part, Manufacturer's Name, and Identifying Stamp)

CERTIFICATION OF DESIGN

User's Design Specification on file at _____

Manufacturer's Design Report on file at _____

User's Design Specification certified by _____ P.E. State _____ Reg. no. _____

Manufacturer's Design Report certified by _____ P.E. State _____ Reg. no. _____

CERTIFICATION OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this
vessel conform to the ASME Safety Standard for Pressure Vessels for Human Occupancy (PVHO-1).


ASME Certificate of Authorization _____, Certificate no. _____ Exp. date _____
(U or U2)

Date _____, 20____ Company name _____ Signed _____
(PVHO manufacturer) (representative)

GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than
republishing.

(23)

Figure 1-7.1-1
Spherical Intermediate Head Attachment



ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

Figure 1-9.1-1
Form of Nameplate, U.S. Customary Units

(23)

PVHO-1	
Certified by	

(name of manufacturer)	
_____ psi internal	_____ psi external
(maximum allowable working pressures)	
_____ °F maximum	_____ °F minimum
(design temperature range)	
_____	_____
(manufacturer's serial no.)	(year built)

(design criteria)	

Figure 1-9.1-2
Form of Nameplate, SI Units

(23)

PVHO-1	
Certified by	

(name of manufacturer)	
_____ MPa internal	_____ MPa external
(maximum allowable working pressures)	
_____ °C maximum	_____ °C minimum
(design temperature range)	
_____	_____
(manufacturer's serial no.)	(year built)

(design criteria)	

(23)

Figure 1-9.2-1
Form of Nameplate With Systems Integrator, U.S. Customary Units

PVHO-1 Systems Integrator	
_____ (PVHO systems integrator)	
_____ (integrated systems serial no.)	_____ (year built)
_____ psig internal	_____ psig external
(maximum operating pressures)	
_____ °F maximum	_____ °F minimum
(operational temperature range)	
_____ (ASME PVHO-1 systems sections)	

(23)

Figure 1-9.2-2
Form of Nameplate With Systems Integrator, SI Units

PVHO-1 Systems Integrator	
_____ (PVHO systems integrator)	
_____ (integrated systems serial no.)	_____ (year built)
_____ MPa internal	_____ MPa external
(maximum operating pressures)	
_____ °C maximum	_____ °C minimum
(operational temperature range)	
_____ (ASME PVHO-1 systems sections)	

Table 1-10-1
Conversion Factor, F_p (for PVHO Occupation Exceeding 8 hr)

Duration of Exposure	F_p
8 hr (or less)	1.0
12 hr	0.85
16 hr	0.75
24 hr	0.65
36 hr	0.56
48 hr	0.52
72 hr	0.46
7 days	0.37
14 days	0.32
30 days	0.28
60 days	0.26
90 days (or longer)	0.25

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

Section 2 Viewports

2-1 GENERAL

2-1.1 Scope

This Standard covers windows manufactured during original construction and windows used as replacements during the service life of the chamber.

The windows covered by this Standard are intended for use only in chambers with window service conditions defined by

- (a) maximum allowable working pressure, equal to design pressure
- (b) maximum temperature at design pressure, equal to design temperature
- (c) pressure cycles, at design pressure and temperature

2-1.2 Exclusions

The windows covered by this Standard are not intended for chambers where any of the following restrictions on design parameters are exceeded:

- (a) The operating temperature shall be within the 0°F to 150°F (−18°C to 66°C) range.
- (b) The pressurization or depressurization rate shall be less than 145 psi/sec (1 MPa/s).
- (c) The fluid (external or internal) shall be only water, seawater, air, or gases used in life-support systems.
- (d) The number of pressure cycles or the total duration of the operational life of the window shall not exceed 10,000 cycles or 40,000 hr, respectively.
- (e) The maximum operational pressure shall not exceed 20,000 psi (138 MPa).
- (f) The exposure to nuclear radiation shall not exceed 4 Mrad.
- (g) The design life of the windows shall not exceed the time limits specified in [para. 2-2.6](#).

2-1.3 Certification

Each window shall be individually identified by the window fabricator in accordance with [para. 2-6.1](#).

2-1.3.1 Traceability. The window fabricator shall provide an overall window certification that shall certify that the window has been fabricated in accordance with all applicable requirements of the Standard (see [PVHO-1 Form VP-1](#) for a representative certification form). The window certification shall provide traceability

of the window throughout all processes associated with its manufacture.

2-1.3.2 Additional Requirements. In addition to the overall window certification, the following certifications shall be required for a window to be considered acceptable for use in chambers: (23)

(a) a design certification for each window and matching viewport assembly that shall include a summary of engineering calculations and/or a description of the experimental method and data used to verify compliance of the window design with the requirements of this Standard (see [subsection 2-2](#) for design requirements).

(b) a material manufacturer's certification for each lot of acrylic that shall certify that the material meets or exceeds the minimum values of physical properties specified in [Table 2-3.4-1](#) for each lot and verify for each casting or lot (see [subsection 2-3](#) for material certification requirements).

(c) a material certification for each window that shall certify that the material meets the minimum values specified in [Table 2-3.4-2](#) and that these properties have been experimentally verified. Average values specified in [Table 2-3.4-2](#) shall be reported (see [subsection 2-3](#) for material certification requirements).

(d) a pressure testing certification for each window that shall describe the pressure, temperature, pressurization rate, duration of sustained loading, and viewport flange or test fixture used during the pressure test (see [subsection 2-7](#) for pressure testing requirements).

2-1.4 Nomenclature

(23)

Symbols used in this Section are as follows:

- b = width of NEMO window hatch mating flange, in.
- CF = conversion factor, unitless
- C_i = internal clearance between inside diameter of hyperhemisphere window and seat, in.
- C_o = external clearance between outside diameter of hyperhemisphere window and seat, in.
- CPP = crack-free cyclic proof pressure, psi (MPa)
- D_f = inside diameter of window seat bearing flange, in. (mm)
- D_h = diameter of opening in the pressure hull for hyperhemispherical window, in.

D_i = window minor diameter, in. (mm)
 D_o = window major diameter, in. (mm)
 D_s = inside diameter of flat disk window seat cavity, in. (mm)
 E_s = orientation of effective radial stiffness for NEMO window, unitless
 g = thickness of plastic insert for NEMO window, in.
 K = depth of window seat bearing flange, in.
 k = thickness of compression gasket for NEMO window, in.
 K_i = inner diameter of conical seat for hyperhemisphere window, in.
 K_o = inner diameter of window penetration for hyperhemisphere window, in.
 L = length between supports for cylindrical window, in. (mm)
 l = edge length of a spherical sector or double-bevel window, in. (mm)
 ℓ_s = depth of window seat for spherical sector window with square edge, in.
LTPP = long-term proof pressure, psi (MPa)
 M = width of equatorial flange for a hemispherical window, in.
 m = elevation of hatch ring for NEMO window, in.
 M_c = bearing seat width for cylindrical window subjected to external pressure, in.
 N = operational pressure range category, unitless
 n = seal gland depth for double-bevel window seat, in.
 P = design pressure, psi (MPa)
 R_1 = corner radius at bearing face of window seat flange, in.
 R_e = inner edge fillet radius for hemispherical window with equatorial flange, in.
 R_f = internal radius of window seat, in. (mm)
 $= D_f/2$
 R_i = inside radius of curvature, in.
 R_k = external radius of window seat for cylindrical windows, in.
 R_m = fillet radius between hemispherical portion of window and flange for hemispherical window with equatorial flange, in.
 R_n = fillet radius inside window seat edge for cylindrical windows, in.
 R_o = outside radius of window, in. (mm)
 $= D_o/2$
STCP = short-term critical pressure, psi (MPa)
STPP = short-term proof pressure, psi (MPa)
 t = window thickness, in. (mm)
 X = combined thickness of NEMO window hatch flange and mating flange, in.
 z = hub thickness of NEMO window hatch mating flange, in.
 α = conical included angle, deg
 β = viewing angle of window seat, deg

γ = spherical angle of hatch seat for NEMO window, deg
 ε = spherical angle of split retaining ring for NEMO window, deg
 η = coefficient used to determine STCP for cylindrical windows under external pressure, unitless
 θ = angle between adjacent penetrations in NEMO window, in.
 ϕ = conical seat angle of window penetration or insert, deg
 ω = angle between adjacent penetrations in NEMO window, in.

2-2 DESIGN

2-2.1 General

The manufacturer of the chamber shall be responsible for ensuring that the viewport design is adequate for the design conditions of the chamber. Particular attention shall be paid to design consideration of the window, including, but not limited to, the design pressure, the temperature at design pressure, and the cyclic life at design pressure.

An ASME PVHO-1 acrylic window may be assigned more than one pressure-temperature rating, provided

(a) The window is in complete compliance with [Section 2](#) for each pressure-temperature rating.

(b) [PVHO-1 Form VP-2](#) (Acrylic Window Design Certification) must be completed and signed for each pressure-temperature rating.

(c) The pressure test shall be performed at the pressure-temperature rating that requires the largest minimum thickness, t (calculated). If the minimum thickness is the same, the pressure test shall be performed at the highest pressure.

(d) The window shall be marked in accordance with this Standard for each pressure-temperature rating.

2-2.2 Standard Window Geometry

2-2.2.1 Configuration. Acrylic windows in chambers must have one of the standard geometries shown in [Figures 2-2.2.1-1 through 2-2.2.1-4](#). Minimum acceptable thickness ratios shall comply with the requirements of [Figures 2-2.2.1-1 through 2-2.2.1-4](#) for the specific window geometry. (For acceptance of nonstandard window geometries, see [subsection 2-11](#).)

2-2.2.2 Calculation. Calculations of the short-term critical pressure (STCP), on the basis of [Figures 2-2.2.1-1 through 2-2.2.1-4](#), satisfy the requirements of the design certification required by this Standard under [para. 2-1.3.2\(a\)](#).

2-2.2.3 Tests. It shall also be acceptable to establish the STCP by conducting a series of destructive tests on full-scale or model-scale windows performed in accordance with the procedure in [para. 2-2.5.2](#).

2-2.3 Determination of Dimensions for Standard-Geometry Windows

2-2.3.1 0 psi to 10,000 psi. The dimensions of a standard window in the 0 psi to 10,000 psi (0 MPa to 69 MPa) design pressure range shall be based solely on the window's STCP and the approved conversion factor (CF) for the given maximum ambient temperature. Minimum STCP values of standard window geometries are given in [Figures 2-2.5.1-1 through 2-2.5.1-15](#). CF values for standard window geometries are given in [Tables 2-2.3.1-1 through 2-2.3.1-5](#).

2-2.3.2 10,000 psi to 20,000 psi. The dimensions of windows in the 10,000 psi to 20,000 psi (69 MPa to 138 MPa) design pressure range shall be based solely on nondestructive tests in the form of long-term and cyclic pressurizations. Dimensions of approved windows for this design pressure range are given in [Table 2-2.3.2-1](#). Only conical frustum windows with included angle of 90 deg or larger are qualified for this pressure range.

2-2.4 Determination of Conversion Factor by Table Method

2-2.4.1 Temperature. When selecting the conversion factors from [Tables 2-2.3.1-1 through 2-2.3.1-5](#), temperature ranges shall be chosen on the basis of highest ambient sustained temperature expected during operation of the chamber at the design pressure.

(a) If the chamber interior is illuminated by externally mounted heat-generating lights shining through the windows, the 150°F (66°C) temperature range shall be mandatory in the selection of conversion factors for all windows.

(b) If the chamber is not illuminated with externally mounted lights, the temperature ranges shall be chosen on the basis of environmental temperature where the chambers reach design pressure. If the design pressure is reached when

(1) only submerged in water, use the ambient temperature of water at that depth

(2) only in air, use the average of the maximum ambient external and internal air temperatures

(3) either in air or in water, use the average maximum ambient external and internal air temperatures

2-2.4.2 Pressure. When a viewport is subjected to pressurization from both sides, the conversion factor used for the window design shall be determined on the basis of the highest design pressure, regardless of

whether this pressure is external or internal to the chamber.

2-2.4.3 Values of Conversion Factors. The values of CF in [Tables 2-2.3.1-1 through 2-2.3.1-5](#), D_i/D_f in [Figures 2-2.9.1-1 and 2-2.9.1-2](#) and [Table 2-2.3.2-1](#), and t/D_i in [Table 2-2.3.2-1](#) represent minimums. The user of this Standard may exceed these values.

2-2.5 Determination of Short-Term Critical Pressure

2-2.5.1 Calculation Method. The STCP of a window accepted for service in chambers, without the use of experimental data, shall not be less than

$$\text{STCP} = \text{CF} \times P$$

where

CF = conversion factor

P = design pressure

Windows having included angles between those shown in [Figures 2-2.5.1-4 through 2-2.5.1-7](#) are to have a t/D_i equal to that determined for a window of the next smaller included angle as shown in the appropriate figure. (For example, a spherical sector window having an included angle of 100 deg and requiring an STCP in the 5 MPa to 50 MPa range would be designed using the 90-deg curve in [Figure 2-2.5.1-6](#).)

(a) For flat disk acrylic windows, shown in [Figure 2-2.2.1-1](#), use conversion factors from [Table 2-2.3.1-1](#) and STCPs from [Figures 2-2.5.1-1 through 2-2.5.1-3](#). Short-term critical pressures may also be experimentally determined according to the procedure in [para. 2-2.5.2](#).

(b) For conical frustum acrylic windows, shown in [Figure 2-2.2.1-1](#), use CFs from [Table 2-2.3.1-2](#) and STCPs from [Figures 2-2.5.1-4 and 2-2.5.1-5](#). Short-term critical pressures may also be experimentally determined according to the procedure in [para. 2-2.5.2](#). Windows of this type are accepted for service only where the pressure is applied to the base of the frustum.

(c) For double-beveled disk acrylic windows, shown in [Figure 2-2.2.1-1](#), use CFs from [Table 2-2.3.1-2](#) and STCPs from [Figures 2-2.5.1-4 and 2-2.5.1-5](#). Short-term critical pressures may also be experimentally determined according to the procedure in [para. 2-2.5.2](#).

(d) For spherical sector acrylic windows with conical edge, shown in [Figure 2-2.2.1-2](#), use CFs from [Table 2-2.3.1-3](#) and STCPs from [Figures 2-2.5.1-6 and 2-2.5.1-7](#). Short-term critical pressures may also be experimentally determined according to the procedure in [para. 2-2.5.2](#). Windows of this type are accepted for service only where the hydrostatic pressure is applied to the convex face.

(e) For spherical sector acrylic windows with square edge, shown in Figure 2-2.2.1-2, use CFs from Table 2-2.3.1-4 and STCPs from Figures 2-2.5.1-6 and 2-2.5.1-7. Short-term critical pressures may also be experimentally determined according to the procedure in para. 2-2.5.2. Windows of this type are accepted for service only where the hydrostatic pressure is applied to the convex surface.

(f) For hemispherical windows with equatorial flange, shown in Figure 2-2.2.1-3, use CFs from Table 2-2.3.1-4 and STCPs from Figures 2-2.5.1-6 and 2-2.5.1-7. Short-term critical pressures may also be experimentally determined according to the procedure in para. 2-2.5.2. Windows of this type are accepted for service only where the hydrostatic pressure is applied to the convex surface.

(g) For cylindrical acrylic windows, shown in Figure 2-2.2.1-3, use CFs from Table 2-2.3.1-5 and STCPs from Figures 2-2.5.1-8 through 2-2.5.1-13. Short-term critical pressures may also be experimentally determined according to the procedure in para. 2-2.5.2.

(h) For hyperhemispherical acrylic windows, shown in Figure 2-2.2.1-4, use CFs from Table 2-2.3.1-3 and STCPs from Figures 2-2.5.1-14 and 2-2.5.1-15. Short-term critical pressures may also be experimentally determined according to the procedure in para. 2-2.5.2. Windows of this type are accepted for service where the hydrostatic pressure is applied only to the convex surface, or the hydrostatic pressures are applied to either surface but the magnitude of internal design pressure does not exceed 5% of the external design pressure.

(i) For NEMO acrylic windows, shown in Figure 2-2.2.1-4, use CFs from Table 2-2.3.1-3 and STCPs from Figures 2-2.5.1-14 and 2-2.5.1-15. Short-term critical pressures may also be experimentally determined according to the procedure in para. 2-2.5.2. Windows of this type are accepted for service where the hydrostatic pressure is applied only to the convex surface, or the hydrostatic pressures are applied to either surface but the magnitude of the internal design pressure does not exceed 5% of the external design pressure.

2-2.5.2 Testing Method. The experimental determination of the STCP of an acrylic window shall be conducted by subjecting the window to hydrostatic pressure that is increased, from ambient, at a constant rate of approximately 650 psi/min (4.5 MPa/min). The pressurization shall take place at the ambient temperature range of 70°F to 77°F (21°C to 25°C) in a flange that satisfies the requirements of para. 2-2.8.

The evaluation of a window design shall be conducted on a minimum of five full-scale windows or on a minimum of five model-scale windows plus one full-scale window.

(a) For tests conducted on full-scale windows, the results generated shall be considered representative only if the lowest STCP for any window is at least 75%

of the mean STCP of the other four windows. In such a case, the STCP value of the window design shall be taken as the lowest critical pressure among the five tests. In the case where the lowest STCP does not meet this criterion, the STCP value of the window design shall be equal to the single lowest STCP among the five windows multiplied by a factor of 0.75.

(b) For tests conducted on model-scale windows, the results shall be considered acceptable only if the STCP of the full-scale window is equal to or above the single lowest STCP among the five model-scale windows. In case the STCP of the single full-scale window does not meet this criterion, four more full-scale windows shall be tested, and the STCP value of the window design shall be calculated according to (a), solely on the basis of the full-scale window tests.

2-2.6 Design Life

2-2.6.1 General. The design life of a window is a function of its geometry, conversion factor, t/D_i ratio, and service environment. Windows that are exposed to only compressive or very low tensile stresses have a longer design life than those that are exposed to high tensile stresses. The design life of windows in the first category shall be 20 yr, while for the windows in the latter category it shall be 10 yr. The design life of windows under this Standard is defined in paras. 2-2.6.2 through 2-2.6.8.

2-2.6.2 Flat Disk Windows. The design life of flat disk windows shown in Figure 2-2.2.1-1 and meeting the requirements of this Standard shall be 10 yr from the date of fabrication.

2-2.6.3 Conical Frustum Windows. The design life of conical frustum windows shown in Figure 2-2.2.1-1 and meeting the requirements of this Standard shall be 10 yr from the date of fabrication for $t/D_i < 0.5$ and 20 yr for $t/D_i \geq 0.5$.

2-2.6.4 Double-Beveled Disk Windows. The design life of double-beveled disk windows shown in Figure 2-2.2.1-1 and meeting the requirements of this Standard shall be 10 yr from the date of fabrication for $t/D_i < 0.5$ and 20 yr for $t/D_i \geq 0.5$.

2-2.6.5 Spherical Sector With Conical Edge, Hyperhemisphere With Conical Edge, and NEMO-Type Windows With Conical Edge Penetrations. The design life of spherical sector with conical edge, hyperhemisphere with conical edge, and NEMO-type windows with conical edge penetrations shown in Figures 2-2.2.1-2 and 2-2.2.1-4 and meeting the requirements of this Standard shall be 20 yr from the date of fabrication.

2-2.6.6 Spherical Sector Windows With Square Edge and Hemispherical Windows with Equatorial Flange. The design life of spherical sector windows with square edge

and hemispherical windows with equatorial flange shown in Figures 2-2.2.1-2 and 2-2.2.1-3 and meeting the requirements of this Standard shall be 10 yr from the date of fabrication.

2-2.6.7 Cylindrical Windows for Internal Pressure Applications. The design life of cylindrical windows for internal pressure applications shown in Figure 2-2.2.1-3 and meeting the requirements of this Standard shall be 10 yr from the date of fabrication.

2-2.6.8 Cylindrical Windows for External Pressure Applications. The design life of cylindrical windows for external pressure applications shown in Figure 2-2.2.1-3 and meeting the requirements of this Standard shall be 20 yr from the date of fabrication.

2-2.6.9 Increase in Cyclic Design Life. For standard-geometry PVHO viewports having a design pressure of less than 2,000 psi (13.8 MPa), other than hyperhemispherical and NEMO types, the number of design pressure cycles can be increased in excess of that stated in ASME PVHO-1 through experimental pressure testing procedures, provided the following procedures and requirements are met:

(a) For each window design, at least one window of identical shape, dimensions, and design pressure-temperature rating shall be pressure cycled from zero to design pressure to determine whether its cyclic pressure fatigue life exceeds the 10,000 cycle limit stated in ASME PVHO-1. The pressure tests shall take place with the window installed in a test fixture whose window seat dimensions, retaining ring, and seals are identical to those of the PVHO chamber.

(b) The window shall be pressurized with gas or water. The design pressure shall be maintained for a minimum of 15 min, or 1.5 times the time it takes for creep to stabilize, whichever is greater, followed by depressurization that is to be maintained for a minimum of 10 min or 1.5 times the time it takes for creep to stabilize, whichever is greater. The pressurization and depressurization rates shall not exceed 650 psi/min (4.5 MPa/min).

(c) The temperature of the pressurizing medium during the test shall be the design temperature for which the window is rated with a tolerance of $+0/-5^{\circ}\text{F}$ ($+0/-2.6^{\circ}\text{C}$). Brief deviations from these temperature tolerances are allowed, provided that the deviations do not exceed $+10^{\circ}\text{F}$ (5.5°C) and last less than 10 min within each 24 hr of continuous testing.

(d) If leaks develop during pressure cycling, the window shall be removed and pertinent information (cycle count, cause, extent of damage, etc.) recorded. If no damage was noted to the window, new seals may be installed. The number of cycles credited to the window shall be those recorded at the last visual inspection prior to seal failure. After the new seal is installed, two pressure cycles (without leaks) shall be performed without credit to ensure proper seating, temperature

stabilization, and creep normalization. If the new seal performs satisfactorily, the numbering of test cycles shall continue from the number recorded at the last visual inspection prior to seal failure, minus the above two cycles.

(e) At scheduled intervals during the pressure test, the windows shall be visually inspected for the presence of crazing, cracks, or permanent deformation. This examination may be performed without removal of the window from the chamber or test fixture.

(f) Crazing, cracks, or excessive permanent deformation visible with the unaided eye (except for correction necessary to achieve 20/20 vision) shall be considered failure of the windows and shall be so noted on the test report. Permanent deformation more than $0.001D_o$, in magnitude measured at the center of the window shall be considered excessive and shall be cause for rejection. The number of credited test cycles shall not exceed the number of cycles achieved during the previous successful inspection.

(g) Pressure test reports shall certify the results of the pressure test. Copies of the pressure test reports shall be furnished to the purchaser.

(h) For windows having a design pressure design life of 10,000 cycles, an extension of one cycle may be granted by the Standard for each two test cycles after completion of the first 10,000 cycles, up to failure of the test window.

(i) The maximum number of design pressure cycles shall be shown on the Window Certifications.

2-2.7 Temperature and Dimensional Criteria

2-2.7.1 Thermal Expansion. Thermal expansion of acrylic shall be taken into account during specification of the dimensional tolerance for the window diameter to be shown on the fabrication drawing, when the material temperature range required by the fabrication (para. 2-2.4) substantially differs from the operational temperature range.

2-2.7.2 Shape and Sealing Arrangement. For wide operational temperature ranges, a window shape and sealing arrangement should be selected that will perform satisfactorily at both the maximum and minimum operational temperatures. Radially compressed O-ring seals and spherical sector windows with a square edge are not suitable for such service when the change in window diameter over the operational temperature range results in a diametral clearance >0.020 in. (>0.5 mm) between the window and its seat.

2-2.7.3 Thermal Expansion Clearance Criteria. The diametral clearance between the window and its seat cavity at maximum operational temperature shall not be less than $0.001D_o$ for flat disk and spherical sector windows with square edges. The external diameter of the conical frustums and spherical shell windows with conical edge may exceed the major diameter of the

conical seat in the flange by $0.002D_o$ at maximum operational temperature, provided the edge of the window is beveled in such a manner that the conical bearing surface of the window never extends beyond the bearing surface of the seat.

2-2.7.4 Window and Seat Diameter. The nominal diameters of the window and of the window seat in the flange shall be identical. The actual diameters at standard temperature will differ, but still will be within the dimensional tolerances specified in [para. 2-2.11](#).

2-2.8 Viewport Flanges

2-2.8.1 Contribution of Window to Reinforcement. Due to the difference in moduli of elasticity of the plastic window and the metallic flange, it shall be assumed in stress calculations that the window does not provide any reinforcement for the hull material around the penetrations.

2-2.8.2 Calculation Method. Any of the analytical or empirical methods for stress and displacement calculations acceptable to the applicable Division of ASME BPVC, Section VIII may be used for dimensioning the thickness, width, and location of the flange around the viewport penetration.

2-2.8.3 Reinforcement. Reinforcement for penetrations of chambers shall meet the requirements of [para. 1-7.11](#) and the requirements of the applicable Division of ASME BPVC, Section VIII.

2-2.8.4 Requirements for Large Openings. The following minimum requirements shall be met by viewport flanges shown in [Figures 2-2.9.1-1](#) through [2-2.9.1-4](#), with a finished diameter opening in excess of 24 in. (635 mm).

(a) Radial deformation of the window seat at maximum internal or external design pressure shall be less than $0.002D_i$.

(b) Angular deformation of the window seat at maximum internal or external design pressure shall be less than 0.5 deg.

Viewport flanges shown in [Figures 2-2.9.1-5](#) through [2-2.9.1-8](#) do not have to meet the radial and angular deformation limits stated in (a) and (b).

2-2.9 Window Seats

2-2.9.1 Dimensional Requirements. The window seat cavity in the viewport flange must be dimensioned to provide the window bearing surface with support during hydrostatic testing and subsequent operation at maximum design pressure. The dimensions of window seat cavities for standard window geometries are shown in [Figures 2-2.9.1-1](#) through [2-2.9.1-8](#).

2-2.9.2 Surface Finish. The surface finish on the window seat cavity shall be 64 μ in. RMS or finer, except surfaces in contact with a bearing gasket shall not exceed 125 μ in. RMS.

2-2.9.3 Corrosion Mitigation. If the window seat is not fabricated of inherently corrosion-resistant material, the surface of the window seat cavity shall be protected against corrosion expected in the design environment. A weld overlay of corrosion-resistant material prior to final machining is acceptable. Other acceptable means are painting, anodizing, or plating with electroless nickel.

2-2.10 Window Seals

2-2.10.1 General Requirements. As primary seals for standard window geometries shown in [Figures 2-2.2.1-1](#) through [2-2.2.1-4](#), a soft elastomer compressed between the high-pressure face of the window and retainer ring shall be acceptable. The soft elastomeric seal may take the form of a flat gasket or a seal ring with O, U, or X cross section. The gasket or seal ring shall be of sufficient thickness to permit adequate compression without permanent set. Double-beveled disk and cylindrical windows shall use, as a primary seal, a seal ring radially compressed between the cylindrical surface of the window facing the pressure and the cylindrical window seat in the flange. Hyperhemispherical and NEMO-type windows may also use, as a primary seal, an elastomeric potting compound that adheres to both the external spherical surface of the window and the lip of the mounting flange.

2-2.10.2 Flat Disk Windows. Flat disk windows with design pressure less than 15 psi (100 kPa) may use, as the primary seal, an elastomeric potting compound that, after injection into the annular space between the edge of the window and the cylindrical surface of the seat (which have been coated beforehand with appropriate primer), shall, after room-temperature cure, adhere to both the window and the seat surfaces. The primer and elastomeric potting compound selected for this application shall be compatible with the window material, and the potting compound shall retain its elastomeric characteristics in the operational temperature range and environment.

2-2.10.3 Retainer Rings. Whenever a gasket is used as the face seal, the retainer shall precompress the gasket to ensure a minimum of 0.01 in. (0.25 mm) compression of the gasket between the retaining ring and the face of the axially displaced window at design pressure.

For conical frustum and spherical sector windows with conical edge, the magnitude of the maximum axial displacement may be calculated on the basis of [Figure 2-2.9.1-1](#), using the specified D_i/D_f ratios as the maximum predicted limits of axial displacement during pressurization to design pressure based on the

assumption that the minor diameter, D_i , of the window will vertically displace to the D_f of the window.

For flat disks, spherical sectors with square edges, and hemispheres with equatorial flanges, the magnitude of maximum axial window displacement may be calculated by multiplying the thickness of the bearing gasket by 0.30.

2-2.10.4 Gasket Compression. The compression of the soft elastomeric gasket by the retainer ring around the circumference of the window shall be uniform. The magnitude and uniformity of compression shall be checked by measuring, around the circumference of the window, the distance between the surface of the window and the external surface of the retainer ring before and after torquing down on the ring. The values of gasket compression measured at fastener locations and measured midway between fasteners shall not differ from each other by more than 25%, and the minimum value shall be equal to or exceed the magnitude of compression specified by [para. 2-2.10.3](#) at standard temperature.

2-2.10.5 ElectroGalvanic Requirements. The retainer ring and the fasteners shall be fabricated from materials that are electrogalvanically compatible with the viewport flanges. Unreinforced plastics and fiber-reinforced plastic composites are not acceptable materials for this application.

2-2.10.6 Retainer Ring Design Factor. The retainer ring and the associated fastening arrangement shall be designed with a safety factor of 4, based on the ultimate strength of materials. The design pressure forcing the window against the retainer ring shall not be less than 5 psig.

2-2.10.7 Minimum Compression. The minimum compression of seal rings shall be governed by the specifications of the seal ring manufacturer for the given seal ring size and service.

2-2.10.8 Secondary Seal. A secondary seal is required between the window and the steel cavity seat for flat disks, spherical sectors with square edge, and hemispheres with equatorial flange. The secondary seal also serves as a bearing gasket for the window. This gasket must be bonded with contact cement to the metal flange seat. Thickness of the gasket shall not exceed $\frac{1}{8}$ in. (3.0 mm). Neoprene-impregnated nylon cloth, neoprene of 90 durometer hardness, and cork gaskets are acceptable for such application.

2-2.10.9 Seal Ring Grooves

(a) Seal ring grooves are not permitted in either the surface of any window shape or the bearing surface of the seat in the mounting, unless data showing that identical window assemblies that have successfully met the criteria of [para. 2-11.6](#) are included with the window design certification package.

(b) Seal ring grooves are permitted in the window seat in the mounting, provided that the groove is located in the nonbearing surface of the seat. The edges of the O-ring groove shall be beveled with a radius of 0.01 in. $< R < 0.02$ in. (0.25 mm $< R < 0.50$ mm).

2-2.10.10 Edge Seals. Edges of bearing surfaces at the high-pressure faces of windows may be beveled for containment of O-rings provided that the width of the bevel as shown in [Figures 2-2.10.10-1](#) and [2-2.10.10-2](#) shall not exceed $0.125t$ for spherical sectors, $0.062t$ for hyperhemispheres, $0.5t$ for conical frustums, $0.25t$ for flanged hemispheres and for flat disks under one-way pressurization, and $0.125t$ for spherical sectors with square edges and for cylinders. For flat disks serving as two-way windows, both edges may be beveled, provided $D_o/D_i > 1.25$ and D_o is measured only to the edge of the plane-bearing surface. (23)

2-2.10.11 Clear Viewport Retaining Covers. Clear viewport retaining covers are permitted for O-ring-sealed flat disk and conical frustum standard-geometry PVHO windows in applications where reverse pressure on the viewport window is not possible and the design pressure is less than 135 psig, provided the following provisions are met:

(a) The thickness of the clear viewport retaining cover shall not be less than 0.25 in. (6 mm) or $0.025D_o$, whichever is greater.

(b) Where retaining screws are used to secure the clear viewport retaining cover, the clearance holes between the retaining screws and the cover shall be large enough to compensate for thermal expansion and contraction of the cover material. Flat washers shall be used between the screwhead and clear viewport retaining cover.

(c) Provisions shall be made for equalizing the pressure between the clear viewport retaining cover and the viewport window, e.g., a $\frac{1}{16}$ -in. (1.6-mm) diameter hole located in the cover inside the O-ring seal diameter.

(d) Acrylic plastic (per ASTM D4802-02 or equivalent) and clear polycarbonate plastic (per ASTM C1349-04 or equivalent) are acceptable materials for clear viewport retaining covers.

(e) The requirements of [paras. 2-2.10.3](#), [2-2.10.4](#), [2-2.10.6](#), and [2-2.10.7](#) apply to clear viewport retaining covers. See [Figure 2-2.10.11-1](#) for acceptable configurations for clear viewport retaining covers.

2-2.10.12 Configurations. The configuration of window mountings and seal arrangements shown in [Figures 2-2.5.1-1](#) through [2-2.5.1-15](#) represent designs acceptable under this Standard and are shown there only for the guidance of designers.

2-2.10.13 Replacement Windows. Replacement windows for pressure chambers fabricated to design criteria of ANSI/ASME PVHO-1-1977 or ANSI/ASME

PVHO-1-1981 may incorporate O-ring grooves in nonbearing surfaces of the window provided

(a) the window meets all the requirements of the 1977 or 1981 edition

(b) the accompanying design certification notes that the window is a replacement for an existing pressure vessel built to the 1977 or 1981 edition

2-2.11 Dimensional Tolerances and Surface Finish

2-2.11.1 Thickness. Thickness of the window shall be everywhere equal to or greater than the nominal value determined by the procedures of [para. 2-2.5.1](#).

2-2.11.2 Conical Windows

(a) The major diameter of the conical bearing surface on a window shall be machined within $+0.000/-0.002D_o$ of the nominal value.

(b) The included conical angle of the window shall be within $+0.25/-0.000$ deg of the nominal value.

(c) The included conical angle of the window seat in the flange must be within $+0.000/-0.25$ deg of the nominal value.

(d) The conical seat in the flange shall not deviate more than $0.001D_o$ in. from an ideal circle when measured with a feeler gauge inserted between the mating conical surfaces of the seat and of the window at its outer circumference. The axial force used to seat the window during this test shall not exceed $10D_o$ lb ($4.53D_o$ kg) applied uniformly around its circumference.

(e) The major diameter of the conical seat cavity in the flange must be within $+0.002D_o/-0.000$ of the nominal value.

2-2.11.3 Spherical Sector Windows. The concave or convex surface of a spherical window shall not differ from an ideal spherical sector by more than $+0.5\%$ of the specified nominal external spherical radius for standard CF values (see [Tables 2-2.3.1-3](#) and [2-2.3.1-4](#) and [Figures 2-2.5.1-6](#), [2-2.5.1-7](#), [2-2.5.1-14](#), and [2-2.5.1-15](#)). Measurements shall be made from an external segmental template whose radius falls within the specified dimensional tolerance and whose length is equal to the window's included conical angle or 90 deg, whichever is the lesser value. The thickness of the spherical window may decrease from its base to its apex provided that the minimum thickness meets the requirements of [para. 2-2.5](#) for the design pressure and design temperature of the particular spherical window geometry.

2-2.11.4 Flat Disk Windows

(23) **2-2.11.4.1 Window External Diameter.** The dimensional tolerance of the external diameter of the window shall be based on the type of sealing arrangement for the window.

(a) The external diameter of the flat disk window shall be within $+0.000/-0.010$ in. ($+0.000/-0.25$ mm) of the nominal value if the window is to be sealed in the seat cavity with a radially compressed O-ring.

(b) The external diameter of the flat disk window shall be within $+0.000/-0.060$ in. ($+0.000/-1.5$ mm) of the nominal value if the window is to be sealed in the seat cavity with a seal ring wedged into the annular space between the retaining ring, the window's bevel, and the cylindrical surface of the seat cavity.

(c) The external diameter of the flat disk window shall be within $+0.0/-0.125$ ($+0.0/-3.2$ mm) of the nominal value if the window is to be sealed in the seat cavity with a flat elastomeric gasket axially compressed by the retaining ring.

(d) The external diameter of the flat disk window shall be within $+0.00/-0.02D_o$ of the nominal value if the window is to be sealed in the seat cavity with a room-temperature curing elastomeric compound injected into the annular space between the edge of the window and the cylindrical surface of the seat.

(e) The plane bearing surface of the flat disk window shall not deviate more than $0.001D_o$ from an ideal plane.

2-2.11.4.2 Seat Cavity Diameter. The dimensional tolerance on the external diameter of the window seat cavity shall be based on the type of sealing arrangement for the window.

(a) The diameter of the seat cavity for a flat disk window shall be within $+0.01/-0.00$ in. ($+0.25/-0.00$ mm) of the nominal value if the window is to be sealed in the seat cavity with a radially compressed O-ring.

(b) The diameter of the seat cavity for a flat disk window shall be within $+0.06/-0.00$ in. ($+1.5/-0.00$ mm) of the nominal value if the window is to be sealed in the seat cavity with a seal ring wedged into the annular space between the retaining ring, the window's bevel, and the cylindrical surface of the seat cavity.

(c) The diameter of the seat cavity for a flat disk window shall be within $+0.125/-0.000$ in. ($+3.2/-0.00$ mm) of the nominal value if the window is to be sealed in the seat cavity with a flat elastomeric gasket axially compressed by the retaining ring.

(d) The diameter of the seat cavity for a flat disk window shall be within $+0.01D_o/-0.000$ of the nominal value if the window is to be sealed in the seat cavity with a room-temperature curing elastomeric compound injected into the annular space between the edge of the window and the cylindrical surface of the seat.

(e) The plane bearing surface of the seat cavity shall not deviate more than $0.002D_o$ from an ideal plane when measured with a feeler gauge inserted between the mating plane surfaces of the flat disk window or a circular plug gauge and the bare seat cavity. The axial force used to seat the window or the plug gauge shall not exceed $10D_o$ lb ($4.53D_o$ kg) applied uniformly around its circumference.

2-2.11.5 Spherical Windows

(a) The external diameter of the spherical window with square seat shall be within $+0.000/-0.0005D_o$ of the nominal value.

(b) The diameter of the seat cavity for a spherical window with square seat shall be within $+0.0005D_o/-0.000$ of the nominal value.

(c) The plane bearing surface of the seat cavity shall not deviate more than $0.001D_o$ from an ideal plane when measured with a feeler gauge inserted between the mating plane bearing surfaces of the spherical window with a square edge and the seat cavity. The axial force used to seat the window shall not exceed $10D_o$ lb ($4.53D_o$ kg) applied uniformly around its circumference.

2-2.11.6 Cylindrical Windows. The maximum out-of-roundness of a cylindrical window shall not differ from an ideal cylinder by more than $+0.5\%$ of the specified nominal external radius for standard CF values (see Table 2-2.3.1-5).

2-2.11.7 Surface Finish. The bearing surface of the window shall have an as-cast or machined finish no rougher than 32 μ in. RMS.

2-2.11.8 Viewing Surface. Window viewing surfaces shall be polished to meet the requirements of para. 2-3.7(e).

2-2.11.9 Other Surfaces. All other surfaces shall be machined or sanded to attain at least a 63- μ in. RMS finish. Saw cut finish is not acceptable on any window surface.

2-2.12 Documentation

2-2.12.1 Drawing Requirements. The manufacturer shall be responsible for the translation of the design of the window and its related viewport flange, retainer rings, and seals into drawings that can be used for fabrication.

2-2.12.2 Window Identification. Drawings that provide construction details shall bear notice that the windows have been designed and shall be built to ASME PVHO-1. Drawings shall identify the appropriate edition.

2-2.12.3 Design Certification. The designer shall fill out a design certification as described in para. 2-1.3.2(a). All pertinent design data shall be shown, and any additional information used in the design shall be referenced on the certification. The designer may develop an appropriate certification form using PVHO-1 Form VP-2 as a representative sample.

2-2.12.4 Drawing Transmittal. The manufacturer shall transmit the design certification plus construction drawings to the window fabricator at the time of fabrication.

2-2.13 Windows With Inserts for Penetrators

2-2.13.1 General. Inserts that serve as bulkheads for electrical, mechanical, optical, or hydraulic penetrators can be incorporated into acrylic windows, provided that the penetrations and inserts meet the requirements of this subsection. These requirements are grouped into categories of window shapes, pressure service, penetration location, penetration configuration, insert material, insert configuration, seating arrangements, insert retainment, pressure testing, and certification.

2-2.13.2 Shape Limitations. The window shapes in which penetrations can be incorporated without reducing their working pressure are spherical shell sectors with conical seats (see Figure 2-2.2.1-2), hemispheres with or without flanges (see Figure 2-2.2.1-3), hyperhemispheres, and NEMO spheres (see Figure 2-2.2.1-4).

2-2.13.3 Penetration Limitations. Windows with penetrations can be incorporated into pressure vessels for external or internal pressure service, provided that the design pressure acts only on the convex surface of the window.

2-2.13.4 Penetration Locations (Spherical Shell Sector). On spherical shell sectors with conical seats, hemispheres without flanges, hyperhemispheres, and NEMO spheres, the penetrations may be located anywhere, provided

(a) the spacing between the window seat and the edge of the penetration exceeds two diameters of the penetration

(b) the spacing between edges of adjacent penetrations measured on the concave surface exceeds the radius of the larger penetration

2-2.13.5 Penetration Location (Hemispheres). On hemispheres with flanges, the penetration may be located only within the area between the apex and latitude of 60 deg, provided the spacing between edges of adjacent penetrations exceeds the radius of the larger penetration measured on the concave surface.

2-2.13.6 Penetration Configuration. The penetrations shall have circular configurations.

2-2.13.7 Area of Single Penetration. The area of a single penetration shall not exceed 15% of the window's surface prior to machining of the penetration in the window.

2-2.13.8 Total Area. The total area of all penetrations in a single window shall not exceed 30% of the window's concave surface.

2-2.13.9 Seats. All penetrations shall have conical seats forming surfaces of imaginary solid cones.

2-2.13.10 Included Angle. The included solid angle of any conical seat shall be chosen to make the imaginary apex of the solid cone coincide with the imaginary center of concave curvature.

2-2.13.11 Maximum Diameter. The maximum size of the penetration diameter shall be defined by a solid cone angle of 60 deg, provided the area of the penetration, defined as $\pi(M_o)^2/4$ (see Figure 2-2.13.11-1), does not exceed the limits specified in paras. 2-2.13.7 and 2-2.13.8.

2-2.13.12 Tolerances. The angular and dimensional tolerances for penetrations, as well as for the surface finish on the seat, are shown in Figure 2-2.2.1-1.

2-2.13.13 Insert Material. The inserts for the penetrations shall be made from metal or from plastic, provided the material properties satisfy the following criteria:

(a) Any metal approved by this Standard may be used for the fabrication of inserts, provided that the selected alloy is corrosion resistant to stagnant seawater and its tensile and compressive yield strengths exceed 25,000 psi (172 MPa). Steel alloys without corrosion resistance may be substituted for corrosion-resistant alloys if the insert is cadmium or nickel plated after completion of all machining operations.

(b) Acrylic meeting the criteria of Table 2-3.4-2 and polycarbonate plastic meeting the criteria of Table 2-2.13.13-1 are acceptable materials for the fabrication of inserts, provided that in service they shall only

(1) come in contact with fluids and gases defined by para. 2-1.2(c)

(2) be subjected to temperatures that are lower than the design temperature of the window

Cast unfilled monolithic Type 6 nylon meeting the criteria of Table 2-2.13.13-2 may be used for the fabrication of bearing gasket inserts for NEMO windows (see Figure 2-2.9.1-8).

2-2.13.14 Temperature Considerations. Since the temperature of a shorted-out electrical connector may exceed the design temperature of the plastic insert, the designer shall forestall the potentially unacceptable temperature rise by limiting the magnitude and/or duration of power input to the connector during an electrical short.

2-2.13.15 Insert Tolerances. The angular and dimensional tolerances for inserts are shown in Figure 2-2.13.15-1. All surfaces on the insert shall have a finish of 32 μ in. RMS or finer.

2-2.13.16 Insert Shape. The inserts shall have the shape of a spherical sector or of a truncated cone, where

(a) the solid included angle of the bearing surface on the insert matches the conical seat in the penetration

(b) the bearing surface of the insert extends past the edges of the seat in the penetration (Figure 2-2.13.16-1)

2-2.13.17 Metal Inserts. Any number or size of holes may be drilled and tapped in the metal insert to receive hydraulic, electrical, optical, or mechanical bulkhead penetrators, provided that the openings and their reinforcements conform to the appropriate Division of ASME BPVC, Section VIII.

2-2.13.18 Polycarbonate Inserts. Smooth holes may be drilled in the polycarbonate insert to receive hydraulic, electrical, optical, or mechanical bulkhead penetrators, provided

(a) the spacing between edges of adjacent holes in the insert exceeds the diameter of the larger adjacent hole.

(b) the spacing between the edge of the insert and the edge of any hole exceeds the diameter of that hole.

(c) the surface finish inside the holes is 32 μ in. RMS or finer. The holes shall be sized for the penetrators to support the edges of the holes when the window assembly is subjected to design pressure.

2-2.13.19 Acrylic Inserts. Smooth holes may be drilled in the acrylic insert to receive hydraulic, electrical, optical, or mechanical bulkhead penetrators, provided

(a) the spacing between edges of adjacent holes in the insert exceeds two diameters of the larger adjacent hole.

(b) the spacing between the edge of the insert and the edge of the hole exceeds two diameters of the hole.

(c) the surface finish inside the holes is 32 μ in. RMS or finer. The holes shall be sized for the penetrators to support the edges of the holes when the window assembly is subjected to design pressure.

2-2.13.20 Insert Thickness. The thickness of the insert shall depend on the material from which the insert is fabricated.

(a) For plastics, the thickness of the inserts in the shape of spherical sectors or conical frustums shall be calculated on the basis of maximum allowable tensile and compressive stresses specified for the chosen material by the appropriate Division of ASME BPVC, Section VIII.

(b) An alternate approach requires hydrostatic testing of the new insert design in an acrylic seat to 3 times the desired design pressure without producing permanent deformation $\geq 0.2\%$. The pressurization shall be at a 650-psi/min (4.5-MPa/min) rate.

2-2.13.21 Duplicate Inserts. Duplicate inserts of the same material, design, and construction need not be proof tested but shall be pressure tested according to subsection 2-7.

2-2.13.22 Insert Seals. All inserts require two separate seals to prevent entry of water through the joint between the bearing surface of the insert and the seat in the window — a primary seal and a secondary seal.

(a) Sealing between the insert and the window shall be provided by two seals. A primary seal shall serve as the contact between the two conical mating surfaces on the insert and window. A secondary seal shall serve as the

contact between the two conical mating surfaces on the insert and window, and as elastomeric material held captive between the convex window surface and a flange on the insert.

(b) Experimentally proven secondary seal designs shown in [Figure 2-2.13.22-1](#) represent designs acceptable under this Standard and are provided for guidance only.

2-2.13.23 Insert Seal Grooves. Grooves for containment of seals shall not be machined in either the conical seat on the window or the conical bearing surface on the insert in contact with the window. It is acceptable to incorporate an O-ring groove in the conical bearing surface of a metallic insert if a gasket of approved material is interposed between the metallic insert and the seat on the window (see [Figure 2-2.9.1-8](#)).

2-2.13.24 Insert Retention. The inserts shall be mechanically restrained against ejection from their seats in the window by accidental application of pressure to the concave surface of the window or bending moments to the feedthroughs.

(a) The mechanical restraint shall be capable of retaining the insert against a pressure of 15 psi (0.1 MPa) applied against the concave surface of the window and bending moments generated by wave slap and hydrodynamic drag against cables, hydraulic lines, or mechanical linkages attached to the insert. The tensile stress resulting from bending moment shall not exceed 2,500 psi (12.2 MPa).

(b) Experimentally proven restraint designs shown in [Figure 2-2.13.24-1](#) represent designs acceptable under this Standard and are provided for guidance only.

2-2.13.25 Insert Stress Relief. All inserts shall be stress relieved after all the fabrication processes have been completed. Acrylic shall be stress relieved according to the schedules of [Table 2-4.5-1](#). Polycarbonate shall be stress relieved for a period of 8 hr at 250°F (120°C).

2-2.13.26 Insert Inspection. Each finished insert shall be subjected by the fabricator to a quality control inspection. The quality control inspection shall consist of dimensional and visual checks whose objective is to determine whether the finished insert meets the dimensional tolerances, material quality, and surface finish requirements specified in [para. 2-2.12](#).

2-2.13.27 Insert Pressure Test. Each insert shall be pressure tested at least once prior to being accepted for service.

(a) The pressure test shall take place with the insert installed in the window, or an acrylic test fixture whose thickness, surface curvatures, and penetration dimensions are identical to those in the window.

(b) The pressure test shall be conducted according to procedures described in [subsection 2-7](#).

(c) The test pressure and temperature shall be determined by the design pressure and temperature of the window in which the insert shall be installed for service.

2-2.13.28 Insert Inspection. Each insert shall be individually certified. The certification shall include the following:

- (a) design certification
- (b) material manufacturer's certification
- (c) material properties certification
- (d) fabrication data report
- (e) pressure testing certification

2-2.13.29 Insert Certification Procedure. Each of the certifications shall follow the procedure described in [para. 2-1.3.2](#), except that the material certifications for polycarbonate and metallic inserts shall differ from the one specified for acrylic.

(a) For polycarbonate, the supplier shall provide a report listing the results of tests performed according to [Table 2-2.13.13-1](#) on coupons cut from the stock used in the fabrication of inserts.

(b) For metal, the supplier shall provide a certified mill test report. The report shall include the results of all the tests as required by the material specifications, including chemical analysis and mechanical tests. In addition, the results of any applicable supplementary tests shall be recorded.

2-3 MATERIAL

2-3.1 Material Restrictions

Windows shall be fabricated only from cast polymethyl methacrylate plastic, hereafter referred to as acrylic.

2-3.2 Laminated Sheets

Laminating several sheets of acrylic to arrive at the desired window thickness is not permitted.

2-3.3 Acrylic Bonding

Joining of acrylic castings by bonding is permitted, provided that the following requirements are met:

- (a) The joint shall be subjected only to membrane compressive stresses.
- (b) The properties of the bond joint shall meet or exceed those specified in [para. 2-3.10](#).
- (c) The joint shall be pressure tight during hydrostatic testing of the window.

2-3.4 Acrylic Requirements

The acrylic used for fabrication of windows shall satisfy the following two general requirements:

- (a) The casting process used in production of acrylic shall be capable of producing material with the minimum physical properties shown in [Table 2-3.4-1](#). The manufacturer of material shall provide certification

to the window fabricator that the typical physical properties of the material satisfy the criteria of [Table 2-3.4-1](#). The material manufacturer's certification shall convey the information in a form equivalent to [PVHO-1 Form VP-3](#). The certification shall identify the material by lot number and shall be marked in such a way that each casting shall be positively identified with the lot number. If the manufacturer is not willing to certify that the typical physical properties of the castings meet the requirements in [Table 2-3.4-1](#), experimental verification of all properties shown in [Table 2-3.4-1](#) becomes mandatory.

(b) The acrylic castings from which the windows are produced shall meet the minimum physical properties specified in [Table 2-3.4-2](#) after the castings have been annealed per [para. 2-4.5](#). The acceptance tests of castings shall be conducted for the window fabricator by the manufacturer of acrylic or by an independent materials testing laboratory. The results of the material acceptance tests (specified in [Table 2-3.4-2](#)) for sheet or custom castings shall be certified on a form equivalent to [PVHO-1 Form VP-4](#). This certification shall be provided to the window fabricator and shall become a part of the certification information forwarded to the chamber manufacturer or user.

2-3.5 Acrylic Form

Acrylic castings shall be supplied in sheet form or as custom castings. All acrylic sheet castings shall have a nominal thickness of $\frac{1}{2}$ in. (12.5 mm) or greater.

For purposes of this Standard, acrylic in the form of custom castings is classified as either Type 1 or Type 2 castings.

(a) Type 1 custom castings are defined as being of such thickness and configuration, and produced by such a process, as to meet the requirements of [Table 2-3.4-1](#) without experimental verification. To classify a casting as a Type 1 custom casting, the manufacturer of acrylic shall certify that the manufacturer has produced castings of similar shape and thickness and of the same material in the past and that such castings have met the requirements of [Table 2-3.4-1](#).

(b) Type 2 custom castings are defined as being produced in such a thickness or configuration, or by such a process, that the manufacturer of acrylic must experimentally verify that the acrylic castings possess the minimum physical properties specified in [Table 2-3.4-1](#). All custom castings failing to meet the requirements of Type 1 shall be classified as Type 2 custom castings.

2-3.6 Material Property Tests

Acceptance tests performed according to [para. 2-3.4\(b\)](#) on a single casting can be used not only to certify the particular casting, but also, under special circumstances, to certify an entire lot.

(a) Acceptance tests performed according to [para. 2-3.4\(b\)](#) on one sheet casting chosen at random from a lot of acrylic cast sheets shall serve to certify all sheets of that lot, provided that the manufacturer of acrylic shall positively and permanently identify each sheet so certified with a lot number and the designation ASME PVHO-1.

(b) The manufacturer of acrylic sheet castings may certify that a product of a given thickness meets the typical physical properties specified in [Table 2-3.4-1](#) without identification of lot number. Each casting so certified shall have acceptance tests performed on it according to [para. 2-3.4\(b\)](#) and at that time have assigned to it an inventory control identification that shall be affixed to the casting by the window fabricator and used in lieu of a lot identification in all ASME PVHO-1 documentation.

(c) Acceptance tests performed according to [para. 2-3.4\(b\)](#) on specimens cut from one Type 1 custom casting shall serve to certify all castings of that lot. The manufacturer shall positively and permanently identify each certified casting with lot number and safety standard designation ASME PVHO-1.

(d) Single Type 1 custom castings shall have acceptance tests performed according to [paras. 2-3.4\(a\)](#) and [2-3.4\(b\)](#) on specimens cut from each casting.

(e) Type 2 custom castings shall have tests performed according to [paras. 2-3.4\(a\)](#) and [2-3.4\(b\)](#) on specimens cut from each casting to experimentally verify that the acrylic possesses the physical properties specified in both [Tables 2-3.4-1](#) and [2-3.4-2](#). Tests for experimental verification of properties in [Table 2-3.4-1](#) shall serve also to certify the properties in [Table 2-3.4-2](#).

2-3.7 Properties Test Specifications

(23)

Testing of acrylic castings for the physical and optical properties specified in [Tables 2-3.4-1](#) and [2-3.4-2](#) shall follow ASTM methods where applicable. Where possible, samples for testing shall be taken from an integral part of the casting. A test coupon casting may be used to supply material for testing, provided that the test coupon and window castings meet the lot requirements. Samples for testing shall be cut so that no surface of the test sample is closer to an unfinished cast surface than the normal trim line. Where possible, test samples shall be cut from the central portion of the original casting (e.g., a large casting cut into several windows). The test methods for physical properties specified in [Table 2-3.4-2](#) shall be as follows:

(a) Tests for tensile properties shall be performed per ASTM D638, using a testing speed of 0.20 in./min (5.0 mm/min) $\pm 25\%$.

(b) Tests for compressive deformation shall be per ASTM D695.

(c) *Tests for Compressive Deformation*

(1) *General.* Tests for compressive deformation shall be performed using specimens loaded to 4,000 psi (27.6 MPa) and tested at 122°F (50°C). The sample size is a $\frac{1}{2}$ -in. (12.5-mm) cube. To test nominal $\frac{1}{2}$ -in. (12.5-mm) thick material, machine the specimen in such a manner that the as-cast surfaces serve as the load-bearing surfaces. Do not stack samples to reach $\frac{1}{2}$ in. (12.5 mm) height; instead test a sample, $\frac{1}{2}$ in. $\times$ $\frac{1}{2}$ in. (12.5 mm $\times$ 12.5 mm) nominal thickness. For materials that are cast with irregular surfaces or thicker than $\frac{1}{2}$ in. (12.5 mm), machine the samples from the casting such that the compression face is as close as possible to the bottom side of the casting.

(2) *Procedure.* Place the test specimen between the anvils of the testing machine. Apply the load to the specimen without shock and take the initial reading 10 sec after the full load is on the specimen. At the end of 24 hr, take a second reading and record the total change in height. Determine the original height of the specimen by measuring the specimen after it is removed from the testing machine and adding this to the total change in height as read on the dial of the testing machine.

(3) *Calculation.* Calculate the deformation as the percentage change in height of the test specimen after 24 hr, as follows:

$$\text{Deformation, \%} = (A/B) \times 100$$

where

A = change in height in 24 hr (= height after load application – height after 24 hr)

B = original height (= height after removal + total change)

(4) *Report.* The report shall include the following:

(-a) original height of the test specimen

(-b) thickness of the cube

(-c) conditioning procedure

(-d) temperature of test and the force applied

(-e) change in height of the test specimen in 24 hr

(-f) deformation (flow or combined flow and shrinkage) expressed as the percentage change in height of the test specimen calculated on the basis of its original height

NOTE: Measurements shall be made in consistent units measured to the nearest 0.001 in. (0.0254 mm).

(d) Test for the presence of an ultraviolet absorber (ultraviolet transmittance) shall be made using a scanning ultraviolet monochromator having a bandwidth of 10 nm or less and a minimum sensitivity of 0.02%, a photometer having reproducibility of +1% of full scale, and the practices of ASTM E308 to measure the spectral transmittance in the 290 nm to 330 nm wavelength band. Report the value of one specimen of $\frac{1}{2}$ in. $\pm$ 0.01 in. (12.7 mm $\pm$ 0.25 mm) thickness with light passing through polished faces. Report the maximum percent transmission detected

between 290 nm and 330 nm and the peak location where the maximum percent transmission was located. Measurements can be made on the casting or on the monomer mix from which the plastic is to be cast. Solid samples shall have two polished faces through which the light passes.

(e) The clarity of a finished window shall be visually rated. Clear print of size 7 lines per column inch (25 mm) and 16 characters to the linear inch (25 mm) shall be clearly visible when viewed from a distance of 20 in. (500 mm) through the thickness of the finished window.

(f) Since an ASTM standard method is not available for measurement of residual acrylic monomer, the procedure specified in para. 2-3.8 is recommended.

(g) Test for thermal expansion coefficient as follows:

(1) Tests for thermal expansion coefficient of acrylic shall be performed per ASTM D696 or ASTM E831 to include reportable thermal expansion data over the full temperature range of -40°F to +140°F (-40°C to +60°C).

(2) The thermal expansion coefficient at temperature of interest T shall be determined by testing the material at two points, each +10°F and -10°F (+5°C and -5°C) from the desired point of interest T .

2-3.8 Testing for Residual Monomer

A sample of suitable size shall be obtained and analyzed for unpolymerized methyl methacrylate and unpolymerized ethyl monomers using gas or liquid chromatographic techniques. Options for determination of residual monomers include gas chromatography (GC) and high-pressure liquid chromatography (HPLC). Samples for testing shall be cut so that the center point of the analyzed piece is no closer to the original edge or surface of the casting than the thickness divided by 2. The following (after Cober and Samsel, SPE Transactions, "Gas Chromatograph, a New Tool for Analysis of Plastics," April 1962, pp. 145-151) is a suitable procedure:

(a) The instrument may be a Beckman GC-2A gas chromatograph, equivalent, or better, with a hydrogen flame detector, or equivalent, and a 6-ft (1.8-m) column of $\frac{1}{4}$ in. (6.0 mm) stainless tubing operated at 212°F (100°C). Pack the column with 25% diethylene glycol adipate polyester (LAC-2R-446, Cambridge Industries Co.) and 2% phosphoric acid on an 80-100 mesh Celite filter aid. The acrylic to be analyzed shall weigh approximately 2.0 g and shall be dissolved in exactly 50 mL of methylene chloride. Inject a 3- μ L aliquot of the plastic-solvent solution into the gas chromatographic apparatus. Compare the area of the resulting peaks with the areas produced by the injection of a standard solution. Prepare the standard solution by dissolving 20 mg to 30 mg of pure monomers in 50 mL of methylene chloride.

(b) Acrylic that does not dissolve shall be analyzed by swelling the plastic and extracting the soluble portion. Place a solid piece of insoluble acrylic plastic weighing about 1 g and 20 mL of methylene chloride in a glass

bottle, and place on a shaker for 24 hr. After 24 hr, the fluid portion shall be analyzed for monomeric methyl methacrylate and monomeric ethyl acrylate per [para. 2-3.5\(a\)](#).

2-3.9 Windows Greater Than 6 in. Thick

Windows in excess of 6 in. (150 mm) thickness shall require material testing of two samples from the casting. One sample shall be taken from the surface of the casting. The second sample shall be taken from the interior of the casting at a distance from any surface equal to half the thickness. The properties of each sample shall meet the requirements of [Table 2-3.4-2](#).

2-3.10 Bond Testing

The physical properties of bonds shall meet or exceed the following:

(a) The tensile strength of the bond shall be at least 50% of the parent material strength as established by the ASTM D638 test on five tensile coupons cut from a bond quality control specimen that was bonded at the same time and in the same manner as the acrylic castings intended for actual service.

(b) The significant and critical dimensions of inclusions, as well as the critical spacing between adjacent inclusions, shall not exceed those specified in [para. 2-5.4](#) for a given window shape. The critical size of inclusion population shall not exceed the cross-sectional area of the bonded joint in square centimeters divided by 10. The critical density of population shall not exceed 2 inclusions per square centimeter of contiguous joint cross-sectional area.

2-3.11 Low Ultraviolet (UV) Cast Acrylic Cylinders

Cast acrylic cylinders may be used without the addition of a UV stabilization agent, provided the following conditions are met:

(a) Storage and use are limited to a protected indoor environment where there is low exposure to UV radiation.

(b) The window markings shall also include "Low UV" as required in [para. 2-6.1](#), as shall the associated ASME PVHO-1 forms.

(c) The window is not subject to life extension beyond design life.

(d) The window shall comply with all other relevant requirements of ASME PVHO-1.

2-4 FABRICATION

2-4.1 Responsibilities and Duties for Window Fabricators

The window fabricator's responsibilities include the following:

(a) compliance with this Standard and the appropriate referenced standard or standards

(b) procurement control of material, parts, and services

(c) establishing and maintaining a Quality Assurance Program in accordance with [Section 3](#)

(d) documenting the Quality Assurance Program in accordance with [Section 3](#)

(e) furnishing the purchaser with appropriate Certification Report or Reports

(f) ensuring that the subcontracted activities comply with the appropriate requirements of this Standard

The PVHO window fabricator shall retain overall responsibility, including certifying and marking PVHO windows.

2-4.2 Quality Assurance and Marking

Windows shall be fabricated only from acrylic castings satisfying the requirements of [Sections 2](#) and [3](#). This shall be accomplished by the window fabricator through compliance with the following procedures:

(a) The window fabricator shall establish and maintain a current and documented Quality Assurance Program that complies with [Section 3](#).

(b) All castings used for fabrication of windows shall be marked prominently with letters and/or numbers that are traceable to the material certifications (see [PVHO-1 Form VP-3](#), [PVHO-1 Form VP-4](#), and [PVHO-1 Form VP-1](#)).

(c) Each window shall be numbered per [para. 2-6.1](#), and these numbers shall be traceable to the castings from which they were fabricated. This traceability shall be certified on the fabrication data report, which shall provide, in equivalent form, the information shown on [PVHO-1 Form VP-1](#).

2-4.3 Use of Solvent

No fabrication process, solvent, cleaner, or coolant that degrades the original physical properties of the acrylic casting shall be used during fabrication.

2-4.4 Identification

During the fabrication process, each window shall be identified with identification and fabrication verification documents containing pertinent material and fabrication data.

2-4.5 Annealing

All window material shall be annealed after all forming, machining, and machine polishing have been completed. All annealing shall take place in a forced-air circulation oven. Annealing shall be in accordance with [Table 2-4.5-1](#). Time and temperature data for all annealing cycles shall be entered into [PVHO-1 Form VP-1](#). A copy of the final anneal's time/temperature chart shall be attached to [PVHO-1 Form VP-1](#).

2-4.6 Polishing

Hand lapping and hand polishing to remove scratches caused by handling may be performed after final annealing.

2-4.7 Inspection

Each window shall be inspected in accordance with [subsection 2-5](#), after the final anneal.

2-5 INSPECTION

2-5.1 General

The quality control inspection shall consist of dimensional and visual checks to ensure the finished window meets the dimensional tolerances, material quality, and surface finish requirements specified in [subsections 2-2](#) through [2-4](#). Windows that meet the requirements of [subsections 2-2](#) through [2-4](#) and the requirements of this subsection shall be accepted. In particular, dimensional measurements shall be made to show compliance with [para. 2-2.11](#).

2-5.2 Inspection Temperature and Orientation

All dimensional and angular measurements shall be performed at a material temperature of 70°F to 75°F (21°C to 24°C). For hyperhemisphere, cylindrical, and NEMO-type windows, measurements for deviation from true circular form, e.g., out-of-roundness and sphericity, shall be conducted at least 24 hr after placing the window in the orientation of, and supported in a similar manner to, the intended service. Out-of-roundness measurements of cylindrical windows shall be taken at both ends and at 25%, 50%, and 75% of the window length.

2-5.3 Surface Scratches

Scratches (or machining marks) on the surfaces of and inclusions in the body of the window shall not be acceptable if they exceed the specified critical dimension, critical spacing, critical size of population, or critical density of population, or are found in a critical location.

2-5.4 Inclusion Inspection

The critical dimensions of inclusions, critical spacing, critical size of inclusion population, critical location, and critical density of inclusion population depend on the shape of the window. Only inclusions whose diameter or length exceeds the following specified significant dimension shall be considered during a visual inspection; all others shall be disregarded.

(a) For spherical sectors with conical edge, hyperhemispheres, NEMO windows, conical frustums and double-beveled disks with $t/D_i \geq 0.5$, and cylinders under external pressure loading

- (1) *significant dimension*: 0.015 in. (0.4 mm)
- (2) *critical dimension*: $0.05t$
- (3) *critical size of population*: total volume of window in cubic centimeters divided by 10 000
- (4) *critical density of population*: one inclusion per 1 in.³ (16 cm³) of contiguous volume
- (5) *critical spacing between adjacent inclusions*: select the larger of the two adjacent inclusions and multiply its diameter by a factor of 2
- (6) *critical locations*: no inclusions are permitted on or within critical spacing of all of the bearing and sealing surfaces

(b) For spherical sectors with square edge, hemispheres with equatorial flange, cylinders under internal pressure, conical frustums and double-beveled disks with $t/D_i < 0.5$, and disks

- (1) *significant dimension*: 0.015 in. (0.4 mm)
- (2) *critical dimension*: 0.030 in. (0.8 mm)
- (3) *critical size of population*: total volume of window in cubic centimeters divided by 10 000
- (4) *critical density of population*: one inclusion per 1 in.³ (16 cm³) of contiguous volume
- (5) *critical spacing between adjacent inclusions*: 0.25 in. (6 mm)
- (6) *critical locations*: no inclusions are permitted on or within critical spacing of all of the surfaces

(c) Windows may be fabricated from acrylic castings with inclusions that exceed the 0.03-in. (0.8-mm) critical dimension specified by (b)(2), provided that the structural performance of the window is not compromised by the presence of these inclusions.

This is to be accomplished by restricting the inclusions to only certain types and sizes, and by compensating their effect on the critical pressure of the window with an increase in tensile strength of the acrylic, or an increase in design critical pressure of the finished window, or both.

(1) Inclusions are allowed in flat disks, cylinders under internal pressure, spherical sectors with square edges, hemispheres with equatorial flange, and double-beveled disks and conical frustums with $t/D_i < 0.5$, provided that the following requirements are met:

- (-a) Significant dimension of the inclusion is 0.03 in. (0.8 mm).
- (-b) Critical dimensions of the inclusions are
 - (-1) voids, specks, and grains of dirt; fragments of metal, wood, or rubber: 0.06 in. (1.5 mm)
 - (-2) hair or cloth fibers: 2 in. (50.8 mm) long
 - (-3) plastic foil fragments: 0.15 in. long × 0.06 in. wide × 0.03 in. thick (3.8 mm × 1.5 mm × 0.76 mm)
- (-c) Critical size of population is total volume of the casting in cubic inches divided by 1,000.
- (-d) Critical density of inclusion population is one inclusion per cubic inch.
- (-e) Critical spacing between adjacent inclusions is 0.25 in. (6.35 mm).

(-f) Critical locations are such that inclusions are not permitted closer than 0.125 in. (3.2 mm) from the finished window surface.

(2) The finished window containing one or more inclusions shall satisfy one of the following structural requirements:

(-a) The minimum tensile strength of inclusion-free tensile test specimens from the lot of casting used in manufacture of windows shall be $\geq 11,000$ psi, and the short-term design-critical pressure of the window shall meet the requirement of this Standard.

(-b) The minimum tensile strength shall be $\geq 10,000$ psi, and the window's short-term design-critical pressure shall exceed the requirements of this Standard by $\geq 10\%$.

(-c) The minimum tensile strength shall be $\geq 9,000$ psi, and the window's STCP shall exceed the requirements of this Standard by $\geq 20\%$.

2-5.4.1 Inclusion Inspection for Nonstandard Windows. Nonstandard geometry windows and standard window geometries with lower conversion factors shall not contain any inclusion with a critical dimension exceeding 0.015 in. (0.40 mm).

2-5.5 Scratch Characterizations

Critical dimensions of scratches (or machining marks), critical spacing, critical sizes of scratch population, critical locations, and critical densities of scratch population depend on the shape of the window. Only scratches whose depth exceeds the significant dimension shall be considered during a visual inspection; all others shall be disregarded.

(a) For spherical sectors with conical edge, hyperhemispheres, NEMO windows, conical frustums and double-beveled disk with $t/D_i \geq 0.5$, and cylinders under external pressure loading

(1) *significant dimension*: 0.01 in. (0.25 mm)

(2) *critical dimension*: 0.02 in. (0.5 mm)

(3) *critical size of population*: total length of all scratches in centimeters equals total area of scratched surface in square centimeters divided by 1000

(4) *critical density of population*: none specified

(5) *critical spacing between scratches*: none specified

(6) *critical locations*: no scratches are permitted on the bearing and sealing surfaces

(b) For conical frustums and double-beveled disks with $t/D_i < 0.5$, flat disks, and cylinders under internal pressure

(1) *significant dimension*: 0.003 in. (0.08 mm)

(2) *critical dimension*: 0.01 in. (0.25 mm)

(3) *critical size of population*: total length of all scratches in centimeters equals total area of scratched surface in square centimeters divided by 1000

(4) *critical density of population*: none specified

(5) *critical spacing between scratches*: none specified

(6) *critical locations*: no scratches are allowed on the bearing and sealing surfaces, on any faces of double-beveled disks and cylinders, or on low-pressure faces of conical frustums and disks

(c) For spherical sectors with square edge and hemispheres with equatorial flange of acrylic

(1) *significant dimension*: 0.003 in. (0.08 mm)

(2) *critical dimension*: 0.01 in. (0.25 mm)

(3) *critical size of population*: total length of all scratches in centimeters equals total area of scratched surface in square centimeters divided by 1000

(4) *critical density of population*: none specified

(5) *critical spacing between scratches*: none specified

(6) *critical locations*: no scratches are permitted on bearing and sealing surfaces, on the low-pressure face of spherical sector with square edge, or in the heel and instep areas of flanged hemispheres

2-5.6 Repairs

Repairs to new windows that do not meet acceptance criteria shall be performed in accordance with [subsection 2-9](#).

2-5.7 Inspection Report


After the quality control inspection, each acceptable window shall be certified as to fabrication processes on a fabrication data report. The report shall be made on a form equivalent to [PVHO-1 Form VP-1](#). This report shall be forwarded to the chamber manufacturer or user as a part of the certification package.

2-6 MARKING

2-6.1 Marking Location, Configurations

Identification of each window with the window fabricator's certification shall be located on the window's seating surface or on the outer diameter of the window. Identification shall consist of $\frac{1}{2}$ -in. (12.5-mm) letters and numbers made by the window fabricator with an indelible black felt marker, or $\frac{1}{8}$ -in. (3.2-mm) letters and numbers applied with epoxy ink. Epoxy ink shall not be used if the marked surface seats against a metal surface. The identification shall contain information per the following example:

50-100-PVHO-RT-21-XX



Windows fabricated without an ultraviolet (UV) stabilization agent shall add "Low UV" after the year of fabrication.

2-6.2 Certification Completion

At the time of marking, the window fabricator shall certify the overall fabrication of the window by completing window certification [PVHO-1 Form VP-1](#). Only after completion of [PVHO-1 Form VP-1](#) shall the window be considered to have met the requirements of this Standard, and the window can be marked in accordance with [para. 2-6.1](#). This window certification shall be forwarded to the purchaser or used as part of the window certification package.

2-6.3 Marking Restrictions

The windows shall be marked by the window fabricator with PVHO identification per [para. 2-6.1](#) only if the design, material manufacture, material testing, and fabrication have been completed and are on file with the window fabricator applying the markings after having met the requirements of [para. 2-6.2](#).

2-6.4 Additional Marking

The window may also be marked with additional identifications. The size of letters, method of application, and their location on the window shall satisfy the requirements of [para. 2-6.1](#).

2-6.5 Marking Certification Retention

The window certification and data reports (see [PVHO-1 Forms VP-1](#) through [VP-5](#)) shall be retained for each window as follows:

(a) One copy of [PVHO-1 Forms VP-1](#) through [VP-5](#) shall be retained by the window fabricator, and one copy of the forms shall be furnished to the window purchaser if the window fabricator performs the pressure test.

(b) If the window fabricator does not perform the pressure test, this shall be noted on [PVHO-1 Form VP-1](#). One copy of [PVHO-1 Forms VP-1](#) through [VP-4](#) shall be retained by the window fabricator, and one copy of the forms shall be furnished to the purchaser of windows.

(c) If the purchaser of windows does not require the window fabricator to perform the pressure test, the purchaser shall have the pressure test performed by a qualified pressure test laboratory, or pressure test the windows according to [subsection 2-7](#), either of which requires the completion of [PVHO-1 Form VP-5](#).

(d) It shall be the responsibility of the owner/user and the chamber manufacturer to possess and retain [PVHO-1 Forms VP-1](#) through [VP-5](#) for a period not less than the design life of the window plus 2 yr.

(e) It shall be the responsibility of the window fabricator to possess and retain [PVHO-1 Forms VP-1](#) through [VP-4](#) (and [PVHO-1 Form VP-5](#) if performing the pressure test) for a period not less than the design life of the window plus 2 yr.

2-7 PRESSURE TESTING

2-7.1 Frequency

Each window shall be pressure tested at least once prior to being accepted for service.

2-7.2 Test Configuration

The pressure test shall take place with the window installed in the chamber or placed within a test fixture whose window seat dimensions, retaining ring, and seals are identical to those of the chamber.

2-7.3 Test Duration

The window shall be pressurized with gas or water until design pressure is reached with a tolerance of $+0\%/-4\%$ for test pressures less than 500 psi (3.46 MPa) and $+0\%/-2\%$ for test pressures greater than 500 psi (3.46 MPa). The design pressure shall be maintained for not less than 1 hr, but not more than 4 hr. Pressurization and depressurization rates shall not exceed 650 psi/min (4.5 MPa/min).

2-7.4 Test Temperature

The temperature of the pressurizing medium during the test shall be the design temperature for which the window is rated with a tolerance of $+0/-5^{\circ}\text{F}$ ($+0/-2.5^{\circ}\text{C}$). Brief deviations from these temperature tolerances are allowed, provided that the deviation does not exceed 10°F (5.5°C) and lasts less than 10 min.

2-7.5 Window Leakage

Windows that leak during the pressure tests shall be removed, fitted out with new seals, and retested. If, during the retest, the leakage continues, efforts will be made to complete the test by stopping the leak with a temporary seal. The inability of seals to operate properly during the test shall be noted in the test report, which shall be submitted at the conclusion of the pressure test to the chamber manufacturer/user.

2-7.6 Post-Test Inspection

At the conclusion of the pressure test, the windows shall be visually inspected for the presence of crazing, cracks, or permanent deformation. This examination may be performed without removal of the window from the chamber.

2-7.7 Rejection Criteria

Presence of crazing, cracks, or permanent deformation visible with the unaided eye (except for correction necessary to achieve 20/20 vision) shall be the cause of rejection of the windows and shall be so noted on the test report. Permanent deformation less than $0.001D_i$ in

magnitude measured at the center of the window shall not be cause for rejection.

2-7.8 Alternate Test Procedure

A hydrostatic or pneumatic test in excess of design pressure may be substituted for the mandatory tests of [paras. 2-7.3](#) and [2-7.4](#) for windows with a design temperature of 125°F (52°C) or less. During the hydrostatic or pneumatic test, the pressure shall be maintained for a minimum of 1 hr, but not more than 4 hr. The test pressure shall not exceed 1.5 times the design pressure or 20,000 psi (138 MPa), whichever is the lesser value. To prevent permanent deformation of windows tested above design pressure, the temperature of the pressurizing medium during the test shall be at least 25°F (14°C) lower than the design temperature. For windows with a 50°F (10°C) design temperature, the pressurizing medium during the test shall be 32°F to 40°F (0°C to 4°C). All the other requirements of the mandatory pressure test specified in [paras. 2-7.5](#) through [2-7.7](#) shall be retained.

2-7.9 Reporting Requirements

After pressure testing, a pressure test report shall be completed to certify the results of the pressure test. The information shall be reported on a form equivalent to [PVHO-1 Form VP-5](#) by the party who performs the pressure test.

2-7.10 Records Retention

Pressure test records shall be kept on file for at least the design life of the window plus 2 yr.

2-8 INSTALLATION OF WINDOWS IN CHAMBERS

2-8.1 Cleaning

The window cavity seat in the flange shall be thoroughly cleaned. Aliphatic naphtha and hexane are suitable fluids for cleaning.

2-8.2 Lubrication

The window cavity seats for all window shapes possessing conical bearing surfaces shall be thoroughly coated with grease prior to placement of the window inside the window cavity so that the greased surfaces will act as secondary seals. Silicone greases are suitable for this purpose. Other greases shall be checked for chemical compatibility with acrylic.

2-8.3 Assembly

After placement of the window inside the window cavity, the primary elastomeric seal shall be placed on the high-pressure face of the window and the retainer tightened until the seal compression reaches the minimum value specified in [para. 2-2.10](#).

2-9 REPAIR OF DAMAGED WINDOWS PRIOR TO BEING PLACED IN SERVICE

2-9.1 General

New fabricated windows that do not meet the acceptance criteria of [subsection 2-5](#), or windows that have been damaged during inspection, shipment, pressure testing, storage, handling, or installation in chambers but prior to being placed in service, may be repaired, provided the requirements of this subsection are met.

2-9.2 Damaged Window Criteria

For the purpose of this Standard, a damaged window is one that meets the criteria of [Section 2](#), is marked per [subsection 2-6](#), and has a Window Certification but has sustained damage that requires repair prior to being placed in service.

2-9.3 Dimensional Assessment

Windows are considered to be damaged when the window can no longer meet the dimensional tolerances and surface finishes specified by [subsection 2-5](#). The assessment of damage shall be performed by an authorized representative of the chamber manufacturer or user or by a window fabricator.

2-9.4 Damage Severity Determination

The damage to windows, depending on its severity, may be repaired by the chamber user or by an accredited fabricator of windows. Only slightly damaged windows may be repaired by the chamber user or an authorized agent, while severely damaged windows shall be repaired solely by a window fabricator.

2-9.5 Slightly Damaged Windows

The damage to windows is considered slight when it consists solely of scratches on the surfaces less than 0.020 in. (0.5 mm) deep or chips on the window edges less than 0.125 in. (3.2 mm) wide. Scratches deeper than 0.020 in. (0.5 mm), edge chips wider than 0.125 in. (3.2 mm), gouges, and cracks are considered severe damage.

2-9.6 Repairs of Slightly Damaged Windows

Slightly damaged windows may be repaired by the chamber user or an authorized agent, provided only hand sanding/polishing techniques are used, and the thickness and surface finish of the window after repair meet the requirements of [Section 2](#). The use of power-driven tools (disk sanders, buffing wheels, lathes, milling machines, etc.) is not allowed. These repairs do not require post annealing.

2-9.7 Repair of Severely Damaged Windows

Special conditions are applicable to the repair of severely damaged windows.

(a) Severely damaged windows shall be repaired by a window fabricator.

(b) Repair of severely damaged windows shall be initiated by the window fabricator only after receipt of written authorization from the chamber manufacturer or user and inspection of the damaged window for identification marking. Damaged windows whose identification does not correspond to the written authorization shall not be repaired.

(c) The written authorization shall be accompanied by the original Design (see [PVHO-1 Form VP-2](#)) and Fabrication Certifications (see [PVHO-1 Form VP-1](#)).

(d) During the repair, the window fabricator may use all the fabrication processes customarily employed in the fabrication of new windows that meet the requirements of [subsection 2-4](#).

(e) Upon completion of repair, the window shall be annealed according to the schedule of [Table 2-4.5-1](#).

(f) After annealing, the repaired window shall be inspected to ensure that the finished window meets the material quality, minimum thickness, dimensional tolerance, surface finish, and inclusion limitation requirements of [Section 2](#).

(g) Repaired windows shall be marked with the identification of the window fabricator performing the repair.

(h) The repair identification shall consist of 0.5-in. (12.5-mm) letters and numbers made with indelible black marker or 0.125-in. (3.2-mm) letters and numbers made with epoxy ink, located on the window's seating surface.

(i) The repair identification shall contain the following information, as per the following example:



The repair identification shall not obscure, in any manner, the original window identification.

(j) Original window identification marking that has been accidentally or intentionally removed during repair operations may be reapplied at this time, provided the restored original identification marking has identical wording to the original one that was removed, and the Repair Certification reflects this fact.

(k) The design life of the repaired window is determined by the original fabrication date shown on the window identification marking.

2-9.8 Repair of Spherical Window by Spot Casting

Windows with spherical surfaces whose dimensional tolerances, surface finish, or inclusions exceed the limits specified in [paras. 2-2.11](#), [2-5.3](#), and [2-5.5](#) may be repaired by spot casting, provided the following conditions are satisfied:

(a) The repaired spot shall be subjected only to compressive stresses in service.

(b) The casting mix used for spot repairs shall have the same chemical composition and shall be polymerized in the same manner as the casting mix in the window casting.

(c) For repaired spots located in areas within 2 deg of the window's edge circumference, or areas not visible from the interior of the pressure vessel by an observer in a typical position required for operation of the vessel, the following limitations apply:

(1) The volume of a single repaired spot shall not exceed 10%, and the cumulative volume of all repaired spots shall not exceed 20% of the total window volume.

(2) There is no limit on the number of repaired spots.

(d) For repaired spots located in areas outside 2 deg of the window's edge circumference, and visible from the interior of the pressure vessel to an observer in a typical position required for operation of the vessel, the following limitations apply:

(1) The area of any repaired spot shall not exceed 0.025% of the total window area.

(2) Only two repaired spots are permitted.

(e) After completion of machining and polishing operations, the window shall be annealed per [para. 2-4.5](#).

(f) Location and extent of spot casting repairs shall be noted on a sketch attached to [PVHO-1 Form VP-6](#).

2-10 GUIDELINES FOR APPLICATION OF THE REQUIREMENTS OF SECTION 2

2-10.1 Introduction

(a) [Section 2](#) presents the necessary information to design, fabricate, and pressure test acrylic windows that, when mounted and sealed in metallic seats, form the viewport assemblies acceptable as pressure-resistant barriers in pressure vessels for human occupancy.

(b) Restrictions are imposed on the service conditions to which the viewport can be subjected to preclude catastrophic failure of the window during its rated life. In order for the window to meet the high standard of safety demanded by human occupancy of the pressure vessel, each step in the production of the windows shall be certified for conformance to this Standard.

(c) Only high-quality cast acrylic (polymethyl methacrylate) is acceptable as the material for fabrication of windows under this Standard. Conformance of the material to the specifications of this Standard shall be proven by testing of material coupons (see [subsection 2-3](#)) and certification (see [PVHO-1 Forms VP-3](#) and [VP-4](#)).

2-10.2 Sample Design Procedures

(a) The design procedure consists of a series of steps that allow the engineer to design a window meeting the requirements of this Standard (see [subsection 2-2](#)).

Step 1. Determine the design pressure, P , and temperature of the pressure vessel. Use the values as maximum design allowable for windows.

Step 2. Select the designed window shape from available standard window geometries (see [Figures 2-2.2.1-1 through 2-2.2.1-4](#)). Note the restrictions on the service in which they can be placed (see [paras. 2-2.2 and 2-2.3](#)).

If the design requirements cannot be met by a standard window geometry, a nonstandard window geometry of your own design may be chosen. In that case, disregard the remainder of the design steps in (a) through (c) and follow instead the procedures specified in [subsection 2-11](#).

Step 3. Select the conversion factor (CF) appropriate for the chosen standard window geometry, pressure range, and temperature range (see [Tables 2-2.3.1-1 through 2-2.3.1-4](#)). Use the pressure range into which the design pressure falls. The CF given by the table represents the lowest value acceptable to this Standard. Whenever feasible, select a higher value than shown in the tables.

Step 4. Calculate the short-term critical pressure (STCP) of the window by multiplying the design pressure, P , by the CF selected in [Step 3](#).

Step 5. Calculate the dimensionless ratio, t/D_i or t/R , for the chosen window geometry by finding the appropriate graph that relates the STCP to the window's dimensionless ratio (see [Figures 2-2.5.1-1 through 2-2.5.1-12](#)). Draw a horizontal line from the appropriate STCP on the ordinate to the graph. From where it intersects the graph, drop a vertical line to the abscissa. The intersection with the abscissa provides the sought-after dimensionless ratio. For design pressures, P , above 10,000 psi (69 MPa), use [Table 2-2.3.2-1](#) to derive the required dimensional ratios. This table applies only to conical frustum windows with an included conical angle $\alpha \geq 60$ deg.

Step 6. Calculate the nominal window's dimensions on the basis of the dimensionless ratio. Wherever it is feasible, increase the nominal thickness to provide extra stock for future operational contingencies.

Step 7. Apply angular and dimensional tolerances to the nominal dimensions and specify surface finishes on the window (see [para. 2-2.11](#)). Enter all applicable data on drawings and [PVHO-1 Form VP-2](#).

(b) The windows can achieve the predicted STCPs only if they are mounted in seats with appropriate cavity dimensions, stiffness, and surface finishes (see [paras. 2-2.6, 2-2.9, and 2-2.11](#)).

Step 1. Calculate seat cavity dimensions on the basis of [Figures 2-2.9.1-1 through 2-2.9.1-8](#). For windows with conical bearing surfaces, the magnitude of seat cavity surface overhang depends on both the included conical

angle and the operational pressure range. The magnitude of overhang is given in terms of D_i/D_f ratios for any given combination of operational pressure ranges and conical angles. Operational pressure ranges 1, 2, 3, and 4 correspond to 0 psi to 2,500 psi, 2,500 psi to 5,000 psi, 5,000 psi to 7,500 psi, and 7,500 psi to 10,000 psi. For operational pressures above 10,000 psi (69 MPa), use [Table 2-2.3.2-1](#).

Step 2. Calculate the stiffness compliance of the window seat with analytical formulas or finite element stress analysis computer programs to meet the requirements of [para. 2-2.8](#). Since the window mounting forms a reinforcement around the penetration in the pressure vessel, its cross section shall also meet the requirements of the applicable Division of ASME BPVC, Section VIII.

Step 3. Apply angular and dimensional tolerances to the nominal dimensions and specify surface finishes on the seat cavity (see [paras. 2-2.9 and 2-2.11](#)). Enter all applicable data on the window seat drawing.

(c) Only certain sealing arrangements have been found to be successful with acrylic windows serving as pressure boundaries (see [para. 2-2.10](#)).

Step 1. Some of the proven seal designs acceptable under this Standard are shown in [Figures 2-2.5.1-1 through 2-2.5.1-6, 2-2.5.1-12, 2-2.9.1-2, and 2-2.9.1-5 through 2-2.9.1-8](#). Select the most appropriate sealing arrangement for your operational conditions. The bevels on the edges of windows cannot exceed the limits shown in [Figures 2-2.10.10-1 and 2-2.10.10-2](#).

Step 2. Seal designs that deviate from the requirements of this Standard shall be subjected to an experimental validation program that will define their effect on the design life of the windows (see [para. 2-2.6](#)).

2-10.3 Sample Purchase Specification and Product Reviews

The designed window, in order to achieve the STCP, shall be fabricated by an accredited window fabricator using materials and a production process that meet the requirements of [subsections 2-3 and 2-4](#), respectively.

Step 1. Ensure that the request for quotation and all drawings carry the following note:

"The cast acrylic, fabrication procedure, Quality Assurance Program, and finished window shall meet all the requirements of ASME PVHO-1."

This note alerts the fabricators to the additional factors imposed by the certification requirements of this Standard.

Step 2. Provide the successful bidder with [PVHO-1 Form VP-2](#), filled out by the window designer. [PVHO-1 Form VP-2](#), together with the window drawing, shall form the basis for future identification of the window.

Step 3. Upon receiving the window from the window fabricator, inspect the finished product dimensionally and visually for compliance to this Standard (see [para. 2-2.11 and subsection 2-4](#)). Review all of the paperwork, which

shall accompany the window (PVHO-1 Forms VP-1 through VP-4). Check for completeness and signatures. Compare the marking on the window bearing surface with

- (a) the identification number on PVHO-1 Form VP-1.
- (b) the design temperature and pressure on PVHO-1 Form VP-2. Only when the window complies with the requirements imposed by this Standard, and the accompanying Window Certification, PVHO-1 Forms VP-1 through VP-4, is complete, can the fabrication be considered to have met all of the contractual obligations imposed by the above note on the window drawing.

2-10.4 Sample Pressure Test Instructions

The window can now be installed into a new pressure chamber or pressure tested in a test fixture and placed in storage for future use as a replacement. If the window is tested in a new chamber (see subsection 2-7 for details of pressure testing), the test shall be conducted without human occupants.

Step 1. Immediately after the pressure test, inspect the window visually for the presence of crazing, cracks, fractures, or permanent deformation.

Step 2. If the window passed the post-pressure test inspection successfully, fill out PVHO-1 Form VP-5.

Step 3. Review certifications, PVHO-1 Forms VP-1 through VP-5, for completeness.

2-10.5 Sample Calculations

The following sample calculations of hypothetical window and window seat dimensions illustrate the design procedure:

Step 1.1. Determine design conditions:

Design pressure = 1,000 psi

Design temperature = 125°F

Window diameter = 10 in.

Step 1.2. Select window shape:

Conical frustum with 90 deg included angle (see Figure 2-2.2.1-1)

Step 1.3. Select conversion factor:

CF = 10, $N = 1$ (see Table 2-2.3.1-2)

Step 1.4. Calculate STCP:

$$\begin{aligned}\text{STCP} &= \text{CF} \times P = 10 \times 1,000 \\ &= 10,000 \text{ psi (68.96 MPa)}\end{aligned}$$

Step 1.5. Select the dimensionless ratio for windows:

$t/D_i = 0.41$ for STCP = 68.96 MPa

$\alpha = 90 \text{ deg}$ (see Figure 2-2.5.1-5)

Step 1.6. Calculate nominal window dimensions:

$D_i = 10 \text{ in.}$

$t = 0.41 \times 10 \text{ in.} = 4.1 \text{ in.}$

$t/D_i = 0.41$

$\alpha = 90 \text{ deg}$

Add 0.1 in. to thickness for future operational contingencies:

Nominal $t = 4.2 \text{ in.}$

Nominal angle = 90 deg

Nominal $D_i = 10 \text{ in.}$

Nominal $D_o = 18.4 \text{ in.}$ (calculated)

Step 1.7. Apply dimensional tolerances to windows (see para 2-2.11):

$D_o = 18.400 +0.000/-0.037 \text{ in.}$ (to sharp edge)

$\alpha = 90 +0.25/-0.00 \text{ deg}$

Bearing surface finish = 32 $\mu\text{in. RMS}$

Step 2.1. Calculate nominal dimensions for seat cavity:

$D_f = 10.000/1.03 = 9.709 \text{ in.}$ (see Figure 2-2.9.1-1)

$D_i/D_f = 1.03$ for pressure range $N = 1$ and included angle 90 deg

$D_o = 18.400 \text{ in.}$

$\alpha = 90 \text{ deg}$

Step 2.2. Calculate cross section of window mounting. (Use procedure of your own choice; NSRDC Report 1737, "Structural Design of Viewing Ports for Oceanographic Vehicles," by K. A. Nott, 1963, can be very helpful.)

Step 2.3. Apply dimensional tolerances to window seat.

Step 3.1. Select sealing arrangement: neoprene O-ring seal compressed against beveled edge of major window diameter by a flat retaining ring (see Figure 2-2.5.1-4). The magnitude of the bevel cannot exceed the limits shown in Figure 2-2.10.10-1. The size of the bevel chosen will provide adequate compression to a nominal 0.25-in. diameter O-ring.

Step 3.2. Enter the following final viewport dimensions on drawing:

(a) Window

$D_o = 18.400 +0.00/-0.037 \text{ in.}$ (to sharp edge)

$t = 4.200 +0.020/-0.00 \text{ in.}$

$\alpha = 90 +0.25/-0.000 \text{ deg}$

(b) Seal

O-ring thickness = $\frac{1}{4} \text{ in.}$ (nominal)

O-ring inside diameter = 17.75 in. (nominal)

(c) Seat

$D_f = 9.709 +0.010/-0.000 \text{ in.}$

$D_o = 18.400 +0.020/-0.000 \text{ in.}$

$\alpha = 90 +0.000/-0.25 \text{ deg}$

2-11 NONSTANDARD WINDOW GEOMETRIES AND STANDARD WINDOW GEOMETRIES WITH LOWER CONVERSION FACTORS

2-11.1 Case Submittal Procedure

Acrylic windows of nonstandard geometry, or of standard geometry but with nonstandard lower CFs, may be submitted for consideration as a Case for adoption by the ASME Pressure Vessels for Human Occupancy Committee

and possible subsequent incorporation into the Standard as another standard geometry or standard CF for windows meeting the design parameters of [subsection 2-2](#).

(a) Prior to submission for review, the window design shall be experimentally verified according to [para. 2-11.3](#), and the window design, testing procedure, test results, and any other pertinent analytical or experimental data shall be summarized in a clear, concise, and legible technical report.

(b) One copy of the report shall accompany the submission for consideration by the Committee. Submission of the report to the Committee places its content into the public domain for review and comment by the public.

2-11.2 Use in Standard PVHOs

Windows with nonstandard geometries, or with standard geometries and lower CFs, may be incorporated into chambers for human occupancy provided their material properties and structural performance satisfy the mandatory short-term, long-term, and cyclic proof pressure requirements of this Standard.

2-11.3 Testing Criteria

Windows with nonstandard geometries, or with standard geometries and lower CFs, shall meet the following mandatory requirements:

(a) *short-term proof pressure (STPP)*: 4 times the design pressure, sustained continuously for a minimum of 30 min without catastrophic failure at design temperature environment under short-term pressurization

(b) *long-term proof pressure (LTPP)*: design pressure sustained continuously for 80,000 hr or according to the alternative LTPP test procedure in [para. 2-11.5.2](#) in design temperature environment without catastrophic failure

(c) *crack-free cyclic proof pressure (CPP)*: design pressure sustained intermittently during 1,000 pressure cycles of 8 hr each in design temperature environment without cracking

2-11.4 STPP Test Procedure

The STPP of a window with nonstandard geometry, or with standard geometry and lower CF, shall be experimentally verified with a minimum of five windows. The STPP windows tested may consist of any combination of model-scale (of the same size) or full-scale windows.

(a) The windows shall be individually pressurized at 650 ± 100 psi/min (4.5 ± 0.7 MPa/min) in the design temperature environment to the STPP.

(b) All five windows shall survive the STPP test without catastrophic failure.

2-11.5 LTPP Test Procedure

2-11.5.1 Regular LTPP Test Procedure. The LTPP of a window with nonstandard geometry, or with standard geometry and lower CF, shall be experimentally verified as per the following paragraphs, using model-scale (of the same size) or full-scale windows:

(a) The windows shall be individually subjected to sustained pressure loading at design temperature.

(b) Each window shall be subjected to a different hydrostatic pressure, and the duration of sustained pressure preceding the catastrophic failure shall be recorded.

(c) The pressures to which five individual windows shall be subjected are 0.9, 0.8, 0.75, 0.7, and 0.65 times the average STCP established experimentally in [para. 2-11.4](#).

(d) The experimental data points of (c) shall be plotted on log-log coordinates, and the relationship between critical pressures and duration of loading shall be represented empirically by a straight line. The experimental points generated in [para. 2-11.4](#) with 30-min sustained loading duration shall be plotted on the same graph. The testing of any window specimen that has not failed in 10,000 hr of sustained loading may be terminated at that time and its data point omitted from the graph.

(e) The extension of the plotted line to 80,000 hr of sustained loading shall exceed the LTPP. The extrapolated failure at 80,000 hr shall be at least two times the design pressure.

(f) An alternative to the LTPP tests defined in (b) through (e) shall be sustained pressure loading of individual windows for a duration of 10,000 hr at design temperature per one of the following test programs:

(1) One window shall be tested at a sustained pressure equal to 0.9 STPP.

(2) Two windows shall be tested at a sustained pressure equal to 0.85 STPP.

(3) Three windows shall be tested at a sustained pressure equal to 0.8 STPP.

(4) Four windows shall be tested at a sustained pressure equal to 0.75 STPP.

(5) Five windows shall be tested at a sustained pressure equal to 0.7 STPP.

If all windows of any one of the five selected test programs in (1) through (5) survive sustained pressurization for 10,000 hr without catastrophic failure, the window design is considered to have satisfied fully all requirements of the LTPP test.

2-11.5.2 Alternative LTPP Test Procedure (ALTPP).

An ALTPP test as defined in this paragraph shall be conducted using model-scale or full-scale windows under one or more of the test pressure options contained in [Table 2-11.5.2-1](#) and the acceptance criteria contained in [Figure 2-11.5.2-1](#).

The use of one or more model-scale windows for ALTPP testing is permitted only if the short-term strength of the model is equivalent to that obtained for a minimum of three full-scale windows. To verify model-scale equivalence, the STPP test in [para. 2-11.4](#) shall be performed on a model-scale window and the failure pressure obtained shall lie within the range obtained on a minimum of three full-scale windows. The same conditions of temperature and rate of pressurization used for full-scale windows shall be applied to the model-scale window. If the model-scale test does not meet these criteria, full-scale windows shall be required for ALTPP tests.

Windows shall be subjected to sustained pressure at maximum design temperature for at least 300 hr without any failure per any one of the procedures in [\(a\)](#), [\(b\)](#), or [\(c\)](#), where design pressure is determined in accordance with [Table 2-11.5.2-1](#).

Three test options are available. In all three cases, however, the test temperature and duration shall be at maximum design temperature for at least 300 hr. [Figure 2-11.5.2-1](#) illustrates these requirements.

(a) If only one creep test is to be performed, it shall be conducted at a pressure and for a duration greater than that defined by a straight line on a semi-log plot (rectilinear pressure versus logarithmic time) defined by the point at 9 times the design pressure and a duration of 0.1 hr at one end and the point at 3 times the design pressure and a duration of 80,000 hr at the other end. If the specimen test pressure and duration exceed the pressure and time defined by this line and the test duration is at least 300 hr, then the design meets the creep test requirements.

(b) If three creep test are to be performed, they shall all be conducted at a pressure and for a duration greater than that defined by a straight line on a semi-log plot (rectilinear pressure versus logarithmic time) defined by the point at 9 times the design pressure and a duration of 0.1 hr at one end and at 2 times the design pressure and a duration of 80,000 hr at the other end. If all three specimen test pressures and durations exceed the pressure and time defined by this line and the test duration for each specimen is at least 300 hr, the design meets the creep test requirements.

(c) If five creep test are to be performed, they shall be conducted at a pressure and for a duration greater than that defined by a straight line on a semi-log plot (rectilinear pressure versus logarithmic time) defined by the point at 6 times the design pressure and a duration of 0.1 hr at one end and at 2 times the design pressure and a duration of 80,000 hr at the other end. If all five specimen test pressures and durations exceed the pressure and time defined by this line and the test duration for each specimen is at least 300 hr, the design meets the creep test requirements.

In all three options, if all windows of any one of the test options survive sustained pressurization without catastrophic failure, the window design is considered to have satisfied fully all requirements of the ALTPP test.

2-11.6 CPP Test Procedure

The crack-free CPP of the window with nonstandard geometry, or with standard geometry and lower CF, shall be experimentally verified on a minimum of two model-scale windows (of the same size) or a single full-scale window.

(a) The window shall be pressure cycled 1,000 times from zero to CPP in the design temperature environment.

(b) The length of the individual pressure cycles may vary from one cycle to another, but the average length of the sustained loading and relaxation phases in all of the pressure cycles shall equal or exceed 4 hr.

(c) At the completion of 1,000 pressure cycles, the window shall be visually inspected with the unaided eye (except for correction necessary to achieve 20/20 vision) for the presence of cracks.

(d) Absence of visible cracks shall be considered proof that the window design meets the crack-free CPP requirement of this Standard.

2-11.7 Test Temperature Criteria

The temperature of the window, the window test assembly, and its pressurizing medium during the performance of proof tests is allowed to deviate from the specified design temperature by the following margin:

(a) for the short-term pressurization of [para. 2-11.4](#), +10°F (5.5°C)

(b) for the long-term pressurization of [para. 2-11.5](#), +10°F (5.5°C)

(c) for the cyclic pressurization of [para. 2-11.6](#), +25°F (14°C)

2-11.8 Fixturing

All STPP, LTPP, and CPP testing shall be performed with each window mounted securely in a test fixture designed to withstand the maximum test pressure to which the window may be subjected.

(a) The window seat dimensions of the test fixture for full-size windows shall be the same as those used for the viewport flanges with operational full-size windows.

(b) The window seat dimensions of the test fixture for model-scale windows shall be scaled down from test fixtures for full-size windows.

2-11.9 Scaling

The successful qualification of a window design with nonstandard geometry, or with standard geometry and lower CF, for a chosen design pressure and temperature under the procedures of [paras. 2-11.2](#) through [2-11.8](#), qualifies also other window designs with the same

geometry and same or higher t/D_i ratios for the same or lower design pressure and temperature.

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

PVHO-1 Form VP-1 Fabrication Certification for Acrylic Windows

Window Drawing No. _____

Window Identification _____

Material Stock Description

Manufacturer of acrylic _____

Trade name _____

Casting shape _____ Nominal thickness _____

Lot number _____ Casting number _____

Certified for conformance to Table 2-3.4-1 by _____ Date _____

Certified for conformance to Table 2-3.4-2 by _____ Date _____

Window Description

Maximum allowable working pressure rating _____ psi _____ MPa

Maximum temperature rating _____ °F _____ °C

Window designed by _____

Joint bonding (if applicable) _____ (name of company and designer)

Manufacturer of acrylic cement _____

Trade name of cement _____

Curing means and duration _____

Average tensile strength (per ASTM D638) _____

Joint quality conforms to para. 2-3.10 (yes/no) _____

Polishing agents _____

Cleaning agent _____

Fabrication Process Data

First annealing temperature (if applicable) _____

Duration _____ Cooling rate _____

Intermediate annealing temperature (if applicable) _____

Duration _____ Cooling rate _____

Final annealing temperature (chart required) _____

Duration _____ Cooling rate _____

Dimensional checksActual outside diameter, D_o _____ Actual inside diameter, D_i _____Actual thickness, t_{max} and t_{min} _____ Actual included angle, α _____

Actual sphericity (maximum deviation from specified sphericity measured by a template on the concave or convex surface) _____

Conforms/deviates from specification for spot casting repairs _____

Window fabricator has tested windows _____ Yes _____ No

Window fabricator has completed PVHO-1 Form VP-5 _____ Yes _____ No

The window identified above has been fabricated in accordance with the material and fabrication requirements of the Safety Standard for Pressure Vessels for Human Occupancy, ASME PVHO-1—_____ edition, and company _____ drawing number _____, revision _____, dated _____.

(authorized representative of window fabricator)_____
(date)_____
(name and address of window fabricator)

GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

PVHO-1 Form VP-2 Acrylic Window Design Certification

Window Description

Window Drawing No. _____

Maximum allowable working pressure _____ psi _____ MPa

Maximum design temperature _____ °F _____ °C Minimum design temperature _____ °F _____ °C

Window shape _____

Conversion factor table number _____

Pressure range, N _____ Conversion factor, CF _____ at _____ °F _____ °C

Maximum internal ambient temp. _____ °F _____ °C Minimum external ambient temp. _____ °F _____ °C

Short-term critical pressure and figure no. _____

Experimental Verification [Note (1)]

No. 1 _____ No. 2 _____

Thickness, t (actual) _____

No. 3 _____ No. 4 _____

 D_o (actual) _____ D_i (actual) _____

No. 5 _____ STCP _____

Water temperature _____ °F _____ °C

(Note each test specimen FS for full scale or MS for model scale.)

Type of failure _____

Test conducted at _____

Test supervised by _____

Window Design

Inner diameter, D_i (nominal) _____ Outer diameter, D_o (nominal) _____

Included angle (nominal) _____ External radius of curvature (nominal) _____

Minimum t (calculated) _____ Minimum t/D_i (calculated) _____ D_o/D_i (nominal) _____ D_i/D_i (nominal) _____Minimum D_i (calculated) _____ Maximum D_i (calculated) _____Diametral interference/clearance between
 D_o of window and window seat at maximum
design temperature (calculated) _____Diametral interference/clearance between
 D_o of window and window seat at minimum
design temperature (calculated) _____Actual t (specified on drawings) _____Actual D_i (specified on drawings) _____Actual D_i (specified on drawings) _____ Actual D_o (specified on drawings) _____Actual external radius of curvature
(specified on drawings)
(spherical or cylindrical) _____

Drawing no. of window _____ Drawing no. of flange _____ Drawing no. of assembly _____

Description of pressure vessel (for which the window has been designed) _____


The viewport design complies with all of the requirements of the Safety Standard for Pressure Vessels for Human Occupancy, subsection 2-2.

(viewport designer) (date)_____
(authorized representative of chamber manufacturer or owner) (date)_____
(name and address of chamber manufacturer or owner) (date)


GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

NOTE: (1) If STCP is determined experimentally according to para. 2-2.5.2, then the critical pressures of all five windows tested, the testing laboratory, and the test supervisor should be noted here.


Figure 2-2.2.1-1
Standard Window Geometries — Part 1



(a) Flat Disk Window




(b) Conical Frustum Window



(c) Double-Beveled Disk Window

Figure 2-2.2.1-2
Standard Window Geometries — Part 2

(23)



$$D_i = 2R_i \sin \alpha/2$$

$$t \geq 1/2 \text{ in. (12.5 mm)}$$


$$\alpha \geq 30 \text{ deg}$$

$$t/R_i \geq 0.09 \text{ for } \alpha \geq 60 \text{ deg}$$

$$t/R_i \geq 0.06 \text{ for } \alpha \geq 90 \text{ deg}$$

$$t/R_i \geq 0.03 \text{ for } \alpha = 180 \text{ deg}$$

(a) Spherical Sector Window With Conical Edge



$$t \geq 1/2 \text{ in. (12.5 mm)}$$

$$30 \text{ deg} \leq \alpha \leq 150 \text{ deg}$$

$$t/R_i \geq 0.03$$

$$D_i = 2R_i \sin \alpha/2$$

$$D_o = 2R_o \sin \alpha/2$$


$$R_o = R_i + t$$

$$\ell = t \sin (90 \text{ deg} - \alpha/2)$$


(b) Spherical Sector Window With Square Edge

(23)

Figure 2-2.2.1-3
Standard Window Geometries — Part 3




(a) Hemispherical Window With Equatorial Flange



(b) Cylindrical Window

Figure 2-2.2.1-4
Standard Window Geometries — Part 4




$$t \geq \frac{1}{2} \text{ in. (12.5 mm)}$$

$$0.03 \leq t/R_o \leq 0.355$$

$$\alpha \leq 100 \text{ deg}$$

(a) Hyperhemispherical Window



$$t \geq \frac{1}{2} \text{ in. (12.5 mm)}$$

$$0.03 \leq t/R_o \leq 0.355$$

$$\alpha \leq 50 \text{ deg}$$

ω, θ = spacing between adjacent penetrations shall exceed $\alpha/2$ of the larger penetrations

(b) NEMO Window

Table 2-2.3.1-1
Conversion Factors for Acrylic Flat Disk Windows

(23)

Operational Pressure Range		Conversion Factor, CF, at				
<i>N</i>	psi (MPa)	50°F (10°C)	75°F (24°C)	100°F (38°C)	125°F (52°C)	150°F (66°C)
1	2,500 (17.2)	5	6	8	10	16
2	5,000 (34.5)	5	6	8	10	
					4,000 psi (27.6 MPa)LIMIT.....	
3	7,500 (51.7)	5	6			
			7,000 psi (48.3 MPa)LIMIT.....			

GENERAL NOTES:

- (a) The conversion factors (CF) in this table apply only to short-term critical pressures (STCP) plotted in Figures 2-2.5.1-1 through 2-2.5.1-3.
 (b) Dotted lines refer to intermediate pressure ranges.
 (c) Interpolation between CFs is allowed.

Table 2-2.3.1-2**Conversion Factors for Acrylic Conical Frustum Windows and Double-Beveled Disk Windows**

Operational Pressure Range		Conversion Factor, CF, at				
<i>N</i>	psi (MPa)	50°F (10°C)	75°F (24°C)	100°F (38°C)	125°F (52°C)	150°F (66°C)
1	2,500 (17.2)	5	6	8	10	16
		Conversion factors for these pressures shall be interpolated between the upper and lower values shown. 4,500 psi (31 MPa)LIMIT.....				
2	5,000 (34.5)	4	5	7	9	
3	7,500 (51.7)	4	5	...		
4	10,000 (69)	4	5 8,000 psi (55.2 MPa)LIMIT.....			

GENERAL NOTES:

- (a) The CFs in this table apply only to STCPs plotted in [Figures 2-2.5.1-4](#) and [Figures 2-2.5.1-5](#).
 (b) Dotted lines refer to intermediate pressure ranges.
 (c) Interpolation between CFs is allowed.

Table 2-2.3.1-3**Conversion Factors for Acrylic Spherical Sector Windows With Conical Edge, Hyperhemispherical Windows With Conical Edge, and NEMO-Type Windows With Conical Edge**

Operational Pressure Range		Conversion Factor, CF, at				
<i>N</i>	psi (MPa)	50°F (10°C)	75°F (24°C)	100°F (38°C)	125°F (52°C)	150°F (66°C)
1	2,500 (17.2)	4	6	8	10	16 1,500 psi (10.3 MPa)LIMIT.....
2	5,000 (34.5)	4	6	8 3,500 psi (24.1 MPa)LIMIT.....	10 3,000 psi (20.7 MPa)LIMIT.....	
3	7,500 (51.7)	4	...			

GENERAL NOTES:

- (a) The CFs in this table apply only to STCPs plotted in [Figures 2-2.5.1-6](#) and [Figures 2-2.5.1-7](#) for spherical sector windows with conical edge and [Figures 2-2.5.1-14](#) and [2-2.5.1-15](#) for hyperhemispherical windows with conical edge and NEMO-type windows with conical penetrations.
 (b) Dotted lines refer to intermediate pressure ranges.
 (c) Interpolation between CFs is allowed.

Table 2-2.3.1-4
Conversion Factors for Acrylic Spherical Sector Windows With Square Edge and Hemispherical Windows With Equatorial Flange (23)

Operational Pressure Range		Conversion Factor, CF, at				
<i>N</i>	psi (MPa)	50°F (10°C)	75°F (24°C)	100°F (38°C)	125°F (52°C)	150°F (66°C)
1	2,500 (17.2)	5	7	9	11	17 1,500 psi (10.3 MPa)LIMIT.....
2	5,000 (34.5)	5	7	9 3,000 psi (20.6 MPa)LIMIT.....		
3	7,500 (51.7)	5	...			

GENERAL NOTES:

- (a) The CFs in this table apply only to STCPs plotted in Figures 2-2.5.1-6 and 2-2.5.1-7.
 (b) Dotted lines refer to intermediate pressure ranges.
 (c) Interpolation between CFs is allowed.

Table 2-2.3.1-5
Conversion Factors for Acrylic Cylindrical Windows (23)

Operational Pressure Range		Conversion Factor, CF, at				
<i>N</i>	psi (MPa)	50°F (10°C)	75°F (24°C)	100°F (38°C)	125°F (52°C)	150°F (66°C)
Part A: Internal Pressure						
1	250 (1.7)	13	14	15	20	25
Part B: External Pressure						
1	2,500 (17.2)	6	7	9	11	17

GENERAL NOTES:

- (a) The CFs in Part A of this table apply only to STCPs plotted in Figures 2-2.5.1-8 and 2-2.5.1-9.
 (b) The CFs in Part B of this table apply only to STCPs plotted in Figures 2-2.5.1-10 through 2-2.5.1-13. Since the tube may fail due to yielding of material (see Figure 2-2.5.1-8) or elastic buckling (see Figures 2-2.5.1-9 through 2-2.5.1-11), both modes of failure shall be considered in selection of t/D ratio. The mode of failure that is chosen as the design criterion depends on which of the failure modes requires a higher t/D_i ratio for the desired STCPs. The mode of failure requiring a higher t/D_i ratio is chosen as the design criterion.
 (c) Interpolation between CFs is allowed.

Table 2-2.3.2-1
Conical Frustum Windows for Design Pressures in Excess of 10,000 psi (69 MPa)

Design Pressure		Temperature Ranges									
		$\leq 50^\circ\text{F} (10^\circ\text{C})$					$\leq 75^\circ\text{F} (24^\circ\text{C})$				
		D_i/D_f					D_i/D_f				
psi	MPa	t/D_i	60 deg	90 deg	120 deg	150 deg	t/D_i	60 deg	90 deg	120 deg	150 deg
11,000	75.86	1.0	1.13	1.17	1.23	1.69	1.1	1.13	1.17	1.23	1.69
12,000	82.76	1.1	1.13	1.17	1.23	1.69	1.2	1.13	1.17	1.23	1.69
13,000	89.66	1.2	1.13	1.17	1.23	1.69	1.3	1.13	1.17	1.23	1.69
14,000	96.55	1.3	1.13	1.17	1.23	1.69	1.4	1.13	1.17	1.23	1.69
15,000	103.45	1.4	1.13	1.17	1.23	1.69	1.5	1.13	1.17	1.23	1.69
16,000	110.34	1.5	1.20	1.26	1.53	2.48	1.6	1.20	1.26	1.53	2.48
17,000	117.24	1.6	1.20	1.26	1.53	2.48	1.7	1.20	1.26	1.53	2.48
18,000	124.14	1.7	1.20	1.26	1.53	2.48	1.8	1.20	1.26	1.53	2.48
19,000	131.03	1.8	1.20	1.26	1.53	2.48	1.9	1.20	1.26	1.53	2.48
20,000	137.93	1.9	1.20	1.26	1.53	2.48	2.0	1.20	1.26	1.53	2.48

GENERAL NOTE: D_i/D_f ratio refers to the conical frustum seat specification shown in Figure 2-2.9.1-1.

Figure 2-2.5.1-1
Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 1




Figure 2-2.5.1-2
Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 2




Figure 2-2.5.1-3
Short-Term Critical Pressure of Flat Disk Acrylic Windows — Part 3




Figure 2-2.5.1-4
Short-Term Critical Pressure of Conical Frustum Acrylic Windows — Part 1




Figure 2-2.5.1-5
Short-Term Critical Pressure of Conical Frustum Acrylic Windows — Part 2




Figure 2-2.5.1-6
Short-Term Critical Pressure of Spherical Sector Acrylic Windows — Part 1




Figure 2-2.5.1-7
Short-Term Critical Pressure of Spherical Sector Acrylic Windows — Part 2




Figure 2-2.5.1-8
Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Internally — Part 1




Figure 2-2.5.1-9
Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Internally — Part 2




Figure 2-2.5.1-10
Short-Term Critical Pressure of Cylindrical Acrylic Windows Pressurized Externally





Figure 2-2.5.1-11
Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure —
Part 1




Legend:

$$D = \frac{D_i + D_o}{2}$$

P_c = short-term critical pressure
 $= \eta \times 3.499 \times 10^{-2}$ (psi)
 $= \eta \times 2.413 \times 10^{-4}$ (MPa)

Figure 2-2.5.1-12
Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure —
Part 2




Legend:

$$D = \frac{D_i + D_o}{2}$$

P_c = short-term critical pressure
 $= \eta \times 3.499 \times 10^{-2}$ (psi)
 $= \eta \times 2.413 \times 10^{-4}$ (MPa)

Figure 2-2.5.1-13
Short-Term Elastic Buckling of Cylindrical Acrylic Windows Between Supports Under External Hydrostatic Pressure —
Part 3



Legend:

$$D = \frac{D_i + D_o}{2}$$

P_c = short-term critical pressure
 $= \eta \times 3.499 \times 10^{-2}$ (psi)
 $= \eta \times 2.413 \times 10^{-4}$ (MPa)

Figure 2-2.5.1-14
Short-Term Critical Pressure of Hyperhemispherical and NEMO-Type Acrylic Windows — Part 1




Figure 2-2.5.1-15
Short-Term Critical Pressure of Hyperhemispherical and NEMO-Type Acrylic Windows — Part 2






Figure 2-2.9.1-1
Seat Cavity Requirements — Conical Frustum Window, Spherical Sector Window With Conical Edge,
and Flat Disk Window




(a) Conical Frustum Window

Operational Pressure Range	D_i/D_f Ratios			
	Included Angle, deg			
	60	90	120	150
$N = 1$	1.02	1.03	1.06	1.14
$N = 2$	1.04	1.06	1.12	1.28
$N = 3$	1.08	1.09	1.17	1.36
$N = 4$	1.10	1.20	1.20	1.42



**(b) Spherical Sector
Window With Conical Edge**

Operational Pressure Range	$[2R_i \sin(\alpha/2)]/D_f$ Ratios (Spherical Sector With Conical Edge)	
	Included Angle, deg	
	30–180	
$N = 1$	1.02	
$N = 2$	1.03	
$N = 3$	1.05	




(c) Flat Disk Window

GENERAL NOTES:

- (a) For α between values shown, interpolation is required.
 (b) $\frac{1}{32}$ in. (1.0 mm) $\leq R1 \leq \frac{1}{16}$ in. (2.0 mm).
 (c) K is selected on the basis of structural analysis.
 (d) β is selected on the basis of optical requirements.

Figure 2-2.9.1-2
Seat Cavity Requirements — Double-Beveled Disk Window




Operational Pressure Range	Included Angle, deg			
	60	90	120	150
$N = 1$	1.02	1.03	1.06	1.14
$N = 2$	1.04	1.06	1.12	1.28
$N = 3$	1.08	1.09	1.17	1.36
$N = 4$	1.10	1.15	1.20	1.42

GENERAL NOTES:

- (a) For α between values shown, interpolation is required.
- (b) K is selected on the basis of structural analysis.
- (c) β is selected on the basis of optical requirements.
- (d) $l \leq 0.25t$.
- (e) $n \leq l$.
- (f) $\frac{1}{32}$ in. (1.0 mm) $\leq R1 \leq \frac{1}{16}$ in. (2.0 mm).


Figure 2-2.9.1-3
Seat Cavity Requirements — Spherical Sector Window With Square Edge



GENERAL NOTES:

- (a) K is selected on the basis of structural analysis.
- (b) β is selected on the basis of optical requirements.
- (c) $D_o = 2 R_o \sin \alpha/2$.
- (d) $D_i = 2 R_i \sin \alpha/2$.
- (e) $D_i - D_f \geq \frac{1}{8}$ in. (3.0 mm).
- (f) $\ell_s \geq t \sin (90 \text{ deg} - \alpha/2)$.
- (g) $R_o = R_i + t$.

Figure 2-2.9.1-4
Seat Cavity Requirements — Hemispherical Window With Equatorial Flange




Operational Pressure Range	D_i/D_f
$N = 1$	1.02
$N = 2$	1.03
$N = 3$	1.05

- GENERAL NOTES:
- (a) K is selected on the basis of structural analysis.
 - (b) β is selected on the basis of optical requirements.


Figure 2-2.9.1-5
Seat Cavity Requirements — Cylindrical Window

(23)



(a) Under Internal Pressure

- K is selected on the basis of structural analysis
 R_f = internal radius of window seat
 $\leq$ calculated R_i of cylinder at zero internal pressure and -30°C minus gasket compressed 50%
 R_k = external radius of window seat
 $\geq$ calculated maximum R_o of cylinder under sustained internal design pressure of 8 hr duration at design temperature plus gasket compressed 50%
 $R_n \geq 1/32$ in. (1.0 mm)




(b) Under External Pressure

- K is selected on the basis of structural analysis
 $M_c \geq 0.05R_i$
 R_f = internal radius of window seat
 $\approx$ calculated R_i of cylinder under zero external pressure at design temperature minus thickness of gasket
 R_k = external radius of window seat
 $\geq$ calculated R_o of cylinder under zero external pressure at $+52^\circ\text{C}$ plus gasket compressed 50%
 $R_n \geq 1/32$ in. (1.0 mm)

Hard bearing gasket
bonded to flange
 $R_i - R_f \leq 0.01R_i$

(23)

Figure 2-2.9.1-6
Seat Cavity Requirements — Hyperhemispherical Window



$$K_o - K_i \geq \frac{1}{4} \text{ in. (6.0 mm)}$$

$$C_i \geq \frac{1}{32} \text{ in. (1.0 mm)}$$

$$C_o \geq \frac{1}{16} \text{ in. (2.0 mm)}$$

$$\alpha \leq 100 \text{ deg}$$

Legend:


D_h = diameter of the opening in the pressure hull

K_i = inner diameter of the conical seat

K_o = inner diameter of the penetration in the window

α = included spherical angle of the opening

Figure 2-2.9.1-7
Seat Cavity Requirements — NEMO Window (Standard Seat)




$$\begin{aligned}
 k &\geq 0.005R_o \\
 m &\geq 0.01R_o \\
 \alpha &\leq 50 \text{ deg} \\
 (\alpha + 8 \text{ deg}) &\leq \epsilon \leq (\alpha + 12 \text{ deg})
 \end{aligned}$$

Legend:

E_s = orientation of effective radial stiffness
 k = thickness of compressed gasket
 m = elevation of hatch ring
 α = spherical angle of window penetration
 ϵ = spherical angle of split retaining ring
 γ = spherical angle of hatch seat

GENERAL NOTE: The variables x , b , z , and l shall be proportioned in such a manner that the effective radial stiffness of all inserts at the penetration does not exceed the radial stiffness of acrylic sector with included angle α by more than 3,500%.

Figure 2-2.9.1-8
Seat Cavity Requirements — NEMO Window (Seat With Extended Cyclic Fatigue Life)



$$\begin{aligned}
 g &\geq 0.03R_o \\
 k &\geq 0.005R_o \\
 m &\geq 0.01R_o \\
 \alpha &\leq 50 \text{ deg} \\
 (\alpha + 8 \text{ deg}) &\leq \varepsilon \leq (\alpha + 12 \text{ deg})
 \end{aligned}$$

Legend:

- E_s = orientation of effective radial stiffness
- g = thickness of plastic insert
- k = thickness of compressed gasket (neoprene)
- m = elevation of hatch ring
- α = spherical angle of window penetration
- ε = spherical angle of split retaining ring
- γ = spherical angle of hatch seat

GENERAL NOTE: The variables x , b , z , and l shall be proportioned in such a manner that the effective radial stiffness of all inserts at the penetration does not exceed the radial stiffness of acrylic sector with included angle α by more than 3,500%.

Figure 2-2.10.10-1
Bevels on Window Edges — Flat Disk Windows, Conical Frustum Windows, Spherical Sector Windows, Hyperhemispheres

(23)




Figure 2-2.10.10-2
Bevels on Window Edges — Flanged Hemispherical Window, Spherical Sector Window With Square Edge,
External Pressure and Internal Pressure of Cylindrical Windows






Figure 2-2.10.11-1
Acceptable Configurations for Clear Viewport Retaining Covers




(a) Flat Disk Viewport Cross Section



(b) Conical Frustum Viewport Cross Section

Figure 2-2.13.11-1
Dimensional Tolerances for Penetrations in Acrylic Windows

(23)



Legend:
 M_o = outside diameter of penetrations
 R_i = radius of curvature
 φ = conical seat angle

Table 2-2.13.13-1
Specified Values of Physical Properties for Polycarbonate Plastic

Test Procedures	Physical Property	Specified Values	
		U.S. Customary Units	SI Units
ASTM D638 [Note (1)]	Tensile:		
	(a) ultimate strength	≥9,000 psi	≥62 MPa
	(b) elongation at break	≥20.0%	≥20.0%
ASTM D695 [Note (1)]	(c) modulus of elasticity	≥300,000 psi	≥2 069 MPa
	Compressive:		
	(a) yield strength	≥12,000 psi	≥82.8 MPa
ASTM D695 [Note (1)]	(b) modulus of elasticity	≥300,000 psi	≥2 069 MPa
	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C) for 24 hr	≤2%	≤2%
ASME PVHO-1 method, para. 2-3.7(c)	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C) for 24 hr	≤2%	≤2%
ASTM D732 [Note (1)]	Shear, ultimate strength	≥9,000 psi	≥62 MPa
ASTM E308	Ultraviolet transmittance	≤5%	≤5%

GENERAL NOTE: Test coupons shall be taken from each plate that serves as machining stock for inserts and shall be tested to verify that the physical properties of the material meet the requirements in this table.

NOTE: (1) These tests require testing a minimum of two specimens. For others, test a minimum of one specimen. Where applicable, use the sampling procedures described in para. 2-3.7. Where two specimens are required in the test procedure, the average of the test values shall be used to meet the requirements of the minimum physical properties of this table.

Table 2-2.13.13-2
Specified Values of Physical Properties for Cast Nylon Plastic


Test Procedures	Physical Property	Specified Values	
		U.S. Customary Units	SI Units
ASTM D638 [Note (1)]	Tensile:		
	(a) ultimate strength	≥9,500 psi	≥65.5 MPa
	(b) elongation at break	≥30.0%	≥30.0%
ASTM D695 [Note (1)]	(c) modulus of elasticity	≥350,000 psi	≥2 415.0 MPa
	Compressive:		
	(a) yield strength	≥6,000 psi	≥41.4 MPa
ASTM D695 [Note (1)]	(b) modulus of elasticity	≥250,000 psi	≥1 725.0 MPa
	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C) for 24 hr	<1.4%	<1.4%
ASME PVHO-1 method, para. 2-3.7(c)	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C) for 24 hr	<1.4%	<1.4%
ASTM D732 [Note (1)]	Shear, ultimate strength	≥4,300 psi	≥29.7 MPa

GENERAL NOTE: Test coupons shall be taken from each casting that serves as machining stock for inserts and shall be tested to verify that the physical properties of the material meet the requirements in this table.

NOTE: (1) These tests require testing a minimum of two specimens. Where applicable, use the sampling procedures described in para. 2-3.7. Where two specimens are required in the test procedure, the average of the test values shall be used to meet the requirements of the minimum physical properties of this table.

(23)

Figure 2-2.13.15-1
Dimensional Tolerances for Inserts in Acrylic Windows



ASME PVHO-1 2023

Click to view the full PDF of ASME PVHO-1 2023

Figure 2-2.13.16-1
Typical Shapes of Inserts

(23)







Figure 2-2.13.22-1
Seal Configurations for Inserts in Acrylic Windows



Legend:

M_o = outside diameter of penetrations

Figure 2-2.13.24-1
Restraints for Inserts in Acrylic Windows



(23)

Table 2-3.4-1
Specified Values of Physical Properties for Each Lot

Test Procedures	Physical Property	Specified Values	
		U.S. Customary Units	SI Units
ASTM D256 [Note (1)]	Izod notched impact strength	≥0.25 ft-lb/in.-min	≥13.3 J/m
ASTM D542	Refractive index	1.49 + 0.01	1.49 + 0.01
ASTM D570 [Note (1)]	Water absorption, 24 hr	≤0.25%	≤0.25%
ASME PVHO-1 method, para. 2-3.7(c)	Compressive deformation at 4,000 psi (27.6 MPa), 122°F (50°C), 24 hr	≤1.0%	≤1.0%
ASTM D638 [Note (1)]	Tensile:		
	(a) ultimate strength	≥9,000 psi	≥62 MPa
	(b) elongation at break	≥2%	≥2%
	(c) modulus	≥400,000 psi	≥2760 MPa
ASTM D695 [Note (1)]	Compressive:		
	(a) yield strength	≥15,000 psi	≥103 MPa
	(b) modulus of elasticity	≥400,000 psi	≥2760 MPa
ASTM D732 [Note (1)]	Shear, ultimate strength	≥8,000 psi	≥55 MPa
ASTM D785 [Note (1)]	Rockwell hardness	≥M scale 90	≥M scale 90
ASTM D790 [Note (1)]	Flexural ultimate strength	≥14,000 psi	≥97 MPa
ASTM D792 [Note (1)]	Specific gravity	1.19 ± 0.01	1.19 ± 0.01
ASME PVHO-1 method, para. 2-3.7(d)	Ultraviolet (290 nm–330 nm) light transmittance	≤5%	≤5%
ASME PVHO-1 method, para. 2-3.7(e)	Clarity, visually rated	Must have readability	Must have readability
ASME PVHO-1 method, para. 2-3.7(g)	Coefficient of linear thermal expansion at	≤10 ⁻⁵ (in./in. °F)	
		≤10 ⁻⁵ (mm/mm °C)	
	°F	°C	
	–40	–40	2.9
	–20	–29	3.0
	0	–18	3.2
	20	–7	3.4
	40	4	3.7
	60	16	4.0
	80	27	4.3
	100	38	4.7
	120	49	5.1
	140	60	5.4
ASTM D648	Deflection temperature of plastics under flexure at 264 psi (1.8 MPa)	≥185°F	≥85°C
ASME PVHO-1 method, para. 2-3.8	Total residual monomer:		
	(a) methyl methacrylate	≤1.6%	≤1.6%
	(b) ethyl acrylate		

GENERAL NOTE: The manufacturer shall certify that the typical physical properties of the acrylic satisfy the criteria in this table.

NOTE: (1) These tests require testing a minimum of two specimens. For others, test a minimum of one specimen. Where applicable, use the sampling procedures described in para. 2-3.7. For other tests, use the sampling procedures described in the appropriate ASTM test methods. Where two specimens are required in the test procedure, the average of the test values shall be used to meet the requirements of the minimum physical properties of this table.

PVHO-1 Form VP-3 Material Manufacturer's Certification for Acrylic

The _____ in. (cm) × _____ in. (cm) acrylic sheet/custom castings of _____ in. (cm)
 nominal thickness in Lot No. _____ have been produced by _____
 under the trademark of _____

These castings possess typical physical properties satisfying the minimum values specified in Safety Standard for Pressure Vessels for Human Occupancy, Section 2, Table 2-3.4-1, in accordance with the material manufacturer's Quality Assurance Manual Edition _____, Rev. _____, dated _____.

 (authorized representative of manufacturer of plastic)

 (date)

 (name and address of manufacturer of plastic)

GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

Table 2-3.4-2
Specified Values of Physical Properties for Each Casting

Test Procedures	Physical Property	Specified Values	
		U.S. Customary Units	SI Units
ASTM D638 [Note (1)]	Tensile:		
	(a) ultimate strength	≥9,000 psi	≥62 MPa
	(b) elongation at break	≥2%	≥2%
	(c) modulus of elasticity	≥400,000 psi	≥2760 MPa
ASTM D695 [Note (1)]	Compressive:		
	(a) yield strength	≥15,000 psi	≥103 MPa
	(b) modulus of elasticity	≥400,000 psi	≥2760 MPa
ASTM D790 [Note (1)]	Flexural ultimate strength	≥14,000 psi	≥97 MPa
ASME PVHO-1 method, para 2-3.7(c)	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C) for 24 hr	≤1.0%	≤1.0%
ASME PVHO-1 method, para 2-3.7(d)	Ultraviolet transmittance [for 0.5 in. (12.5 mm) thickness]	≤5%	≤5%
ASME PVHO-1 method, para. 2-3.7(e)	Visual clarity	Must pass readability test	Must pass readability test
ASME PVHO-1 method, para. 2-3.8	Total residual monomer:		
	(a) methyl methacrylate	≤1.6%	≤1.6%
	(b) ethyl acrylate		

GENERAL NOTE: To be verified by testing of specimen from each casting or lot as defined in para. 2-3.5.

NOTE: (1) These tests require testing a minimum of two specimens. For others, test a minimum of one specimen. Where applicable, use the sampling procedures described in para. 2-3.7. Where two specimens are required in the test procedure, the average of the test values shall be used to meet the requirements of the minimum physical properties of this table.

PVHO-1 Form VP-4 Material Testing Certification for Acrylic

1. Test specimens have been ☐ cut from casting or ☐ supplied already cut by _____
2. Test specimen taken from ☐ acrylic sheet or ☐ custom castings no. _____ in Lot no. _____ of _____ in. (cm)
nominal thickness that have been produced by _____ under the
(material manufacturer)
trademark of _____ possess the following physical and chemical properties:

Test Method	Property	Results
ASME PVHO-1, para. 2-3.7(c)	Compressive deformation at 4,000 psi (27.6 MPa) and 122°F (50°C)	_____
ASTM D638	Tensile: (a) ultimate strength (b) elongation at break (c) modulus of elasticity	_____ _____ _____
ASTM D695	Compressive: (a) yield strength (b) modulus of elasticity	_____ _____
ASME PVHO-1, para. 2-3.7(d)	Ultraviolet transmittance [for 1/2 in. (12.5 mm) thickness]	_____
ASME PVHO-1, para. 2-3.7(e)	Visual clarity	_____
ASME PVHO-1, para. 2-3.8	Total residual methyl methacrylate and ethyl acrylate monomers	_____% _____%

The experimentally proven properties satisfy the minimum values specified in Table 2-3.4-2 of the Safety Standard for Pressure Vessels for Human Occupancy.

(authorized representative of material testing laboratory)

(date)

(name and address of material testing laboratory)

GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

Table 2-4.5-1
Annealing Schedule for Acrylic Windows

Part A: Minimum Heating Times of Elevated Temperature Annealing of Acrylic					
Heat Time [Note (1)], hr (h), for Acrylic Placed in a Forced-Air Circulation Oven Maintained at a Set Temperature Within ±5°F (±2.8°C)					
Thickness, in. (mm)	230°F (110°C), Max.	212°F (100°C), Min.	195°F (90°C), Min.	185°F (85°C), Min.	
0.50 (12.70)	3.5	4.0	6.0	11.0	
0.75 (19.05)	4.4	4.9	6.9	11.8	
1.00 (25.40)	5.3	5.9	7.7	12.6	
1.25 (31.75)	6.2	6.8	8.6	13.4	
1.50 (38.10)	7.1	7.7	9.4	14.1	
1.75 (44.45)	8.0	8.6	10.3	14.9	
2.00 (50.80)	8.9	9.6	11.1	15.7	
2.25 (57.15)	9.8	10.5	12.0	16.5	
2.50 (63.50)	10.6	11.4	12.9	17.3	
2.75 (69.85)	11.5	12.4	13.7	18.1	
3.00 (76.20)	12.4	13.3	14.6	18.9	
3.25 (82.55)	13.3	14.2	15.4	19.6	
3.50 (88.90)	14.2	15.1	16.3	20.4	
3.75 (95.25)	15.1	16.1	17.1	21.2	
4.00 (101.60)	16.0	17.0	18.0	22.0	
>4.00 (>101.60)	4	6	6	6	
				(per in. of additional thickness over 4)	
Part B: Maximum Cooling Rates for Acrylic Subjected to Elevated Annealing Temperatures					
Time, hr (h), to Cool Acrylic From the Indicated Annealing Temperature at the Maximum Permissible Rate to the Maximum Allowable Removal Temperature of 120°F (49°C)					
Thickness, in. (mm)	Maximum Cooling Rate, °F/hr (°C/h)	230°F (110°C)	212°F (100°C)	195°F (90°C)	185°F (85°C)
0.500 to 0.750, incl. (13 to 19, incl.)	25 (14)	4.5	3.5	3	2.5
0.875 to 1.125, incl. (22 to 28, incl.)	18 (10)	6	5	4	4
1.250 to 1.500, incl. (32 to 38, incl.)	13 (7.2)	8.5	7	6	5
1.750 (44)	11 (6.1)	10	8.5	7	6
2.000 (50)	10 (5.5)	11	9	7.5	6.5
2.250 (57)	9 (5)	12.5	10	8.5	7.5
2.500 (64)	8 (4.5)	14	11.5	9.5	8.5
3.000 (75)	7 (4)	16	13	11	9.5
3.250 (82)	6 (3.5)	18.5	15	12.5	11
3.500 (89)	6 (3.5)	18.5	15	12.5	11
3.750 (92)	6 (3.5)	18.5	15	12.5	11
4.000 (100)	5 (3)	22	18	15	13
4.000 to 6.000, incl. (100 to 150, incl.)	4 (2)	27.5	23	19	16.5
6.000 to 8.000, incl. (150 to 200, incl.)	3 (1.5)	37	30.5	25	22
8.000 to 10.000, incl. (200 to 250, incl.)	2 (1)	55	45.5	37.5	32.5
10.000 to 12.000, incl. (250 to 300, incl.)	1 (0.5)	110	91	75	65

NOTE: (1) Includes period of time required to bring part up to annealing temperature, but not cooling time.

PVHO-1 Form VP-5 Pressure Testing Certification

Window Identification _____

Window Description

Maximum allowable working pressure _____

Maximum design temperature _____

Test Arrangement

Windows tested in operational viewport/simulated viewport _____
(operational/simulated)

Operational/simulated viewport drawing no. _____

Window tested according to subsection 2-7 _____
(yes/no)

Test pressure _____ psi _____ MPa

Overpressure ratio (test pressure/maximum allowable working pressure) _____

Pressurizing medium temperature _____ °F _____ °C

Rate of pressurization (average) _____

Duration of sustained pressurization _____

Test Observations (yes/no)

Leakage _____

Permanent deformation _____

Crazing _____

Cracking _____

The acrylic window was pressure tested according to the procedure of subsection 2-7 of the Safety Standard for Pressure Vessels for Human Occupancy and was found to perform satisfactorily without any visible permanent deformation, crazing, or cracking.

(pressure test supervisor) _____ (date)

(name and address of pressure testing laboratory)

[authorized representative of chamber manufacturer (windows for new chamber) or user (windows for replacement in an existing chamber)] _____ (date)

GENERAL NOTE: This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

PVHO-1 Form VP-6 Acrylic Window Repair Certification

Window Identification

1. Window Shape (From Visual Inspection)

Conical frustum _____ Double beveled _____
 Spherical sector with conical edge _____ Spherical sector with square edge _____
 Hemisphere with equatorial flange _____ Flat disk _____
 Hyperhemisphere with conical edge _____ NEMO _____
 Cylinder _____

2. Design Data (From PVHO-1 Form VP-2)

Original design certification prepared by _____
 Maximum allowable working pressure _____ Maximum design temperature _____
 Minimum thickness (calculated t) for above temperature and pressure _____

3. Original Fabrication Date (From PVHO-1 Form VP-1)

Original fabrication certification prepared by _____ (name of preparer)
 _____ (name of fabricator)
 Fabricated according to drawing _____ Identification marking _____
 Actual minimum thickness, t _____ Actual inside diameter, D_i _____
 Actual outside diameter, D_o _____

4. Repair Instructions (Refinish the following surfaces)

High-pressure face _____ Low-pressure face _____ Bearing surfaces _____
 Beveled edges _____ Sealing surfaces _____
 Spot casting meeting requirements of paras. 2-3.10 and 2-9.8 is
 authorized where appropriate _____
 The minimum thickness, t , of the repaired window is to meet or exceed _____
 The inside diameter, D_i , of the repaired window is to meet or exceed _____
 Repair of window has been authorized by _____ (name of company)
 _____ (name of authorized representative) _____ (signature of authorized representative)

5. Repair History (The following surfaces were refinished)

High-pressure face _____ Low-pressure face _____
 Bearing surfaces _____ Beveled edges _____
 Spot Casting Process
 Resin used _____ Catalyst used _____
 Polymerization technique _____
 Tensile strength of bond with acrylic per para. 2-3.10(a) _____
 Sketch of spot casting locations attached _____ (yes) _____ (no)
 Minimum thickness of repaired window _____
 The minimum thickness of repaired window meets or exceeds
 minimum calculated thickness of paras. 2-2.2 through 2-2.5 _____ (yes) _____ (no)
 The repaired window was annealed at _____ for _____ hr
 During fabrication, the original window identification markings were Left intact _____ Removed and reapplied _____
 The repair marking applied to the window reads as follows: _____

The refinished surfaces, spot castings, and minimum thickness of the repaired window meet all the requirements of
 Section 2 and the attached Design Certification PVHO-1 Form VP-2.

 (authorized representative of window fabricator)

 (name and address of window fabricator)

GENERAL NOTES:

- (a) The data for parts 1 through 4 of this form shall be provided and certified by the company/individual authorizing the repair of windows.
 (b) The repair process information required by part 5 shall be provided and certified by the window fabricator performing the repair.
 (c) This form may be reproduced and used without written permission from ASME if used for purposes other than republication.

(23) **Table 2-11.5.2-1**
ALTPP Test Options

Number of Prototypes Tested	Test Pressure at 300 hr [Note (1)]
1	$5.46 \times$ design pressure
3	$4.87 \times$ design pressure
5	$3.64 \times$ design pressure

NOTE: (1) Lower test pressures may be used at longer test durations.
See [Figure 2-11.5.2-1](#).

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

Section 3

Quality Assurance for PVHO Manufacturers

3-1 GENERAL

This Section specifies the requirements for establishing and maintaining a Quality Assurance Program for PVHO manufacturers and window fabricators in accordance with the applicable edition of this Standard.

3-1.1 Scope

The responsibilities set forth herein relate only to compliance with this Standard.

3-1.2 Quality Assurance System Verification

This Section applies only to the structure and content of a Quality Assurance Program.

3-2 RESPONSIBILITIES

3-2.1 Compliance With This Standard

The PVHO manufacturer and window fabricator are responsible for implementing and maintaining the quality requirements as described in ISO 9001 or ISO 13485, whichever is applicable. It is not, however, the intent of this Standard to require a PVHO manufacturer's or window fabricator's Quality Assurance Program to be certified in accordance with ISO 9001 or ISO 13485 requirements by a third party, and nothing in this Standard should be construed to imply such a requirement.

3-2.2 Documentation of the Quality Assurance Program

The PVHO manufacturer and window fabricator shall be responsible for documenting the Quality Assurance Program in accordance with this Section.

3-2.3 Certification

The PVHO manufacturer and window fabricator shall certify compliance with this Standard by furnishing the purchaser with the appropriate PVHO-1 forms and by marking in accordance with the requirements of this Standard.

3-2.4 Right of Access

The purchaser or their authorized representative, authorized inspection agency representatives, and regulatory agency representatives shall be granted reasonable access to PVHO manufacturer and window fabricator's facilities for the purpose of conducting inspection or qualification activities.

3-2.5 Records

Records required for traceability shall be retained by the PVHO manufacturer and window fabricator in accordance with [para. 1-7.9](#).

Section 4

Piping Systems

4-1 GENERAL

4-1.1 Scope

PVHO piping systems are subject to the requirements of this Section and any additional requirements specified in the User's Design Specification in accordance with subsection 1-4.

Piping systems constructed under the requirements contained in this Section are limited to design temperatures between 0°F and 150°F (–17.8°C and 65°C), inclusive.

This Section shall be used as an adjunctive document to ASME B31.1 or ASME B31.3. The user or an agent on behalf of the user shall specify the appropriate section of ASME B31 to be used by the designer.

Specific piping within the PVHO piping system may also be subject to other codes or standards, such as ASME B31.9, NFPA 99 for health care facilities, and building codes.

This Section provides guidance and engineering requirements deemed necessary to the safe design and construction of a PVHO piping system. This Section is not all inclusive and does not relieve the designer of the responsibility to use competent engineering judgment.

4-1.2 Design and Fabrication

4-1.2.1 User's Design Specification. The user, or an agent on behalf of the user, who intends that a piping system be designed, fabricated, tested, and certified to be in compliance with this Section, shall provide, or cause to be provided, a written User's Design Specification. The User's Design Specification shall set forth requirements as to the intended use and operating conditions in such detail as to constitute an adequate basis for designing, fabricating, and inspecting the system as required to comply with this Section. Those requirements shall include, as a minimum, the following:

- (a) limitations and boundaries of the piping systems
- (b) piping system maximum operating pressures, required pressurization and depressurization rates, ventilation rates, and the conditions under which those rates are to be maintainable [see paras. 4-9.7.1(a) and 4-9.7.1(b)]
- (c) conditions affecting the requirements for and amounts of stored gas reserves

(d) required number of breathing gas connections and their characteristics

(e) data that shall be provided to the owner and the duration of retention of that data by the fabricator if other than that required by para. 4-1.2.3, and the disposition of the data should the fabricator go out of business

4-1.2.2 Design Certification. Conformance of the piping system design to the requirements of this Section and the User's Design Specification shall be established by one of the following procedures:

(a) *Professional Engineer Certification.* A Professional Engineer, registered in one or more of the U.S. states or the provinces of Canada, or the equivalent in other countries, experienced in piping systems design, shall certify that the piping system was designed by them or under their direct supervision, or that they have thoroughly reviewed a design prepared by others, and that to the best of their knowledge, within the User's Design Specification, the piping system design complies with this Section.

(b) *Independent Third-Party Certification.* The piping system design shall be reviewed by an independent classification society competent in pressure vessels for human occupancy systems, and such organization shall provide a certification that, within the User's Design Specification, the piping system design complies with this Section.

(c) *Fabricator's Certification.* The fabricator of the piping system shall be responsible for complying with the requirements of this Section. The fabricator shall provide written certification of compliance with this Section and with the User's Design Specification.

4-1.2.3 Data Retention. The fabricator shall retain a copy of the User's Design Specification, the Design Certification, the Fabricator's Certification, and supporting data (test data, material test reports, as required by the User's Design Specification) for at least 5 yr. A copy of the piping system User's Design Specification, the Design Certification, and the Fabricator's Certification shall be provided to the user with the system.

4-2 MATERIAL REQUIREMENTS

4-2.1 Acceptable Materials

4-2.1.1 Pipe and Tube. Pipe and tube for use in PVHO piping systems, except as otherwise restricted or permitted, shall be of a material for which allowable stress values are listed in Nonmandatory Appendix A of ASME B31.1, Nonmandatory Appendices A and B of ASME B31.3, or [Table 4-2.1.1-1](#).

4-2.1.2 Fittings. Unless otherwise restricted or permitted, the following apply:

(a) Fittings that are attached to a pipe or tube by welding, brazing, or threading shall conform to the specifications and standards listed in Table 126.1 of ASME B31.1 and Table 326.1 of ASME B31.3.

(b) Fittings that are attached to a pipe or tube by other methods shall be of a material and type recommended by the fitting manufacturer for the application.

4-2.2 Limitations on Materials

4-2.2.1 Service Requirements. It is the responsibility of the designer to select materials suitable for the conditions of operation. All metallic materials used for oxygen service, breathing gas service, fire suppression, and water or steam service and all components subject to the requirements of [para. 4-9.3](#) shall not use plating or coating with cadmium and shall not be manufactured from the following materials:

- (a) carbon steel
- (b) iron

Components of beryllium or those containing mercury shall not be used. Components containing asbestos shall not be used for breathing gas service applications.

4-2.2.2 Carbon Steel. The use of carbon steel pipe, tube, valves, and fittings in PVHO systems not subject to the requirements of [para. 4-2.2.1](#) is permitted, provided that they are compatible with anticipated cleaning and operational procedures and are adequately protected against corrosion, both internally and externally.

The effects of the migration of rust and other corrosion products into downstream components such as valves and regulators shall be considered.

4-2.2.3 Aluminum. Aluminum may be used only when adequate precautions are taken to prevent contact with fluorochlorocarbon lubricants and hydroxide-based absorbents. Further, the corrosive effect of seawater and combinations of hydroxide chemicals and seawater shall be considered in alloys intended for use in marine systems.

4-2.2.4 Castings. Cast components are subject to possible porosity and should be avoided in helium service. Cast, ductile, and malleable iron pipe, tube, and fittings shall not be used. Cast components of

other materials may be used if not otherwise prohibited by this Standard.

4-2.2.5 Seawater Service. Materials that will be repeatedly or continuously exposed to seawater shall be compatible with seawater service.

4-2.2.6 Oxygen Service. Materials that will be exposed to oxygen and oxygen lubricants shall be compatible with the combination of oxygen, lubrication, and flowing conditions to which they are exposed. For guidance in the selection of materials suitable for oxygen service, refer to CGA G4.4 and ASTM G88.

4-2.3 Lubricants and Sealants

Lubricants and sealants are necessary in breathing gas systems for lubricating O-rings, lubricating moving parts of pressure control valves, and lubricating and sealing pipe thread joints; however, due to the possible presence of oxygen-enriched gases and the ultimate use of the gas for respiratory purposes, lubricants and sealants shall be selected with care.

(a) Lubricants and sealants used in breathing gas and oxygen systems shall be of a type recommended by the manufacturer for the intended service.

(b) Fluorochlorocarbon-based lubricants shall not be used on aluminum.

4-2.4 Nonmetallic Materials

4-2.4.1 Hose Materials and Pressure Ratings

(a) *Maximum Allowable Working Pressure (MAWP).* All hoses used in PVHO piping systems shall have a MAWP equal to or greater than the design pressure of the line in which they are used, or a suitable relief valve set at the MAWP of the hose shall be provided.

(b) *Burst Pressure.* The burst pressure rating of any hose shall be at least 4 times its rated MAWP. The effect of fittings on the burst pressure shall be considered in establishing MAWP.

(c) *Liners.* The liners for hoses shall be appropriate for the intended service. Liners for use with breathing gases containing helium should also be relatively impervious to helium. Nylon, polytetrafluoroethylene (PTFE), and many natural and synthetic rubbers will normally satisfy these requirements.

(1) Liner materials are acceptable for breathing gas service if they will pass the off-gassing test contained in [para. 4-9.14](#) or they are rated by the manufacturer for breathing gas service. PTFE, nylon, and flexible metal liners meeting the requirements of [para. 4-2.2](#) and that have been cleaned for breathing gas service are acceptable for breathing gas and oxygen service without an off-gassing test.

(2) Hoses to be used for oxygen service shall use liner materials that are suitable for use with gaseous oxygen at the design pressure of the system or that are rated for such service by the manufacturer.

(3) Liner material shall be compatible with cleaning materials used to clean the hose assembly to the same level of cleanliness as the system of which it is a component.

(d) *Reinforcement Layer.* Reinforcement layer materials shall be compatible with the intended service.

(e) *Outer Jacket.* Jacket materials shall be compatible with the intended service. The outer jacket on hoses intended for helium service shall be perforated or sufficiently permeable to allow escape of gas that may seep through the inner liner. For other gas service applications, the designer should consider the possible needs for outer jacket perforation.

(f) *Fittings.* Fitting material shall be suitable for the intended service, and fitting materials shall comply with para. 4-2.2. Fittings used on life-critical breathing devices shall be of types that are resistant to inadvertent disengagement.

4-2.4.2 Installation

(a) All permanently installed hoses shall be installed such that they are not subject to bending at radii less than the manufacturer's minimum rated bend radii and in accordance with all other applicable manufacturer's recommendations.

(b) Permanently installed hoses used to compensate for expansion and contraction shall be installed in accordance with manufacturer's recommendations. Where possible, hoses should be installed to always be in single-plane bending and free of torsional or axial loading.

(c) Hoses installed in locations subject to abnormal levels of cyclic vibration shall be sized and selected for this type of service.

4-2.4.3 Marking. Hoses shall be marked with the manufacturer's name or trademark, type or catalog number, MAWP, test pressure, and test date. This information shall be permanently printed either on the hose or on a permanently attached corrosion-resistant metal tag. Metal tags, when used, shall be affixed so as not to abrade the hose or prevent the hose from normal bending or expansion due to pressure.

4-2.4.4 Hoses Subject to External Pressure. The following are required for hoses subject to external pressure:

(a) The hose construction shall be of a type that is resistant to collapse.

(b) The liner, if present, shall be securely bonded to the reinforcing layer.

(c) Fittings shall be of a type that forms a seal at the end of the hose. Fittings that leave the cut end of the hose open to pressure shall not be used.

(d) Hoses shall be installed in a manner that minimizes minor kinks, crushes, etc., which may not harm the internal working pressure capability of the hose but may cause it to collapse when subject to external pressure.

(e) Tight radius bends and torsional loads shall be avoided.

4-2.4.5 Testing

(a) Hoses that are received made up from the hose manufacturer and that were tested by the manufacturer in a manner substantially equivalent to the procedure described in para. 4-9.14 need not be retested.

(b) Locally assembled hose assemblies shall be tested as prescribed in para. 4-9.14 before being placed in service. Hose assemblies may be tested individually or as a portion of the system of which they form a part.

(c) Locally assembled hose material intended for external pressure service shall be tested as follows:

A representative section of hose shall be made up with fittings of the type intended for use with the hose using normally expected attachment procedures. The section of hose shall be bent 180 deg at a bend radius equal to the minimum bend radius expected in service. The hose shall be exposed to an external pressure 1.5 times its maximum system external pressure for 1 hr. Air is an acceptable pressurizing medium. The hose shall exhibit no evidence of collapse, either of the casing (outer jacket and reinforcing layer) and liner together, or of the liner separately. Hose collapse may be determined by observing the pressure drop at a specific flow rate of a fluid flowing through the hose. The pressure drop will increase significantly when collapse occurs. Note that liner collapse may occur with no visible deformation occurring in the casing. Hose collapse may also be determined by filling the hose with water and measuring the amount of water displaced as the hose is pressurized.

4-2.4.6 Nonmetallic Pipe and Tube and Bonding

Agents. Design properties of these materials vary greatly and depend on the materials, type, grade, and lot. For new nonmetallic piping assemblies, particular consideration shall be given to the possibility of

(a) destruction by fire

(b) decrease in tensile strength at elevated temperature

(c) toxic off-gassing, in-service, and fire condition

(d) adequate support for flexible pipe

(e) breathing gas compatibility

4-3 DESIGN OF COMPONENTS

4-3.1 Straight Piping Under External Pressure

For determining wall thickness and stiffening requirements for straight pipe and tubing under external pressure, the requirements of ASME BPVC, Section VIII, Division 1 or Division 2 shall be followed.

4-3.2 Straight Piping Under Internal Pressure

4-3.2.1 Minimum Wall Thickness. The thickness of pipe or tubing shall not be less than as required in ASME B31.1, para. 104.1, or as specified in ASME B31.3, para. 304.1.

4-3.2.2 Additional Thickness Requirements. The thickness determined from the formulas in ASME B31.1, para. 104.1, and ASME B31.3, para. 304.1 are theoretically ample for both bursting pressure and material removed in threading. The following requirements are mandatory to furnish additional mechanical strength:

(a) Threaded steel or stainless steel pipe for use at pressures over 500 psig shall have a minimum ultimate tensile strength of 48,000 psi (330 MPa) and a wall thickness at least equal to Schedule 80 of ASME B36.10M. For pressures of 500 psi and less, threaded pipe shall have a wall thickness at least equal to Schedule 40 of ASME B36.10M.

(b) Threaded brass or copper pipe used for the services described above shall have a wall thickness at least equal to that specified above for steel pipe.

(c) Pipe or tubing subject to bending shall comply with the wall thickness requirements of ASME B31.1, Table 102.4.5, or ASME B31.3, para. 332.

4-3.3 Bending of Pipe and Tube

Pipe and tube bent or formed for a PVHO piping system shall be bent or formed as described in ASME B31.1, para. 102, or ASME B31.3, para. 332.

(a) Bending of pipe and tube in a PVHO piping system shall be performed in accordance with a written bending procedure.

(b) Pipe and tube may be bent by any hot or cold method and to any radius that will result in a bend surface free of cracks and buckles.

4-3.4 Stress Analysis of Piping Components

It shall be the responsibility of the designer to determine that the piping is adequately supported and that the piping system is sufficiently flexible to accommodate the relative movements and changes in temperature.

Should the designer determine that a stress analysis is required, it shall be performed in accordance with the requirements of ASME B31.1, para. 104.8, or ASME B31.3, para. 319.

4-3.5 Pressure Design of Fabricated Joints and Intersections

(a) Except as permitted in (b), where joints are fabricated and the service does not exceed 5 psig, ASME B31.1, para. 104.3 or ASME B31.3, para. 304.3 shall be followed.

(b) Fabricated branch joints made by brazing a branch line into an extruded opening in the run line may be used, provided that

(1) The line MAWP is 175 psig or less.

(2) The joint meets the reinforcement requirements of ASME B31.1, para. 104.3.1(g).

4-3.6 Pressure Design of Bolted Flanges and Blanks

The pressure design of bolted flanges and blanks shall be in accordance with ASME B31.1, para. 104.5.

Gasket and seal materials and design shall be suitable for the intended service.

4-3.7 Design of Penetrations Through the Pressure Boundaries of PVHOs

See [Nonmandatory Appendix B](#) for guidelines for the design of piping penetrations through the pressure boundaries of PVHOs.

4-4 SELECTION AND LIMITATIONS OF PIPING COMPONENTS

4-4.1 Pressure Requirements

4-4.1.1 Maximum Allowable Working Pressure. The MAWP of all components shall be equal to or greater than the maximum operating pressure of the system or line of which they form a part.

4-4.1.2 Differential Pressures. Where components may be subject to differential system pressures, the differential pressure capacity of the component shall be equal to, or greater than, the maximum possible differential pressure; otherwise, suitable overpressure protection shall be provided.

4-4.1.3 Alternating Internal and External Pressures. Components subject to alternating (i.e., both internal and external) pressure shall be designed for the maximum differential pressure that may exist in either direction.

4-4.1.4 Pressure Ratings. When possible, all pipe and tubing of the same material and diameter used in a single PVHO piping system shall have the same pressure rating. When this is not possible, special precautions shall be taken to prevent inadvertent mixing of materials.

4-4.2 Valves

The designer shall select valves suitable for the intended service.

4-4.2.1 Valves Subject to Internal and External Pressures. Valves subject to both internal and external pressures shall employ seals and stem packing suitable for bidirectional service.

4-4.2.2 Stop Valves. Stop valves shall be selected and installed to close with a clockwise rotation of the valve handle.

4-4.2.3 Ball Valves. Ball valves shall employ blowout-proof stem designs.

4-4.2.4 Service Access. Valves in breathing gas and other life-sensitive systems shall be selected and installed to provide access for maintenance.

4-4.2.5 Quick-Opening Valves. Quick-opening valves shall not be used in oxygen systems with a MAWP over 125 psig. Quick-closing valves (e.g., an excess flow check valve) may be used regardless of pressure, provided that their capacity is sufficiently less than the capacity of upstream components so that closure of the valve will not result in a pressure rise at the inlet to the valve large enough to cause hazardous adiabatic compression heating of the gas.

4-4.2.6 Remotely Operated Valves. Remotely operated valves shall be selected and installed so that they fail in the safe position. Valves in services that cannot tolerate interruptions shall be provided with a manual override or bypass.

4-4.2.7 Relief Valves. Where tamper-proof design is required, relief valves used for protection against overpressures in excess of system service pressures shall be "V" stamped valves manufactured in accordance with ASME BPVC, Section VIII.

4-4.3 Filters

4-4.3.1 Element Collapse Pressure Rating. Elements of filters used in breathing gas and other life-sensitive systems shall have a collapse pressure rating equal to or greater than the design pressure of the line in which they are installed, or the filter shall be fitted with a differential pressure device indicating when the element needs renewal or cleaning.

4-4.3.2 Element Construction. All particulate filters in pressurized lines in breathing gas and other life-sensitive systems shall use elements of the woven wire, screen, or sintered metal types. Sintered metal elements should be avoided in high-flow, high-vibration, or other applications conducive to element deterioration. Cloth and paper elements shall not be used.

4-4.3.3 Bypass Requirements. In systems where the ability to maintain uninterrupted service is required, all particulate filters shall be installed so that a clogged filter can be bypassed without disrupting the fluid flow to the end-use point.

4-4.4 Mufflers

Mufflers used for oxygen service (including vent lines from oxygen service systems) shall be fabricated of materials that are compatible with oxygen.

4-5 SELECTION AND LIMITATIONS OF PIPING JOINTS

4-5.1 Welded Joints

Welded joints in PVHO piping systems shall be constructed in accordance with the requirements of paras. 127, 131, and 132 of ASME B31.1 or paras. 328, 330, and 331 of ASME B31.3.

Welded joints of NPS (nominal pipe size) 2½ (DN 65) pipe size or smaller may be socket welded or butt welded. Welded joints larger than NPS 2½ (DN 65) pipe size shall be butt welded.

4-5.2 Brazed Joints

Brazing shall be performed in accordance with ASME B31.3, para. 333.

The Brazing Procedure Specification and the Procedure Qualification Record shall meet the requirements of ASME BPVC, Section IX or AWS B2.2.

Fabricator certification of the brazing procedure, procedure qualification, and brazer qualification is required.

4-5.3 Mechanical Joints

4-5.3.1 Seal Selection. Mechanical joint designs employing seals where effective sealing is not dependent on bolt preloading are recommended.

4-5.4 Threaded Joints

4-5.4.1 Pressure Limitations

(a) Fittings shall have a pressure rating equal to or greater than the MAWP of the system in which they are used.

(b) Size-pressure limits for pipe threaded joints shall be as follows:

Size NPS, in.	Pressure
>3	Not permitted
2½-3	400 psig
2	600 psig
1¼-1½	800 psig
1	1,500 psig
≤¾	MAWP of the fittings or pipe, whichever is less

(c) Straight-thread O-ring-sealed fittings may be used without limitation on size.

4-5.4.2 Helium Service. For helium service, pipe threads should be avoided; straight-thread O-ring-sealed fittings are recommended over pipe thread fittings for helium service.

4-5.4.3 Lubricants. Any compound or lubricant used in threaded joints shall be suitable for the service conditions and shall not react unfavorably with either the service fluid or the piping materials.

4-5.4.4 Seal Welding. Threaded joints that are to be seal welded shall be made up without any thread compound, and the weld shall provide complete (360 deg) coverage. Seal welding shall be done by using qualified welders in accordance with ASME BPVC, Section IX per ASME B31.1, para. 127.5, or ASME B31.3, para. 328.2. Seal welds shall not be considered as contributing to the mechanical strength of a joint.

4-5.4.5 Stainless Steel Threads. To reduce the possibility of galling where pipe threads are to be used between stainless steel components, there shall be a hardness difference between the thread surfaces of the two components of at least 5 points on the Rockwell B scale, or some other method of galling prevention shall be used.

4-5.4.6 Straight Threads. When straight-thread O-ring-sealed fittings are used in locations that may subject the fitting to vibration or a torque that would tend to unscrew it, provision shall be made to prevent inadvertent loosening of the fitting.

4-5.4.7 Aluminum Threads. A suitable thread compound shall be used in making up threaded joints in aluminum fittings to prevent seizing. Aluminum pipe should not be threaded.

4-5.5 Joints and Fittings in Tubes

Factors such as vibration loads and frequent disassembly and reassembly of the piping system shall be considered in the selection of the type of tube fittings to be used.

4-5.5.1 Fittings Subject to Frequent Disassembly. The designer shall give special consideration to the selection of fittings in locations where frequent disassembly and reassembly is likely. For these locations, one of the following fitting types shall be used:

- (a) flare fittings
- (b) welded or brazed fittings employing a flat-face seal mechanical union integral to the fitting
- (c) O-ring-sealed, straight-thread fittings

4-5.5.2 Limitations. Compression-type fittings of aluminum shall not be reused. Bite-type fittings shall not be used on metallic pipe in PVHO piping systems. Welded fittings may be used subject to the requirements of para. 4-5.1. Brazed fittings may be used subject to the requirements of para. 4-5.2.

4-5.5.3 Restrictions. Fittings and their joints shall be compatible with the tubes with which they are to be used. They shall conform to the range of wall thickness and method of assembly recommended by the manufacturer,

except that brass fittings may be used on stainless steel or nickel-copper tube under the following restrictions:

(a) *Flared Tube.* The tube shall be flared using a suitable flaring tool for the tube material, and a crushable metal gasket shall be used between the tube and the body of the fitting.

(b) *Compression Fittings.* The nuts and ferrules used shall be of the same material type (e.g., stainless steel or nickel-copper) as the tube, and the tube end shall be pre-swaged using a swaging tool or a suitable temporary fitting.

4-5.5.4 Cutting of Tube. All tube that is to be used with flare tube fittings shall be saw cut.

4-6 SUPPORTS

It shall be the responsibility of the designer to determine the support requirements of the piping system. The suggested support spacing is found in ASME B31.1, Table 121.5, or ASME B31.3, para. 321.

Where detailed support designs and calculations are required, they shall be performed in accordance with ASME B31.1, para. 119, or ASME B31.3, para. 319, as applicable.

4-7 INSPECTION

4-7.1 Inspection of Welded Joints

All welds in PVHO piping systems that are subject to stresses due to pressure shall be inspected in accordance with the requirements of Table 4-7.1-1. The inspection procedures and acceptance standards shall be in accordance with ASME B31.1, para. 136, or ASME B31.3, para. 340. The fabricator (or agent) shall ensure that all inspection personnel are qualified to perform the required inspections.

4-7.2 Inspection of Brazed Joints

Brazed joints performed in accordance with para. 4-5.2 shall be subject to a visual inspection as a minimum. The following acceptance criteria shall apply:

(a) Preinserted alloy-type joints may be considered satisfactory when, before any face feeding, the total length of exposed brazing alloy between the outside surface of the pipe or tube and the outer end of the fitting is greater than $\frac{3}{4}$ of the circumference, with the greatest unexposed portion not exceeding 10% of the circumference.

(b) Face-fed joints shall show a complete ring of brazing alloy between the outside surface of the line and the outer end of the fitting.

4-8 TESTING

4-8.1 Hydrostatic Tests

Pressure testing of the piping systems may be carried out at either the component or system level. When component-level testing is specified in the User's Design Specification, a postassembly system leak test to operating pressure shall be performed.

Where a hydrostatic test is not possible or desirable, refer to [para. 4-8.2](#) for pneumatic test requirements.

4-8.1.1 Test Fluid. Water shall normally be used for a hydrostatic test fluid unless otherwise specified by the owner in the User's Design Specification. Test water shall be clean, oil free, and of such purity as to minimize corrosion of the material in the piping system.

4-8.1.2 Test Pressure. Piping systems shall be subjected to a hydrostatic test pressure not less than 1.5 times the MAWP of the system or subsystem. Any component requiring isolation shall be isolated.

4-8.1.3 Holding Time. The hydrostatic test pressure shall be continuously maintained for a minimum of 10 min and for such additional time as may be necessary to conduct the examinations for leakage.

4-8.1.4 Examination. Examinations for leakage shall be made of all joints and connections. The piping system, exclusive of possible localized instances at pump or valve packings, shall show no visual evidence of weeping or leaking.

4-8.1.5 Air Vents. Where a complete piping system is to be hydrostatically tested, vents shall be provided at all high points of the piping system in the position in which the test is to be conducted, to permit purging of air while the component or system is filling. As an alternative, the required venting may be provided by the loosening of flanges, tube fittings, or union joints in pipelines, or by the use of equipment vents during the filling of the system.

4-8.2 Pneumatic Tests

4-8.2.1 Limitations. Pneumatic testing shall not be used in lieu of other means of pressure testing except as limited in [para. 4-8.2.3](#), or when one or more of the following conditions exist:

- (a) when the User's Design Specification requires or permits the use of this test as an alternative
- (b) when piping systems are so designed that they cannot be filled with water
- (c) when piping systems are to be used in service where traces of the testing medium cannot be tolerated (e.g., lines to gas analyzers)

4-8.2.2 Test Medium. The gas used as the test medium shall be oil free, nonflammable, and nontoxic or as specified in the User's Design Specification. Since compressed

gas may be hazardous when used as a testing medium, it is recommended that special precautions for protection of personnel shall be observed during pneumatic testing.

4-8.2.3 Test Pressure. The pneumatic test pressure shall not be less than 1.2 nor more than 1.5 times the MAWP of the piping system. Any component requiring isolation shall be isolated.

4-8.2.4 Preliminary Test. A preliminary pneumatic test not to exceed 25 psig may be applied, prior to other methods of leak testing, as a means of locating major leaks. If used, the preliminary pneumatic test shall be performed in accordance with the requirements of [paras. 4-8.2.2](#) and [4-8.2.3](#).

4-8.2.5 Application of Pressure. The pressure in the system shall be gradually increased to not more than $\frac{1}{2}$ of the test pressure, after which the pressure shall be increased in steps of approximately $\frac{1}{10}$ of the test pressure until the required test pressure has been reached.

4-8.2.6 Holding Time. The pneumatic test pressure shall be continuously maintained for a minimum of 10 min, after which the pressure shall be reduced to system design pressure for examination for leakage.

4-8.3 Leak Testing

Using a suitable test medium, all joints and connections shall be examined for leakage by bubble testing or equivalent method at the maximum operating pressure. The piping system, exclusive of possible localized instances at valve packings, should show no evidence of leaking. For helium systems, foaming of the test medium is allowed. Detectable leaks in oxygen systems shall not be permitted at any location.

Following either pneumatic or hydrostatic testing, the piping system shall be leak tested in final assembled condition.

4-9 SYSTEMS

There are various system and component selection considerations that may affect the operational safety of a PVHO piping system. Requirements regarding specific safety and component issues are found in this subsection. These requirements are not intended to be used in totality for all PVHO piping systems but rather should be applied by the designer as applicable to the specific industry in which the PVHO will be used.

It is the owner's and/or the designer's responsibility to determine which of these requirements is applicable to the PVHO piping system being designed.

Specific [subsection 4-9](#) requirements being applied shall be enumerated in the User's Design Specification and thereby become mandatory.

4-9.1 System Design Requirements

The designer shall use the requirements in this subsection as appropriate for the specific industry PVHO piping system being designed. It is intended that only those requirements determined by the designer to be applicable be mandatory, and the designer should be thoroughly familiar with this subsection before application of these requirements. It is the designer's responsibility to determine the specific application of [subsection 4-9](#) in accordance with accepted practice, jurisdictional requirements, and safety. Those requirements deemed mandatory by the designer because of industry, service, or regulatory requirement shall be listed in the User's Design Specification.

4-9.2 Pressurization and Depressurization Systems

4-9.2.1 Pressurization and Depressurization Rates. The PVHO pressurization and depressurization systems shall be capable of providing the full range of pressurization and depressurization rates specified in the User's Design Specification. When the pressurization gas comes from a stored gas system, the pressurization rates specified in the User's Design Specification shall be maintainable at maximum PVHO pressure at all gas storage pressures over 50% of maximum.

4-9.2.2 Ventilation Rates. On all PVHOs designed for operation in a continuous ventilation mode, the pressurization and depressurization system shall be capable of maintaining all required ventilation rates while holding depth stable to within the range specified by the User's Design Specification. Such systems should also be provided with a means of indicating the rate of flow of ventilation gas through the PVHO.

4-9.2.3 Stored Gas Reserves. The requirements for stored gas reserves vary with the application for which a PVHO system shall be used. The designer shall consider all pertinent operational and jurisdictional requirements.

4-9.2.4 Exhaust Inlet Protection. The inlets to all PVHO exhaust lines shall be fitted with a device that prevents a PVHO occupant from inadvertently blocking the opening to the line with a body part or be located in normally unoccupied areas, such as under the PVHO floor. PVHO exhaust line inlets shall also be located such that, where applicable, discharge of the fire-suppression system will not result in water collecting in the bottom of the PVHO being injected into the exhaust line.

4-9.2.5 Exhaust Locations. The exhausts from the depressurization system of PVHOs located inside enclosures shall be piped to a location outside the enclosure and at least 10 ft (3 m) away from any air intake.

4-9.2.6 Noise. Noise in a PVHO may interfere with voice communication, as well as present a risk of hearing damage if the level of noise is severe. The designer shall consider all sources of noise in the PVHO and shall design the system to prevent noise levels generated by routine PVHO operations from exceeding those determined in appropriate national standards to cause damage or discomfort to the PVHO occupants.

4-9.3 Pressure Boundary Valve Requirements

4-9.3.1 Internal Pressure PVHOs. All lines penetrating the pressure boundary of a PVHO subject only to internal pressure shall have a stop valve or a check valve, as appropriate, on the outside of the PVHO, as close as possible to the penetration. Where stop valves are placed in locations that prevent ready access in an emergency, they shall be provided with operators that are controllable from suitable accessible locations. Depressurization lines, drain lines, and other lines that normally communicate between PVHO pressure and outside atmospheric pressure shall also have a second valve. This second stop valve may be located either inside or outside of the PVHO.

4-9.3.2 External Pressure PVHOs. All lines penetrating the pressure boundary of a PVHO normally subject only to external pressure shall have a stop valve or check valve, as appropriate, as close as practically possible to the penetration on the inside of the PVHO. A second stop valve shall be provided on lines that are normally open to external pressure.

4-9.3.3 Internal and External Pressure PVHOs. PVHOs that may be subject to both internal and external pressure shall meet the requirements of [paras. 4-9.3.1](#) and [4-9.3.2](#).

4-9.3.4 External Override. When valves are provided inside a PVHO to permit the PVHO occupants to control the pressure in the PVHO, an external means of overriding the effect of those valves shall be provided.

NOTE: The external override need not be on the same lines or on lines of similar capacity. The fundamental requirement is that there be some means provided, in advance, for gaining access to the PVHO if the inside personnel becomes incapacitated.

4-9.3.5 Special Requirements for PVHOs Used for Saturation Service. For PVHOs designed to be used for saturation applications, all lines that are open to PVHO pressure except pressure relief lines and pressure reference lines (e.g., all lines used for pressurization, depressurization, external gas, or water conditioning systems) shall have double valves with one stop, or check, valve inside the PVHO and the other valve outside.

4-9.3.6 Flow-Rate-Sensitive Valves. When check valves or stop valves cannot be used, a flow-rate-sensitive valve that closes automatically in the event of excess flow may be used. Flow-rate-sensitive valves, when used, may

satisfy the second stop valve requirement of [paras. 4-9.3.1, 4-9.3.2, and 4-9.3.5](#).

4-9.3.7 Remotely Operated Stop Valves. Remotely operated stop valves, whose operation is triggered upon uncontrolled loss of pressure, are an acceptable alternative to the flow-rate-sensitive valves described in [para. 4-9.3.6](#). Such valves may be used to satisfy the second stop valve requirements of [paras. 4-9.3.1, 4-9.3.2, and 4-9.3.5](#), provided individual valves may be closed manually without triggering closure of other valves. Remotely operated valves used in pressure boundary applications shall also have a manual actuation capability, or a secondary means of pressurizing and/or depressurizing the PVHO shall be provided for use if the valve becomes inoperable.

(23) 4-9.4 Pressure Gauges

Sufficient gauges shall be located throughout the system so that operators are able to monitor gas pressure and depth at all times. ASME B40.1 and ASME B40.7 provide information on the operation, use, testing, and calibration of pressure-indicating dial-type elastic element and digital gauges, respectively. ASME B40.1 and ASME B40.7 should be referred to when selecting gauges to meet the User Design Specifications.

4-9.4.1 Quantity and Location

(a) Each internal pressure PVHO compartment in a PVHO system shall have at least one dedicated depth gauge (PVHO compartment pressure indicator) indicating compartment PVHO internal pressure to the PVHO or system operator. Each compartment or PVHO in PVHO systems other than medical monoplace PVHOs also shall have a second depth gauge that may be located either inside or outside the PVHO.

(b) External pressure PVHOs and PVHOs subject to both internal and external pressure shall have dedicated gauges indicating both internal and external pressures to the PVHO or system operator, and separate gauges indicating these pressures to the PVHO occupants, unless the occupants are also the operators, as in the case of a submersible.

4-9.4.2 Scale. Full-scale reading of the gauge should be approximately 130% to 160% of the maximum operating pressure of the system. For example, for a system with a maximum operating pressure of 3,000 psi, the full-scale reading of the gauge should be 4,000 psi or 5,000 psi.

4-9.4.3 Accuracy. The selection of gauge accuracy and precision is based on the type of system and how the gauge is used. A high level of precision is not required on air bank pressure gauges where only relative values are necessary to determine how much air is left in the bank or when to shut down the charging compressor. However, considerable accuracy is required for gauges that read depth. The

User Design Specifications should provide the gauge accuracy requirement using the gauge accuracy grades provided in ASME B40.1

4-9.4.4 Gauge Calibration

4-9.4.4.1 Calibration Requirements. All new gauges shall be calibrated and verified prior to use. ASME B40.1 and ASME B40.7 provide testing procedures for new gauges as applicable.

4-9.4.4.2 In-Use Verification. A means shall be provided to permit depth gauges to be checked, while in use, against other system depth gauges normally accessible to the PVHO or system operator or against an external master gauge for accuracy.

4-9.4.5 Piping. The lines connecting depth gauges to their associated PVHOs shall not be used for any other purpose. The inside diameter of depth gauge lines shall not be smaller than 0.12 in. (3 mm).

4-9.4.6 Valve Arrangements. Valve arrangements used with depth gauges shall be designed so that the pressure source to which each gauge is connected is clearly indicated to the system operator.

4-9.4.7 Gauge Isolation. All breathing-gas and life-sensitive systems shall be fitted with at least one pressure gauge equipped with a gauge isolation valve. Measures to protect gauges from excessive vibration or sudden pressure changes shall be taken where appropriate.

4-9.5 Pressure Gauges Other Than Depth Gauges

All breathing gas and life-sensitive systems shall be fitted with at least one pressure gauge equipped with a gauge isolation valve. Measures to protect gauges from excessive vibration or sudden pressure changes shall be taken where appropriate.

4-9.6 Breathing Gas Systems

4-9.6.1 Breathing Gas Outlets. The number of breathing gas outlets provided in PVHOs shall be not less than the maximum rated number of occupants plus one, except for diving bells where the number of breathing gas outlets shall not be less than the maximum rated number of occupants. Each gas outlet shall have a stop valve. Each gas outlet shall be compatible (pressure and flow rate capacity, connection type, etc.) with the type of breathing apparatus listed in the User's Design Specification.

4-9.6.2 Redundancy of Breathing Gas Supply. The piping system shall be designed so that breathing gas can be delivered to the breathing gas outlets in PVHOs and to the divers' breathing gas manifold in diving bells from at least two supply sources.

4-9.6.3 Stored Gas Reserves. The designer shall consider all operational and jurisdictional requirements.

4-9.6.4 Multiple Gases. Where gases of different composition are connected to a distribution manifold or other distribution system, a positive means shall be provided to ensure that leaking valves will not result in an improper gas being supplied to the end-use point or result in backflow from one supply gas into the distribution system for another supply gas.

4-9.6.5 Labeling of Breathing Gas Outlets. All breathing gas outlets shall be labeled. Where the gas supplied is always known, the label shall indicate the type of gas supplied, such as "Oxygen." Where the gas supplied is subject to change based on operational requirements, the label shall contain a generic term, such as "Breathing Gas."

4-9.6.6 Separation of Breathing Gases. This Standard recognizes that complete separation of breathing gases of different types is generally not possible in PVHO applications. The designer shall take all reasonable steps to minimize the number of locations/situations where gases of different compositions need to use common distribution equipment and/or common outlets.

4-9.6.7 Pressure Control Valves in Demand Breathing Systems. Pressure control valves used in demand breathing systems shall meet the requirements of para. 4-9.7.6.

4-9.7 Pressure Control Valves

4-9.7.1 Performance Characteristics. The performance of a pressure control valve is characterized primarily by two factors, both of which shall be considered by the designer. These factors are

(a) the rate at which the outlet pressure decreases (from the set point) as flow demand increases. In many designs, there is a significant difference between outlet pressure at the no-flow condition and the outlet pressure at design service flow rates. In unbalanced single-stage pressure control valves, outlet pressure may also be influenced by changes in inlet pressure. The flow effect is usually the controlling factor in design.

(b) limit flow capacity. This factor is a function of upstream pressure, orifice size, downstream pressure, and outlet porting size.

4-9.7.2 Seats. All pressure control valves used in life-sensitive systems shall employ soft seats capable of bubble-tight shutoff.

4-9.7.3 Filters. All pressure control valves used in life-sensitive systems, except those used in overboard dump systems for breathing masks, shall be provided with an upstream particulate filter that meets the requirements of para. 4-4.3.

4-9.7.4 Gauges. Gauges indicating the controlled pressure shall be provided with all pressure control valves, and they shall be located so as to be clearly visible to a person adjusting the setting of the pressure control valve.

4-9.7.5 Bypass Requirements. Except as otherwise required in para. 4-9.7.6(b), in systems where the ability to maintain uninterrupted service is required, all regulators shall be provided with either a redundant regulator of equal size or a manually operated bypass valve.

4-9.7.6 Pressure Control Valves Used in Demand Breathing Systems

(a) *Capacity Requirements.* The peak respiratory flow rates, both inspiratory and expiratory, in a demand breathing system are normally 3.0 to 3.14 times the net average flow as represented by the user's respiratory minute volume. Therefore, the capacity of pressure control valves used to support demand-type breathing apparatus shall be computed as

$$Q = \pi(N)(D)(RMV)(F)$$

where

D = maximum usage depth, atm absolute

F = factor, to be taken as 1.0 unless data is available to support a lower number

NOTE: $F = 1$ assumes all gas users inhale or exhale simultaneously. Consequently, as N becomes large, F will approach 0.5. For $N = 1$ or 2, F shall be taken as 1.0. For $N > 2$, F may be reduced as warranted by testing or experience with prior designs. F may also be reduced if it can be shown, either experimentally or analytically, that sufficient volume exists between the pressure regulation point and the usage point or points to provide an accumulator effect capable of providing whatever differences may exist between the instantaneous flow rate requirements and the regulator capacity provided. In no case may F be reduced below 0.5.

N = maximum number of breathing apparatuses to be supported at one time

Q = regulator capacity at minimum design inlet pressure, ft³/min (L/min)

RMV = maximum anticipated user respiratory minute volume, in ft³/min (L/min) at usage pressure; the minimum RMV that may be used is 1.41 ft³/min (40 L/min) for a working diver and 0.7 ft³/min (20 L/min) for a resting diver or PVHO occupant

(b) *Bypass Requirements*

(1) The pressure control valves in piping circuits supplying breathing gas to divers using demand breathing apparatus in the water or in a diving bell shall be either of the following:

(-a) provided with a bypass loop containing a second pressure regulator of equal capacity and appropriate related components

(-b) arranged as a series of two or more pressure control valve stations each with a hand-operated bypass, appropriate related components, and a pressure control valve capable of accepting full initial supply pressure and providing regulated outlet conditions appropriate for the end-use function

(2) Hand-operated bypass valves may be used in systems supplying gas to PVHO mask breathing gas outlets, provided that adequate overpressure relief is provided.

(3) Bypass capability is not required for pressure control valves supporting single consumers where a service interruption is tolerable, e.g., for pressure control valves dedicated to each of several mask breathing gas outlets in a PVHO.

(4) Bypass capability is not required for pressure control valves supporting overboard dump manifolds in PVHOs.

4-9.8 Pressure Relief Requirements

4-9.8.1 Overpressure Relief

(a) All systems that may be subject to internal pressures in excess of their design pressure shall be provided with overpressure relief devices capable of maintaining system pressure not to exceed 110% of design pressure.

(b) Systems located inside of PVHOs that are normally pressurized at less than PVHO pressure shall be equipped with relief devices (check valves are acceptable) if any of the components in the system (e.g., vacuum gauges) are subject to damage, if PVHO pressure is released without a concurrent release of system pressure.

4-9.8.2 Underpressure Relief

(a) Piping or components located inside of PVHOs that are normally pressurized in excess of PVHO pressure shall be equipped with vacuum breakers if any of the components of the system (such as pressure gauges) are subject to damage, if the PVHO is pressurized without pressure in the system.

(b) Piping or components located inside of PVHOs that are normally pressurized to a level less than PVHO pressure (e.g., mask overboard dump lines, medical suction lines, etc.) shall be provided with vacuum relief valves capable of relieving underpressures in excess of the maximum limits established by the system designer.

4-9.8.3 Rupture Disks. Rupture disks shall not be used except on gas containers.

4-9.8.4 Division Valves. Where piping systems operating at different pressures are connected, a division valve shall be provided that shall be designed for the higher system pressure.

4-9.8.5 Pressure-Reducing Valves. Relief devices shall be provided on the low-pressure side of the pressure-reducing valves, or the piping and equipment on the low-pressure side shall meet the requirements for the full system pressure.

The relief devices shall be located as close as possible to the reducing valve. The total relieving capacity provided shall be such that the design pressure of the low-pressure piping system will not be exceeded by more than 10% if the reducing valve fails open.

4-9.8.6 Bypass Valves. Where manually operated bypass valves are permitted around pressure control valves, they shall not have a maximum flow capacity greater than the reducing valve unless the downstream piping is adequately protected by relief devices or meets the design requirements of the higher system pressure.

4-9.8.7 Stop Valves. There shall be no stop valves between piping being protected and its protective device or devices, except that stop valves may be installed between a relief valve and the piping being protected under the following conditions:

(a) when, in the judgment of the designer, the hazard from a relief valve failing open exceeds the hazard presented by the possible concurrent occurrence of system overpressure plus a closed stop valve

(b) when a stop valve is provided between a relief valve and the associated protected piping, the valve shall be per the designer's specification for the fluid piping being protected, and the relief device shall be per ASME BPVC, Section VIII, Division 1, UG-125 through UG-136, or Section VIII, Division 2, Part 9

4-9.8.8 Exhausts From Relief Devices

(a) Exhausts from relief devices that are located inside enclosed spaces shall be piped outside of the space if operation of the relief device could result in overpressurizing the space.

(b) Exhausts from relief devices that are located inside enclosed spaces on lines containing gases other than air shall be ducted out of the space.

4-9.9 Color Coding

4-9.9.1 Consistent Color Codes. PVHO piping systems shall employ a consistent color coding system. Suggested guidelines are provided in [Nonmandatory Appendix C](#).

4-9.9.2 Owner's Responsibility. Color code requirements vary substantially between the various jurisdictions in which PVHO systems may be used. It shall be the responsibility of the designer to specify the required color coding system.

4-9.10 Labeling

4-9.10.1 Piping and Gas Storage Vessels. All piping and gas storage bottles shall be labeled to show contents, direction of flow (when appropriate), and MAWP.

4-9.10.2 Critical Components. The designer shall determine all critical components whose function is not obvious from their location and appearance. These components shall be labeled as to function.

4-9.10.3 Panel-Mounted Components. All components that are mounted in panels shall be labeled as to function.

4-9.11 Soft Goods

4-9.11.1 Breathing Gas Systems. Soft goods used in breathing gas service shall be compatible with intended service fluids at the anticipated maximum pressures and shall be compatible with all anticipated cleaning procedures.

For breathing gas systems using oxygen-enriched gases (greater than 25% oxygen), consideration shall be given to the soft goods flammability in the oxygen-enriched environment. ASTM G63 and ASTM Manual 36 provide guidance.

4-9.11.2 Other Systems. Soft goods used in other systems shall be compatible with the fluids contained, at the maximum anticipated conditions of temperature and pressures.

4-9.12 Lubricants and Sealants

See [para. 4-2.3](#), ASTM G63, and ASTM Manual 36 regarding appropriate materials and practices.

4-9.13 Cleaning Requirements

4-9.13.1 Oxygen and Breathing Gas Systems. The cleaning of oxygen and breathing gas piping systems is an essential part of PVHO piping system design and fabrication. The following are recommended guidelines:

(a) A written cleaning procedure with well-defined procedures, personnel responsibilities, acceptance/recleaning criteria, marking, packaging, and storage requirements shall be developed and implemented.

(b) Component handling procedures shall be developed and implemented so that components and systems, once cleaned, are not recontaminated.

(c) The cleaning procedures intended to be used with the piping system shall be considered by the designer during the selection of all materials, especially soft goods, and during the layout of the piping.

4-9.13.2 Components Located Inside PVHOs. Piping components that are to be located inside the PVHO shall also be cleaned on their exteriors. The exteriors of components for use inside marine systems should show no visible signs of oil or grease. The exteriors of

components for use inside PVHOs with elevated oxygen environments should show no fluorescence typical of oil or grease when examined under ultraviolet light.

4-9.13.3 Prohibited Cleaning Materials. Trichloroethylene shall not be used to clean breathing gas systems or any components to be located inside a PVHO.

NOTE: When gas is passed through a moderately heated alkali bed (such as those used in most carbon dioxide scrubbers), residual trichloroethylene can decompose into highly toxic dichloroacetylene.

4-9.14 Off-Gassing Test for Hoses Used for Breathing Gas Service

4-9.14.1 Background. Some components used in the manufacture of hoses can give off vapors that are toxic if inhaled. For hoses to be considered acceptable for breathing gas service, they shall pass the off-gassing test described herein.

(a) *hydrocarbon*: for this test procedure, all organic compounds detectable by a total hydrocarbon analyzer

(b) *methane equivalent*: concentration of methane in air that will cause a total hydrocarbon analyzer to give an indication equivalent to that obtained from the gas being analyzed

4-9.14.2 Procedure

(a) Off-gassing measurements shall be made only on hoses that have not been flushed with air, gas, or water. Both the total hydrocarbon analyzer and the hose or hoses to be tested shall be maintained at a temperature not lower than 73°F (22.8°C) throughout the testing period.

(b) By this procedure, measurements are made of the increase in the hydrocarbon concentration of a stream of air flowing through the test hose at a flow rate of 28 LPM (1 CFM). The temperatures of the test hose, air supply, and analyzer shall not be lower than 73°F (22.8°C). A diagram of the flow arrangement is shown in [Figure 4-9.14.2-1](#). Before the air passes through the test hose, the air shall be clean and shall contain no more than 1 mg/m³ of hydrocarbons (methane equivalents). The analyzer shall be zeroed with air passing at the stipulated flow rate and temperature through the connector tubes only. The test hose shall then be inserted in the line and the airstream passed through it. For the ensuing 15 min, readings of the hydrocarbon concentration shall be recorded. The test hose shall be rated on the reading at the end of the 15-min test period. Hoses that contaminate the air by greater amounts than specified in [Table 4-9.14.2-1](#) shall not be acceptable.

4-9.14.3 Hose Testing. MIL-H-2815 provides guidance in testing hoses.

Table 4-2.1.1-1
Maximum Allowable Stress Values for Seamless Pipe and Tube Materials Not Listed in Nonmandatory Appendix A of ASME B31.1

Material	Specification	Temper or Grade	Strength, ksi	Maximum Allowable Stress Values in Tension, ksi
Alpha-brass	British Standard 1306	...	54	10.8
Copper water tube	ASTM B88, Types K & L	Drawn	36	6.0

GENERAL NOTE: 1 ksi = 1,000 psi.

Table 4-7.1-1
Mandatory Minimum Nondestructive Examinations for Pressure Welds in Piping Systems for Pressure Vessels for Human Occupancy

Type of Weld	Examination Requirements
Butt welds (girth and longitudinal)	Pressure boundary and life-sensitive piping RT, all sizes Otherwise, RT for NPS over 2 in., MT or PT for NPS 2 in. and less
Branch welds (intersection and nozzle); size indicated is branch size	RT for NPS over 4 in., MT or PT for NPS 4 in. and less
Fillet welds, socket welds	PT or MT for all sizes and thicknesses

GENERAL NOTES:

- RT = radiographic examination; MT = magnetic particle examination; PT = liquid penetrant examination; NPS = nominal pipe size.
- For vent lines not subject to chamber pressure, MT or PT may be substituted for RT.
- All welds shall be given a visual examination in addition to the type of specific nondestructive test specified.
- It should be noted that it is impractical to radiograph some branch connections due to the angle of intersection or the configuration. If the joint configuration precludes RT, other nondestructive testing (NDT) methods should be substituted to establish the quality of the joint.
- Nondestructive examinations specified above do not apply to components made to standards listed in ASME B31.1, Table 126.1, or ASME B31.3, Table 326.1.

Figure 4-9.14.2-1
Flow Diagram of Apparatus for Measuring the Concentration of Hydrocarbons in a Stream of Air or Other Gas
After It Has Passed Through a Test Hose




Table 4-9.14.2-1
Maximum Allowable Concentration of Hydrocarbons in Air Passing Through Hose

Hose Length, ft	Hydrocarbon Concentration as Methane Equivalents, mg/m ³
3	4
100	100

Section 5

Medical Hyperbaric Systems

5-1 GENERAL

5-1.1 Scope

This Section, along with [Sections 1](#) through [4](#), provides minimum requirements for the design, assembly, inspection, testing, and certification of PVHO systems used specifically in medical hyperbaric therapy.

5-1.2 User's Design Specification

The user, agent on the user's behalf, or the manufacturer shall provide or cause to be written a User's Design Specification in accordance with [subsection 1-4](#). This specification shall set forth the requirements as to the intended use of the chamber and operating conditions in such detail as to constitute an adequate basis for designing the system as necessary to comply with this Standard. They shall include, as a minimum, the following:

- (a) rated number of occupants
- (b) maximum operating pressure
- (c) pressurization/depressurization rates, ventilation rates, and the conditions under which those rates are to be maintained
- (d) requirements affecting the amount of stored gas reserves
- (e) number of breathing gas outlets and their characteristics
- (f) temperature and humidity control requirements, if any
- (g) fire-suppression requirements
- (h) minimum and maximum operating temperatures
- (i) type or types of breathing gas delivery systems
- (j) pressurization gas (air or oxygen)
- (k) the edition or editions of other codes and/or standards used in the development of the User's Design Specification

5-1.3 Documentation

- (a) PVHO documentation shall be in accordance with [para. 1-7.9](#) and the requirements of other codes and standards as required.
- (b) Viewport (window) documentation shall be in accordance with [Section 2](#).
- (c) All documentation should be retained by the user for the life of the PVHO. If the PVHO is transferred to a new user, all documentation should accompany the PVHO.

5-1.4 Viewports

All chambers shall have at least one viewport in each compartment for viewing the chamber interior and its occupants.

5-1.4.1 Monoplace Chambers. Monoplace chambers shall have sufficient visual access to permit the chamber operator to observe at least the patient's head, face, chest, and arms.

5-1.4.2 Multiplace Chambers (Multioccupancy Chambers). Each multiplace chamber compartment shall have at least one viewport positioned to support visual communication between one or more persons located inside and one or more persons located outside the compartment. Additional methods [e.g., closed circuit televisions (CCTVs)] may be used to enhance viewing of the interior of each chamber, compartment, and occupants by the operator. CCTV systems shall have sufficient backup power for emergency situations.

5-1.5 Quick-Actuating Closures

Quick-actuating closures that have the potential to be opened while pressurized, such as most medical lock outer doors, shall be designed in accordance with the requirements for quick-acting closures contained in ASME BPVC, Section VIII, Division 1, UG-35.

5-1.6 Personnel Entry Lock

Chambers intended for medical treatment at 3 ATA or less that do not normally incur a decompression obligation for the patients shall not be required to have a personnel lock.

5-1.7 Penetrations

Additional penetrations to provide for access for sensor leads, etc., shall be provided as required by the User's Design Specification.

5-1.8 Personnel Egress

Consideration shall be given to the size and configuration of doorways and/or hatches for safe access and egress of personnel and patients.

5-1.9 Medical-Use PVHO Certifications

The piping systems for PVHOs intended for use as medical devices, designed and manufactured according to the manufacturer's standard commercial design, shall comply with the U.S. Food and Drug Administration (FDA) Design Control Requirements (C.F.R.) Part 820, Quality System Regulations. Standard products meeting the requirements of the FDA are exempt from the requirements stated in [paras. 4-1.2.1 through 4-1.2.3](#).

(23) 5-2 PVHO SYSTEM DESIGN

5-2.1 System Design Requirements

System design shall be such that pressurization/depressurization rates, gas composition limits, contaminant control, ventilation, fire-suppression system performance, and heating and cooling requirements can be maintained in accordance with the User's Design Specification and other applicable codes and standards. (See NFPA 99, relevant chapter, for guidance.)

5-2.2 Pressure Boundary Valve Requirements

Chambers built under this Section shall not be required to conform to the requirements of [para. 4-9.3.1](#) provided

- (a) the chamber has a rated occupancy of no more than 1 person.

- (b) the maximum operating pressure (MOP) of the PVHO is limited to 3 ATA and the maximum exposure to the occupant is limited in time to avoid decompression obligation.

- (c) provision is made to override chamber pressurization and exhaust control valves.

- (d) all pressure boundary penetrators connected to pneumatic (or plumbing) lines, larger than $\frac{1}{4}$ in. in diameter are protected with stop valves, check valves, or quick-disconnects. Electrical penetrators or smaller signal lines shall be exempted from this requirement.

(23) 5-3 GAS SYSTEMS

5-3.1 Gas Supply Requirements

Gas supplies for medical PVHO system vary in gas production and storage capacities depending on the required flow rates that support monoplace or multiplace PVHO system operation. The gas supply capacity includes the combination of gas production and storage as required for PVHO pressurization and ventilation, treatment gas, and emergency air supplies for the maximum flow rates and number of occupants. The gas supply and exhaust shall comply with local building regulations for installation and with [Section 4](#).

5-3.2 Breathing Devices

The type of breathing devices (e.g., breathing mask or hood) and number of each shall be identified in the User's Design Specification. The supply and exhaust minimum flow rates to the device or devices should be determined by the identified device manufacturer. The gas exhaust flow rate for each device shall be equal to or greater than its gas supply flow rate. For multiplace PVHOs, a minimum supply flow rate shall be maintained, assuming all occupants are using the breathing devices simultaneously. The device supply controls shall provide the capability of switching all occupants from treatment gas to emergency air simultaneously in the event of chamber fire or contaminated environment. The emergency air shall be supplied independent of the air used for chamber pressurization and venting.

5-3.3 Breathing Device Gas Outlets

Each PVHO treatment compartment shall be equipped with the number of gas supply and exhaust outlets for each occupant breathing device. Nontreatment compartments shall have emergency air supply and exhaust outlets for each designated occupant. Each outlet connection type shall be compatible with the designated breathing device. Monoplace PVHOs without breathing devices, as designated in the User's Design Specification or PVHO manufacturer manuals, are exempt from this requirement.

5-4 CONTROL SYSTEMS AND INSTRUMENTATION

5-4.1 Controls Location

Primary operation shall be external to the chamber. If remote or automated controls are used, manual overrides shall be provided and easily accessible.

5-4.2 Communications

Control console or stations shall be equipped to provide communication with each compartment.

5-5 ENVIRONMENTAL SYSTEMS

5-5.1 Environmental Conditions

All systems and components shall be capable of operating satisfactorily and safely in accordance with their specifications at the environmental conditions stated. The designer shall give specific consideration to the comfort of the patients in deciding whether environmental control of the chamber atmosphere is required or whether ambient conditions will suffice.

5-5.2 Temperature

Patient comfort shall be maintained by supplemental heating or cooling, as required.

5-5.2.1 Multiplace Chambers. If multiplace chambers are equipped with heating or cooling systems, provision shall be made to shut off the heating or cooling system in the event of malfunction.

5-5.2.2 Monoplace Chambers. Temperature control for the chamber area shall be considered for monoplace chambers.

5-5.3 Humidity

A specific system for the control of humidity is not mandatory if other methods such as ventilation or circulation are sufficient to maintain patient comfort in accordance with the User's Design Specification.

5-5.4 Contaminants

Sources of volatile, toxic, or potentially toxic contamination shall be minimized to the extent practical. Possible sources of contamination include off-gassing of nonmetallic materials.

5-5.5 Lighting

There shall be sufficient lighting in or around a chamber to see the patient or patients, the chamber control console, and chamber support equipment systems.

5-5.5.1 External Lighting. External lighting fixtures shall not come into contact with or be allowed to overheat the surface of a window in excess of its maximum design temperature in accordance with [Section 2](#).

5-5.5.2 Emergency Lighting. Emergency lighting shall be provided.

5-5.6 External Heat Sources

External heat sources in addition to lighting fixtures shall not come in contact with or otherwise heat the surface of a window in excess of its maximum design temperature.

5-5.7 Access to Emergency Equipment

No permanent seat or stretcher shall block the aisles, hatches, doors, medical locks, handheld hoses, fire-suppression controls, or any emergency equipment.

5-5.8 Suction Systems

All systems for use inside a chamber shall have a trap in-line to keep waste materials out of the piping system.

If a suction system uses pressure differential for the vacuum while at depth, there shall be a vacuum source for use on the surface.

5-5.9 Accidental Depressurization

(a) If a sink, water supply, or drainage system is used, provisions shall be made to prevent unintentional depressurization of the system.

(b) Any toilet that is plumbed to discharge to the outside of the chamber shall have a holding tank and a dual-valve safety interlock system.

(c) Any toilet that flushes to the outside of the chamber shall be designed to preclude the possibility that a seal might be created between the seat and the person using the toilet.

5-6 INSTALLATION TESTING

(23)

5-6.1 Installation

The manufacturer or a manufacturer-approved qualified person shall perform a thorough operational test of each installed PVHO. A written record of these test results shall be provided to the owner/user or a designated agent and a copy shall be retained by the manufacturer.

Where multiple PVHOs are installed, a functional test, including of the relevant electrical- and gas-supply systems, shall be performed to confirm that all PVHOs operate simultaneously and safely under predicted maximum demand.

5-6.2 Handover

The manufacturer or a manufacturer-approved qualified person shall provide specific equipment operating instructions and a specific equipment operations manual covering normal chamber usage and equipment maintenance as well as emergency conditions identified in the risk analysis ([subsection 1-11](#)).

Section 6

Diving Systems

6-1 GENERAL

6-1.1 Scope

6-1.1.1 PVHOs. This Section, along with [Sections 1 through 4](#), provides the requirements for the design, fabrication, assembly, inspection, testing, certification, and stamping of PVHOs used in diving systems. This includes but is not limited to

- (a) deck decompression chambers
- (b) diving bells
- (c) transfer locks
- (d) saturation living chambers
- (e) rescue chambers
- (f) hyperbaric evacuation systems
- (g) diving subsystems/components
- (h) diver lockout chambers
- (i) hyperbaric stretchers

6-1.1.2 Components. The scope of this Section includes, but is not limited to, the following components:

- (a) doors
- (b) hatches
- (c) penetrations and fittings
- (d) medical and service locks
- (e) quick-opening closures
- (f) viewports
- (g) light-transmitting devices
- (h) electrical penetrators
- (i) trunks and tunnels

6-1.2 User's Design Specification

A User's Design Specification, as described in [subsection 1-4](#), shall be written for the PVHO diving system. The Specification shall set forth the requirements as to the intended use of the PVHO or component and the operating and environmental conditions in such detail as to constitute an adequate basis for design, fabrication, inspection, and testing of the PVHO or component necessary to comply with this Standard. The User's Design Specification shall include

- (a) number of intended occupants
- (b) maximum operating pressure/depth
- (c) required pressurization and depressurization rates, ventilation rates, and conditions under which rates are to be maintained
- (d) intended operational environment

- (e) maximum number of pressure cycles
- (f) maximum/minimum internal/external pressures
- (g) operating temperatures
- (h) storage conditions/temperatures
- (i) number, size, and type of penetrators, doors, hatches, windows, and service locks
- (j) corrosion allowance
- (k) environmental requirements
- (l) special design considerations applicable to normal and emergency service, e.g., requirements for the sizing of the diver lockout hatch [i.e., the diver dress and potential underwater breathing apparatus (UBA) to be used]
- (m) fire suppression

6-1.3 Design Certification

Conformance of the completed PVHO to the requirements of this Standard and the User's Design Specification shall be established by the following procedures:

(a) A competent Professional Engineer, registered in one or more of the U.S. states or provinces of Canada, or the equivalent in other countries, and experienced in the design of PVHOs, shall certify that the PVHO or component was designed or completely reviewed by the engineer or under the engineer's direct supervision, and that to the best of their knowledge, it meets the requirements of the User's Design Specification and complies with this Standard.

(b) Alternatively, the PVHO or component shall be reviewed by an authorized government agency or an independent classification society competent in pressure vessels for human occupancy, and such organization shall provide a certification that the PVHO or component complies with this Standard and the User's Design Specification.

6-1.4 Documentation

The user shall be provided with the following data and documentation:

- (a) User's Design Specification
- (b) PVHO and/or PVHO component certification
- (c) PVHO window certificates in accordance with [Section 2](#)
- (d) viewport and window drawings
- (e) applicable ASME data reports and partial data reports
- (f) any classification society certifications

(g) vessel drawings necessary for the maintenance, inspection, and repair of the PVHO

6-1.5 Useful References

The designer should be familiar with the references contained in [Nonmandatory Appendix F](#).

6-2 DESIGN

6-2.1 General

PVHOs, their components, and attachments shall be designed for the environmental conditions in which they are intended to operate. For example, particular attention shall be given to the corrosive effect of salt water, sea, air, and chlorinated water, as applicable.

The PVHO shall be designed, fabricated, assembled, inspected, tested, and certified in accordance with [Section 1](#). The design should facilitate the ability to conduct planned maintenance and inspections.

The design of the diving system shall incorporate appropriate backup systems and equipment to ensure the safety of both the occupants and the operating personnel in the event of any single failure.

6-2.2 Design Loads

The designer shall address in the design all forces acting on the PVHO. These may include but are not limited to

- (a) internal and external pressure forces
- (b) dynamic loads
- (c) local loads including impact, lifting force localized reactions, and discontinuities
- (d) loads due to expansion and contraction
- (e) loads due to weight of contents, or equipment mounting
- (f) transportation loads
- (g) test loading and configurations
- (h) entrapped water loads
- (i) loads due to lifting, handling, or mounting
- (j) loads due to external connections (e.g., bell or escape tunnel clamped to a chamber, piping connections)
- (k) wave loads
- (l) operation and emergency loads
- (m) vibration loads
- (n) seismic loads

The design shall consider the external forces transmitted to the PVHO.

For marine design purposes, these forces shall be at least 2.0g vertical, 1.0g transverse, and 1.0g longitudinal, unless otherwise determined, all acting simultaneously while the chamber is pressurized. Consideration shall be given to inclinations as follows:

Design	Roll, deg	List, deg	Pitch, deg	Trim, deg
Mounted on a conventional ship or construction barge	±22.5	±15	±10	±5
Mounted on a semisubmersible	...	±15	...	±15
Components in a bell	±45	±22.5	...	...

6-2.3 Environmental Requirements

Pressure vessels used in diving are exposed to conditions needing special consideration. These conditions may include

- (a) weather
- (b) frequent handling
- (c) weight and buoyancy
- (d) static/dynamic loads
- (e) exposure to marine conditions
- (f) corrosion
- (g) exposure to temperature extremes

6-2.4 Corrosion

The design shall consider corrosion allowance and/or mitigating process based on the operating environment as defined in the User's Design Specification. Areas of pressure vessels subject to corrosion shall be protected by an appropriate means.

6-2.5 External Pressure Rating

Components of PVHO pressure boundaries subject to external pressure shall be designed in accordance with [Section 1](#).

6-2.6 Impact Protection

The designer shall provide protection to the pressure hull of the PVHO and critical components (e.g., viewports and emergency gas supplies) that may be subject to impact during operations and transportation. This protection should also be designed to minimize the risk of fouling or entanglement.

6-2.7 Buoyancy

Should the User's Design Specification require a positively buoyant bell, any ballast control mechanism shall be designed to prevent accidental activation or inadvertent release.

6-2.8 Occupant Requirements

6-2.8.1 All PVHOs shall have an entry lock or the capability of being mated to another PVHO as a method for access to the occupants while under pressure.

6-2.8.2 The designer shall apply principles of ergonomics to the arrangement of the PVHO. The recommended minimum internal dimensions and volumes are as follows:

- (a) saturation living chambers — sized to allow occupants to stand and lie down, move in and out of the chamber, and permit meal services while saturated
- (b) transfer lock (TUP) — 105 ft³ (3.0 m³) floodable volume
- (c) diving bell (SDC) for
 - (1) two occupants — 105 ft³ (3.0 m³) floodable volume
 - (2) three occupants — 160 ft³ (4.5 m³) floodable volume
- (d) deck decompression/recompression chamber (DDC) — sufficient to accommodate a diver and an attendant

6-2.8.3 PVHOs intended for use as living chambers for longer than 24 hr in other than emergency situations shall have, or be capable of connecting to another PVHO equipped with, the following for the intended number of occupants:

- (a) the ability to monitor and control the oxygen level, carbon dioxide level, ambient temperature, and primary life-support parameters
- (b) one bunk per occupant
- (c) potable water
- (d) toilet
- (e) shower
- (f) medical or service lock
- (g) built-in breathing system (BIBS) with a breathing gas

6-2.8.4 PVHOs shall be designed to allow access to internal bilge/void areas for cleaning and inspection.

6-2.9 Lubricants and Sealants

Lubricants and sealants selected for use in PVHOs shall be suitable for the hyperbaric environment in which they operate. The designer shall address

- (a) flammability
- (b) toxicity
- (c) compatibility with breathing gases
- (d) odor
- (e) skin irritation
- (f) compatibility to materials

6-2.10 Material Toxicity (Including Paints)

Materials and equipment inside manned compartments shall not give off noxious or toxic vapors within the limits of anticipated environments. Where compliance with this requirement has not been demonstrated through satisfactory service experience, an analysis or testing program shall be performed.

6-2.11 Emergency Recovery of Diving Bells

6-2.11.1 General. This subsection addresses the design, construction, and testing of emergency recovery equipment on diving bells.

6-2.11.2 Design. All diving bells shall be equipped with a secondary lifting point, meeting the same requirements as the primary lifting point, to facilitate the attachment of an emergency lifting wire.

Consideration shall be given to the clearance necessary between the bottom door and the seabed to ensure safe ingress or egress of divers under emergency conditions.

Diving bells shall be outfitted with a means of emergency recovery depending on whether they have been designed to remain negatively buoyant or become positively buoyant.

6-2.11.3 Negative Buoyancy Diving Bells. Guide wires and one or more clump weights shall be designed to permit the diving bell to be recovered from the maximum operating depth when loaded to the maximum service weight, with the trunk or trunks flooded, and the maximum deployable length of umbilical and lifting wire attached to the bell and severed at the surface.

6-2.11.4 Positive Buoyancy Diving Bells. The diving bell shall be equipped with devices for releasing the main lifting wire, guide wires, and the umbilical and ballast weight or weights. The operation of each emergency release device shall require at least two mutually independent actions for release.

Release devices shall be designed to prevent accidental actuation. Consideration shall be given to environmental factors, e.g., exposure to ambient temperatures and pressures. The design should facilitate regular testing and maintenance.

After the release of the main bell wire, guide wires, and umbilical and ballast weight or weights, the diving bell shall exhibit positive buoyancy when loaded to the maximum service weight and with the trunk or trunks flooded. Under these circumstances, the diving bell shall have sufficient stability to remain upright. Consideration shall be given during the risk assessment, as required in [subsection 1-11](#), to the ascent rate and impact on surface vessels and structures.

6-2.11.5 Functional Testing. Functional testing shall be carried out to demonstrate and document proper operation of all emergency recovery functions.

6-3 PRESSURE BOUNDARY

6-3.1 Personnel Access Doors/Hatches

The design of doors and hatches shall

- (a) be in accordance with the requirements of [Section 1](#).

(b) have a nominal diameter of at least 24 in. (610 mm) if used as a normal means of personnel ingress or egress.

(c) be provided on each side with a means of opening and closing hatches or doors (i.e., handle).

(d) be operable from both sides of the door or hatch.

(e) be such that reverse overpressurization of the door does not cause catastrophic failure of the locking dog or other similar devices if used.

(f) be such that corrosion or binding due to friction shall be eliminated as far as practical.

(g) be such that opening may not take place when the pressure is not equal on both sides.

(h) take into account dynamic movements and loads on door and hatch operating and hinge mechanisms to verify the structural adequacy and seal tolerance.

(i) provide a means for securing any hinged door or hatch in the fully open position.

(j) preclude unintentional operation of the door or hatch when springs or mechanisms are used to assist in the operation.

(k) ensure that if fluids are used in door or hatch assist mechanisms, they are compatible with the environment.

(l) have a safety interlock system if pressure acts to open or unseat the door or hatch. The safety interlock system shall not permit pressurization of the door or hatch unless the door/hatch closure is fully engaged.

SDC (diving bell) lockout hatches shall be sized to facilitate recovery of a fully dressed and unconscious diver. Larger openings may be necessary to accommodate divers with emergency life-support systems activated. A minimum 28-in. (711-mm) diameter clear opening is required.

6-3.2 Medical/Service Locks

Medical/service locks shall

(a) be designed, fabricated, inspected, certified, and tested in conformance with this Standard

(b) be sized for the purpose intended (e.g., passing food, medicine, emergency supplies, scrubber canisters, diving helmets, and equipment)

(c) have an external means for monitoring, venting, and equalizing pressure to the compartment being serviced or to atmosphere

(d) be provided with a safety interlock to prevent inadvertent opening of the door, cover, or hatch when the pressure in the medical/service lock acts to open the door, cover, or hatch

6-3.3 Closures

Clamps and closure devices used to couple PVHOs shall

(a) be designed, fabricated, inspected, tested, and certified in accordance with [Section 1](#)

(b) be designed for vessel dynamic movements and include sufficient supports to carry the weight of the clamps while in the open position

(c) be fitted as per requirements in [para. 6-3.4](#) where trunks or tunnels are created by use of clamps and closures

(d) be provided with a positive safety interlock in accordance with ASME BPVC, Section VIII

(e) incorporate a manual system to allow clamp opening on failure of the primary operating system if the primary system is a powered system

6-3.4 Quick-Acting Closures for Diving Bells and Hyperbaric Evacuation Systems

6-3.4.1 General. These requirements are applicable to quick-acting closures that facilitate the connection and disconnection of diving bells and evacuation systems to and from a main diving system for the purpose of diver transfer under pressure.

6-3.4.2 Design

(a) The quick-acting closure shall be designed to connect and disconnect the diving bell and emergency evacuation system under all operational conditions as detailed in the User's Design Specification.

(b) The quick-acting closure shall be provided with a safety interlock to prevent accidental opening in accordance with ASME BPVC, Section VIII, Division 1, UG-35.2.

(c) The quick-acting closure safety interlock shall also prevent pressurization until the closure mechanism is fully engaged.

(d) When power-actuating systems are used for mating operations, a manual backup actuation system shall be provided for use in the event of a system power or switching failure. The manual backup system shall require two mutually independent actions for operation.

(e) An interlock system with visual indicator shall be provided to prevent operation of the handling system while mated. The interlock system shall prevent activation of the handling system until the quick-acting closure is in the fully open position.

6-3.5 Trunks and Tunnels

Trunks and tunnels incorporated in or created by the coupling of PVHOs shall

(a) be designed, fabricated, inspected, tested, and certified in accordance with [Section 1](#)

(b) have a minimum internal diameter of 24 in. (610 mm)

(c) have an external means for monitoring, venting, and equalizing pressure when connected to an adjacent compartment or atmospheric pressure

(d) provide hand- and/or footholds in trunks or tunnels exceeding 36 in. (914 mm) in length

6-3.6 Viewports

All viewports shall meet the requirements of [Section 2](#). Viewports shall be provided with protection suitable for the use intended.

6-3.7 Lighting Devices

Interior lighting devices shall be rated for the PVHO's MAWP. Exterior light-transmitting devices that act as part of the PVHO pressure boundary shall meet the requirements of [Section 2](#).

6-3.8 Service Penetrators

Service penetrators shall

- (a) be equipped with valves on both sides of the penetrator and be installed as close to the PVHO hull penetration as possible
- (b) have a MAWP equal to or greater than that of the PVHO
- (c) be able to withstand maximum internal and external pressures
- (d) be compatible with the intended service
- (e) be suitable for the effects of chemical reactions
- (f) be suitable for the effects of temperature
- (g) be suitable for the effects of corrosion
- (h) have suitable protection to areas subject to impacts during operation or transportation
- (i) be accessible for inspection

6-3.9 Electrical Penetrators

Electrical service and instrumentation penetrators shall

- (a) be designed for the service intended
- (b) be constructed from materials suitable for the service intended, including the effects of corrosion
- (c) have a design pressure and temperature rating equal to or greater than the PVHO MAWP and temperature
- (d) be gas-/watertight even in the event of damage to the connecting cable
- (e) be designed for both internal and external pressure when used in PVHOs that are rated for internal and external pressure (e.g., diving bell)

6-3.10 Fiber-Optic Penetrators

Fiber-optic penetrators shall meet the mechanical criteria as described for electrical penetrators.

6-4 SYSTEMS

6-4.1 Life-Support Systems

6-4.1.1 General. All PVHOs shall have

- (a) sufficient gas supply for normal and emergency requirements
- (b) the ability to monitor and control the depth
- (c) the ability to maintain a life-sustaining breathable environment

(d) the ability to monitor oxygen and carbon-dioxide levels of the breathing environment if the PVHO's life-sustaining breathable environment is maintained by carbon dioxide scrubbing.

6-4.1.2 Unventilated PVHOs. Unventilated PVHOs shall have a means of injecting oxygen, removing carbon dioxide, and controlling both humidity and temperature levels for the purpose of maintaining a life-sustaining environment.

6-4.1.3 Oxygen Supply

(a) If the User's Design Specification requires the injection of oxygen into a chamber, a means for the controlled injection of oxygen shall be provided.

(b) The system shall be designed to ensure safe and reliable operation under all normal and emergency operating and environmental conditions, as defined in the User's Design Specification.

(c) The system shall be designed to ensure the volume of oxygen injected into any PVHO during an injection cycle will not increase the partial pressure of oxygen (PPO₂) in that PVHO beyond the limits defined in the exposure tables employed.

(d) Visual indicators shall be provided and shall clearly display the functional status of the system. Audio alarms shall be provided to alert personnel in the event of a system or a parameter exceeding allowable limits. Both audio and visual indicators shall be capable of operating under the normal and emergency conditions, as defined in the User's Design Specification. In the case of internally mounted makeup systems operated by the chamber occupants, with a predetermined injection volume per cycle, only a visual indicator is required.

(e) A means of monitoring the PPO₂ shall be provided for each occupied compartment of every PVHO forming part of the system, as defined in the User's Design Specification.

6-4.1.4 Carbon Dioxide Removal. For unventilated PVHOs, each occupied compartment shall be provided with suitable equipment for carbon dioxide removal. This equipment shall comply with the following:

(a) The carbon dioxide removal equipment shall be designed to ensure safe and reliable operation under all normal and emergency operating and environmental conditions, as defined in the User's Design Specification.

(b) The carbon dioxide removal equipment shall be capable of maintaining the partial pressure of carbon dioxide (PPCO₂) at or below the following limits:

(1) 0.005 atmosphere absolute (ata) under normal operating conditions

(2) 0.015 ata under emergency operating conditions

(c) The carbon dioxide removal equipment shall be designed for the carbon dioxide production rate or rates specified in the User's Design Specification, which

shall not be lower than 0.115 lb (0.0523 kg) per hour per person.

(d) The carbon dioxide removal equipment shall be provided with full redundancy.

(e) Materials used for the carbon dioxide removal equipment shall be compatible with the carbon dioxide removal agent and shall be corrosion resistant. In addition, the toxicity of these materials shall be considered.

(f) Canisters, panels, or curtains used for holding the carbon dioxide removal agent shall be designed for ease of replacement, without the need for any special tools.

(g) Where solid adsorbents are used as the carbon dioxide removal agent, they shall be the low-dusting type. Solid adsorbents shall be stored in containers free of moisture.

(h) Where lithium hydroxide (LiOH) is used as the carbon dioxide removal agent, the canisters, panels, or curtains holding the LiOH shall be designed to prevent LiOH dust from escaping, or LiOH drippings from falling on personnel or equipment. These canisters, panels, or curtains shall be replaceable as complete units.

(i) Where required by the User's Design Specification, adequate heating shall be provided to maintain the temperature of the carbon dioxide removal agent above the minimum limits specified by the manufacturer of the removal agent.

6-4.1.5 Gas Storage Cylinders and Volume Tanks

6-4.1.5.1 Gas Storage Cylinders. Individual cylinders or multiple cylinders grouped together by means of a manifold to form a cylinder bank shall be provided with

(a) a readily accessible isolation valve to stop gas flow to the system. This valve shall be rated for the maximum allowable working pressure (MAWP) of the cylinder.

(b) a protective device to relieve excess pressure. The relieving device shall meet the requirements of the applicable cylinder standard.

(c) clear labeling as to content in accordance with a recognized national or international standard.

(d) a means of eliminating moisture when used for storing reclaimed gases.

(e) moisture separators and filters that may be used to ensure no moisture enters the system.

(f) a means of monitoring internal pressure.

6-4.1.5.2 Volume Tanks. Each volume tank shall be provided with

(a) a readily accessible isolation valve to stop gas flow to the system. This valve shall be rated for the MAWP of the volume tank.

(b) a means of periodically draining moisture from the bottom of the tank.

(c) a means of relieving excess pressure.

(d) a method for monitoring internal pressure.

6-4.1.6 Emergency Breathing Systems (EBS)

6-4.1.6.1 EBS Internal to PVHOs

(23)

(a) An emergency breathing system shall be included that provides a life-sustaining breathable medium for every PVHO occupant.

(b) The capacity of the EBS shall be 150% of the time normally required to return every PVHO occupant to a breathable life-sustaining environment. This shall be based on the operational use cases established in the User's Design Specification, unless otherwise approved by the jurisdictional authority on the basis of special operating conditions. Returning to a breathable life-sustaining environment typically entails either returning to a surface ambient environment or correcting conditions to reestablish the primary breathable life-sustaining environment.

(c) The emergency breathing gas shall be supplied to the PVHO occupant from either an emergency surface supply or an onboard emergency life-support system, depending on the application of the PVHO.

(d) The EBS shall be independent from the primary breathing system. The emergency breathing gas shall be compatible with the primary breathing gas and operational depths/pressures set forth in the User's Design Specification. The emergency breathing gas shall be compliant with appropriate breathing gas standards. Where open-circuit systems are used and means to exhaust the PVHO compartment are not present, the effects of increased compartment pressure shall be considered.

(e) Emergency breathing gas shall be supplied to either full-face masks or oral-nasal masks using a built-in breathing system (BIBS), self-contained rebreathers, or other means suitable for supporting life in a contaminated environment, which may contain by-products of a fire. One emergency breathing mask or rebreather per occupant shall be provided in each PVHO compartment. In addition, one reserve breathing mask or rebreather shall be readily available in each PVHO compartment. A minimum of two emergency breathing masks shall be provided in each PVHO lock.

(f) Emergency breathing masks or rebreathers shall be stowed within the PVHO in a manner that allows each occupant to access and don them quickly.

6-4.1.6.2 EBS for Control Stations External to the PVHO (23)

(a) Enclosed dive/sat control stations and local control stations for handling systems shall be provided with an EBS that accommodates all system operators required to perform emergency operations as specified in the User's Design Specification.

(b) Emergency breathing gas shall be supplied to full-face masks using a BIBS, self-contained system, or other means suitable for supporting life in a contaminated environment that may contain the by-products of a fire.

(c) Emergency breathing devices shall be compatible with communication equipment.

(d) The EBS shall be capable of functioning for a sufficient duration, based on the operational use cases as set forth in the User's Design Specification, to enable operators to perform their duties in hazardous environments.

6-4.1.7 Life-Support Monitoring

(a) *General.* For ventilated and unventilated PVHOs, each occupied compartment, except ventilated locks designed for the transfer of personnel, shall be provided with suitable instrumentation for continuously monitoring the oxygen and carbon dioxide concentrations in the compartment atmosphere.

(b) *Unventilated PVHOs.* In addition to (a), unventilated PVHOs shall comply with the following:

(1) Instrumentation for monitoring the oxygen and carbon dioxide concentrations shall be provided with audiovisual alarms to alert personnel when the monitored parameters are outside their allowable limits.

(2) Where means are provided to control the temperature and humidity of the occupied compartment, instrumentation shall also be provided to monitor the temperature and relative humidity of the compartment.

(3) Life-support monitoring instrumentation shall be provided in duplicate or an alternative means of monitoring shall be provided.

(4) Electrically operated life-support monitoring instrumentation that is powered externally (i.e., having no self-contained batteries) shall be provided with an uninterruptible power supply (UPS) for maintaining continuity of power in the event of primary power supply failure.

(5) Where applicable, the design of the life-support monitoring instrumentation shall permit calibration.

6-4.2 Sanitary Systems

6-4.2.1 All diving PVHO systems designed for extended occupancy shall be outfitted with the following system capable of supporting the sanitary needs of the occupants:

(a) Chambers designed for occupancy not exceeding 24 hr shall have provisions for handling sanitary waste and handwashing facilities.

(b) Chambers designed for occupancy in excess of 24 hr, except those used exclusively for hyperbaric rescue, shall incorporate a flushing toilet, handwashing sink, and shower with running water and drain facilities.

6-4.2.2 The flushing toilet shall be provided with the following:

(a) a source of water capable of being delivered at a pressure adequate to ensure sufficient flow into the chamber at its maximum operating pressure

(b) one or more interlocks to prevent actuation while the occupant is seated

(c) an actuation that shall require at least two distinct and separate sequential actions by the occupant

(d) a flushing system that shall be designed to limit the volume of gas exhausted with each actuation

(e) an effluent drain that shall be routed to an external holding tank

(f) a toilet seat that must include a standoff to ensure that a complete seal between the toilet bowl and user cannot be achieved

6-4.2.3 The handwashing sink and shower system shall be provided with the following:

(a) a source of water capable of being delivered at a pressure adequate to ensure sufficient flow into the chamber at its maximum working pressure

(b) a water drain that shall be routed to an external holding tank

(c) a drain that may be manual or automatic

(d) a drain system that shall include a standoff that ensures that a complete seal between the drain and user cannot occur

6-4.2.4 The holding tank shall be provided with the following:

(a) pilot and vent valves to ensure it cannot exceed chamber pressure during system actuation or chamber decompression.

(b) a pressure gauge indicating tank pressure.

(c) a level-indicating device and normally closed fail-to-safety actuating drain valve.

(d) a drain line connecting the holding tank with the appropriate system on the vessel or land-based facility sewerage system. This external drain shall be designed to prevent impermissible pressurization of the external drainage system.

6-4.3 Electrical Systems

6-4.3.1 General. Electrical systems, including power supply arrangements, shall be designed for the environment in which they will operate in order to minimize the risk of fires, explosions, electrical shocks, emission of toxic gases, and galvanic action on the PVHOs.

For electrical equipment exposed to diving conditions, the designer shall consider pressure and pressure cycling, humidity, moisture, temperature, oxygen concentration, hydrogen concentration, and cable flammability.

Electrical systems installed within PVHOs shall be limited to those necessary for the safe operation of the PVHO and the monitoring of its occupants.

Measures shall be taken to minimize any electrical hazards to divers and personnel in the diving system.

6-4.3.2 Power Supplies

6-4.3.2.1 General. Diving systems shall be provided with independent main and emergency sources of electrical power.

6-4.3.2.2 Main Power. The main source of electrical power shall have sufficient capacity for all anticipated diving operations.

6-4.3.2.3 Emergency Power. The emergency source of power shall have sufficient capacity to supply the applicable emergency electrical loads for the safe termination of the diving operations. The emergency source of electrical power shall be located so as to ensure its functioning in the event of failure of the main source of power.

6-4.3.2.4 Reserve Power. In addition to the main and emergency sources of power, diving bells/personnel transfer capsules and hyperbaric rescue chambers/lifeboats shall be provided with a suitable onboard reserve source of power. This onboard source of power shall be capable of feeding the applicable emergency equipment, e.g., the emergency life-support equipment, communication equipment, and internal lighting. For diving bells/personnel transfer capsules, the onboard source of power shall have sufficient capacity to supply power for at least 24 hr. For hyperbaric rescue chambers/lifeboats, the onboard source of power shall have sufficient capacity to supply power for at least 72 hr.

6-4.3.3 Distribution

6-4.3.3.1 General. The pressure boundary of PVHOs shall not be used as a current-carrying conductor. All electrical power distribution systems shall be ungrounded and insulated to minimize the occurrence of faults and stray currents that may create galvanic corrosion.

6-4.3.3.2 Voltage. The maximum voltages for PVHOs shall not exceed those specified below.

Application	Maximum Voltage	Nominal Voltage
AC with circuit protection device	250	220
AC without circuit protection device	7.5	6
DC with circuit protection device	285	250
DC without circuit protection device	30	24

6-4.3.3.3 Ground Detectors. Ground detectors or interrupters shall be provided for systems with a line voltage above 7.5 V AC or 30 V DC.

6-4.3.3.4 Cables and Wiring. Cables and wiring shall meet a recognized national or international electrical standard (such as IEC standards or IEEE 45). They shall be flame retardant and shall comply with the flammability criteria of a recognized national or international standard. Cables and wiring within the pressure boundary of PVHOs shall be of the low-smoke, low/zero-halogen type.

6-4.3.3.5 Cable Separation. Cables and wiring of circuits supplied by different voltages and by main and emergency circuits shall be effectively separated from each other.

6-4.3.3.6 Power Supply Conductors. All power supply conductors from the same main or emergency power source shall be spaced sufficiently to prevent damaging currents and shall not pass through the same penetrator or connection in a pressure boundary unless

(a) it can be shown that there is little risk of short-circuiting or tracking between the conductors and

(b) the voltages and currents are of such an order that, in the event of failure in any way of the conductor insulation, the penetrating device's gas and watertight integrity are maintained

6-4.3.3.7 Cables Subjected to External Pressure.

Materials for uncompensated cable and wiring insulation subjected to external pressure shall be capable of withstanding a hydrostatic pressure of 1.5 times the design pressure of the diving system. Submerged cable assemblies shall be tested by the continuous application of an alternating current voltage of at least 500 V for 1 min. This shall be performed with the jacket exposed to seawater. The quality of the assembly should be such that the leakage current will neither prevent proper operation of the systems nor expose personnel to unsafe voltages.

6-4.3.4 Circuit Protection

6-4.3.4.1 Circuit Protection Devices. Power cables shall be protected from overloads and short circuits by protective devices that isolate all conductors in the overloaded circuit. Circuit protection devices shall meet a recognized national or international electrical standard. Fuses and thermal circuit breakers are not permitted in a helium-oxygen environment.

6-4.3.4.2 Pressure Boundary Power Penetrations.

All power cables passing through the pressure boundaries of PVHOs shall be adequately protected by circuit breakers or fuses against overload and short circuits. The circuit breakers or fuses shall be located on the power-source side of the pressure boundaries and shall have the ability to open the circuits quickly to prevent damage to the gas-/watertight integrity of the electrical penetrators.

6-4.3.5 Battery Compartments

6-4.3.5.1 Sources of Ignition. Design and procedural precautions shall be taken to eliminate all potential sources of ignition within battery compartments.

6-4.3.5.2 Hydrogen Levels. For batteries capable of generating hydrogen gas, design features shall be in place to avoid the potential hazards arising from hydrogen accumulation. Protective devices located in battery

compartments containing these batteries shall not provide an ignition source for the hydrogen gas.

6-4.3.5.3 Electrical Equipment. All electrical equipment in battery compartments containing batteries capable of generating hydrogen gas shall be of the explosion-proof or intrinsically safe type.

6-4.4 Lighting Systems

Sufficient lighting shall be provided for the safe operation of the PVHO.

6-4.5 Communication Systems

6-4.5.1 All diving PVHOs shall be equipped with communications between the PVHO operator or operators and internal occupants. Communication systems shall consist of both a primary and a secondary system. The secondary system shall consist of a sound-powered telephone or other methods that operate in the event of power loss. Communication systems shall be included in each occupiable lock of the PVHO. In the event that the control operator or the occupants do not have direct visual contact, the secondary system shall be equipped with a signal device, e.g., an audible annunciator, to alert the operator or the occupants.

- (23) **6-4.5.2** When helium mixtures are used in the breathing medium, a helium unscrambler shall be provided.

6-4.5.3 Diving bells shall be equipped with a through-water communications system rated for the maximum operational distance from the PVHO operator or operators.

6-4.6 Fire Protection and Detection Systems

6-4.6.1 Fire Safety. The construction of the PVHO shall be such as to minimize hazards of smoke and fire. Systems shall be designed and equipped to avoid sources of ignition and minimize flammable materials. Toxicity of combustion products and flame-spread characteristics shall be considered in material selection.

6-4.6.2 Fire Suppression. The system designer shall address fire suppression. A formal risk analysis shall be conducted to establish the performance requirements for the system. The designer may elect to provide a passive-prevention or an active-suppression system.

Active-suppression systems shall be tested for operation under the full range of required suppression system pressures. Extinguishing systems shall be compatible with life-support requirements of the PVHO. Carbon dioxide and dry powder are not suitable for use as extinguishing agents in enclosed environments.

6-5 HANDLING SYSTEMS

6-5.1 General

This subsection provides the additional requirements for the handling, deployment, and emergency recovery of diving bells, which are also known as personnel transfer capsules (PTCs).

Handling systems for diving bells shall comply with at least one of the codes and standards required by an International Association of Classification Societies (IACS) member classification society and the applicable organization or organizations having regulatory and jurisdictional authority.

Ropes and loose gear items (blocks, sheaves, shackles, etc.) used on handling systems shall comply with the codes and standards recognized by the applicable organization or organizations having regulatory and/or jurisdictional authority.

6-5.2 Design

(23)

Diving systems shall be provided with a handling system as defined. The handling system shall be capable of safely moving the diving bell and its occupants (divers) between the work location and surface compression chamber or chambers.

The handling system shall be designed for the defined rated (or safe working) load requirements and the applicable design loads specified under [para. 6-2.2](#). Additionally, the handling system shall meet the performance criteria given in the User's Design Specification.

The handling system shall comply with the handling system design load requirements as defined in [para. 6-2.2](#) and meet the performance criteria given in the User's Design Specification.

For the eventuality of a single component failure in the main handling system, a secondary system shall be provided to enable the divers to be brought back to the surface compression chamber. This secondary system shall be powered independently from the main handling system.

Handling system winches shall be provided with two independent braking mechanisms. The braking mechanisms shall be designed to hold 100% of the design load of the handling system.

Braking mechanisms shall be designed to fail-to-safety and set automatically upon loss of power to the winch.

Lowering of loads shall be controlled by powered drives independent of the braking mechanisms. Powered drives shall be designed to handle 100% of the design load of the handling system.

The handling system shall be provided with the means to stabilize the diving bell and prevent excessive rotation during ascent/descent through the water column. It also shall be provided with the means to prevent the diving bell from contacting the vessel's hull or any elements of the

handling system during handling operations between the surface compression chambers and keel depth of the vessel.

6-5.3 Test and Trials

The fully assembled handling system shall be statically load tested to 100% of the design load of the handling system.

After installation on board the vessel, the handling system shall be functionally tested at the maximum rated speed of the system. Satisfactory operation of the complete handling system, including the powered drives and brakes, shall be demonstrated and shown to meet the requirements of [para. 6-4.1.2](#).

6-6 HYPERBARIC EVACUATION SYSTEMS

(23) 6-6.1 General

All diving systems used to support saturation diving operations shall be equipped with a hyperbaric evacuation system (HES) capable of providing a means of evacuation for the maximum number of divers that the diving system is capable of accommodating. As a minimum, the HES shall include a hyperbaric evacuation unit (HEU), its launching system, and a portable life-support package (LSP).

(a) The HEU shall be capable of maintaining the divers at the appropriate pressure, with adequate life support for a minimum of 72 hr.

(b) The HEU shall be capable of operating at the maximum operating pressure of the diving system as set forth in the User's Design Specification in accordance with [subsection 1-4](#).

(c) The HEU shall be readily accessible to all occupants of the saturation diving system. It shall be mated to the diving system by means of trunking and a quick-acting closure in accordance with [paras. 6-3.4](#) and [6-3.5](#).

(d) A launching system in accordance with [para. 6-6.4](#) shall be provided for each HEU.

(e) A clearly written Hyperbaric Evacuation Plan detailing the procedures required for maintenance, testing, training, and operations prior to, during, and following hyperbaric evacuation shall be provided. This plan should list specific responsibilities for each job title associated with the evacuation. The plan shall also include the operational procedures for the evacuation of divers stored at different pressures.

(f) Following the initial evacuation, the diving system operator shall arrange for transportation of the HEU and its occupants to a designated location (safe haven), where the appropriate facilities shall be available for decompressing the HEU occupants to surface pressure in a safe and controlled manner.

6-6.2 Hyperbaric Evacuation Unit User Requirements

6-6.2.1 There are two common forms of HEUs, as follows:

(a) *Hyperbaric Rescue Chamber (HRC)*. An HRC is a PVHO that has been specifically designed and outfitted with the equipment and life-support systems necessary to evacuate divers from a ship, barge, semisubmersible, or fixed structure, and maintain life-supporting conditions for the maximum number of occupants at the maximum operating pressure of the diving system for a period of not less than 72 hr. An HRC generally does not have onboard propulsion and is typically towed or transported to its safe haven.

(b) *Self-Propelled Hyperbaric Lifeboat (SPHL)*. An SPHL is a PVHO integrated into or forming part of a purpose-built, SOLAS¹-compliant self-propelled lifeboat outfitted with the equipment and life-support systems necessary to evacuate divers and maintain life-supporting conditions for the maximum number of occupants at the maximum operating pressure of the diving system for a period of not less than 72 hr.

6-6.2.2 The HEU shall be fitted with and/or carry onboard the following:

(a) individual seats for each occupant, outfitted with a positive means to prevent injury to the occupants during launch and recovery, and in rough weather conditions.

(b) a clearly written operation procedure manual, detailing preparation for evacuation, the setup and operation of the environmental control equipment, and all other life-support equipment and systems.

(c) a list of tapping codes for nonverbal communication with personnel outside the evacuation chamber in the absence or failure of two-way radio communications.

(d) onboard oxygen to support the metabolic oxygen requirements of the maximum number of occupants for a period of 72 hr, based on a minimum flow of 0.017 standard ft³/min (0.48 standard L/min) per occupant. Special care shall be taken to ensure adequate distribution and mixing of metabolic oxygen within the chamber.

(e) a primary and secondary means of removing carbon dioxide (CO₂) from the atmosphere, including, but not limited to, battery- and lung-powered systems with absorbent chemicals sufficient to remove the CO₂ output from the maximum number of occupants for a period of 72 hr.

(f) a primary and secondary means of chamber lighting. The primary lighting power source shall be sufficient to maintain primary lighting for a period of 72 hr. If the secondary means of lighting is powered, it too shall be sufficient for 72 hr.

¹ SOLAS is the IMO Convention on the Safety of Life at Sea.

(g) a tool kit that is capable of supporting minor repairs and maintenance inside the chamber. The tool kit shall be clearly marked and located to be easily accessible. For self-propelled lifeboats, an additional external tool kit shall be provided.

(h) a means of monitoring the chamber environment, including pressure, temperature, humidity, oxygen (O_2), and carbon dioxide (CO_2). Independent backup for O_2 and CO_2 monitoring shall be provided.

(i) a system for heating/cooling the PVHO to maintain physiologically acceptable conditions throughout the operating range of the evacuation system. Thermally protective clothing may also be provided as a passive backup system to the heating system.

(j) power sufficient to support all life-critical powered systems for a period of 72 hr.

(k) a medical kit that is suitable for at least minor injuries, with sick bags and medications for motion sickness. The kit shall be stored in a suitable container, clearly marked, and located to be easily accessible.

(l) a means of transferring equipment and supplies into and out of the chamber under pressure.

(m) meals for the maximum number of occupants for a period of 72 hr, stored in a clearly marked, easily accessible location. Each meal shall provide a minimum equivalent of 800 calories per 24-hr period per occupant. Meals that use exothermic chemical means, flames, electrical resistance, or any other heating means not suitable for use in pressurized, oxygen-enriched environments shall not be used.

(n) a minimum of 6 pints (3 L) of drinking water per 24-hr period per occupant for the maximum number of occupants for a period of 72 hr. The water shall be stored in a secure, clearly marked, and easily accessible location.

(o) a means of managing human waste. The system shall be capable of preventing accidental spillage during launch or recovery, or in rough weather conditions.

(p) an internationally recognized marine emergency position-indicating radio beacon (EPIRB).

(q) HEU external surfaces colored international orange.

(r) signs indicating DIVERS IN DISTRESS, located on the top and sides in three places, and sized and marked in accordance with International Maritime Organization (IMO) Resolution A.692(17) (see [Figure 6-6.2.2-1](#)).

(s) warning information located on the sides at or above the waterline in accordance with IMO Resolution A.692(17), as shown in [Figure 6-6.2.2-2](#).

(t) a radar reflector, reflective tape, and a strobe light, installed to facilitate system location.

(u) lifting slings and towing bridles, securely stowed and labeled. The total in-air weight of the evacuation system including personnel and equipment shall be prominently displayed. In addition, each lifting point shall be clearly marked with its safe working load.

(v) a communication system capable of permitting two-way voice communication between the chamber occupants and outside attendants.

(w) a sound-powered phone secondary communication system.

(x) a waterproof emergency services interface point protected from damage by a reinforced cover. This interface shall contain connection points for power, gas/oxygen, and the internal chamber two-way voice communication system, a sound-powered phone, a copy of the operation procedure manual, a set of the tapping codes, and a complete inventory of supplies. Consideration shall be given to providing a waterproof handheld VHF radio for use by rescuing personnel.

(y) at least one viewport that provides visual access to the occupants.

6-6.3 Life-Support Package (LSP)

Each hyperbaric evacuation system shall have a separate, portable life-support package that provides all interfaces and services necessary to maintain, monitor, and control the chamber environment and conduct safe decompression of the evacuated divers.

Based on the maximum number of occupants, and the decompression duration from maximum rated depth of the HEU, the LSP shall be provided with the following:

(a) clearly written operational procedures detailing the decompression phase of the evacuation, as well as the setup and operation of the environmental control equipment and all other associated life-support equipment and systems.

(b) a list of tapping codes for nonverbal communication with personnel outside the HEU, in the absence or failure of two-way radio communications.

(c) a manifold designed to control pressurization, exhaust, oxygen (O_2) makeup and treatment mixes, as well as the life-support gas samples for analysis.

(d) a means of monitoring the HEU internal environment, including pressure, temperature, humidity, oxygen (O_2), and carbon dioxide (CO_2). Independent backup for O_2 and CO_2 monitoring shall be provided.

(e) a hard-wired communication system between the HEU and the LSP operator.

(f) an environmental control system for heating/cooling the HEU to maintain physiologically acceptable conditions throughout duration of the decompression.

(g) power-generating equipment sufficient to support electrical requirements for the duration of the decompression.

(h) a sufficient quantity of life-support gases (e.g., oxygen and helium) to support decompression, as well as treatment. In calculating the quantity of life-support gases required, the designer shall take into account the quantity of all life-support gases required for system makeup, as well as for completing the worst-case scenario treatment tables for the maximum number of occupants.

(i) interconnecting hose and cable bundles between the LSP and HEU that are capable of supplying the HEU with life-support gases and electrical power, as well as facilitating communication, environmental control, and internal environmental monitoring.

(j) a medical kit that is suitable for major injuries, including an appropriate trauma kit and relevant medical manuals.

(k) water and meals in a quantity sufficient to support both the occupants in the HEU and the LSP operating personnel for the duration of the decompression.

(l) a tool kit and repair manuals to facilitate maintenance and repair of all associated support equipment.

(m) absorbent chemicals sufficient to remove the CO₂ output from the maximum number of occupants of the HEU for the duration of the decompression.

6-6.4 Hyperbaric Evacuation Launch Systems

(a) Each HEU shall be provided with a dedicated launch system that serves as the primary means for the safe and timely evacuation of the divers.

(b) HEU launch systems shall comply with the applicable requirements of IMO Resolution A.692(17) and this Standard.

(c) Launch systems shall be designed to safely launch the HEU when the ship or support facility is under conditions of 20 deg list and 10 deg trim either way, in the fully loaded or unloaded condition.

(d) The HEU launch system may be powered by the vessel or support facility power supply, provided the vessel or facility power supply is capable of meeting all power requirements of the system.

(e) A secondary means that depends on either stored mechanical power or gravity to safely launch the HEU shall also be provided.

(f) Launch systems using wire rope for launching the HEU shall provide means for releasing the wire rope after the HEU is afloat.

(g) The wire rope shall be rotation-resistant and corrosion-resistant steel wire rope.

(h) For launch systems installed on a ship or support facility, the length of the wire rope shall be sufficient to allow the HEU to be launched in water when the ship or support facility is at its lightest draft, and under conditions of 20 deg list and 10 deg trim either way, in the fully loaded or unloaded condition.

(23) 6-6.5 HEU Interfaces

HEU interfaces shall comply with the requirements of this paragraph, as well as the User's Design Specification (see [subsection 1-4](#)).

6-6.5.1 Quick Release. The interfaces between the HEU and the parent saturation diving system, including but not limited to the service connections, manway

flange connections, and tiedown fixtures, shall be designed for quick release.

6-6.5.2 Standardized Interfaces. To facilitate interface compatibility between HEUs and hyperbaric reception facilities (HRFs), designers shall consider using standardized HEU interfaces such as those outlined by the International Marine Contractors Association (IMCA) in IMCA D051.²

6-7 TESTING AND TRIALS

All diving PVHO systems shall be functionally and physically tested prior to operational service. Testing and trials shall be conducted on all parts, components, and systems for a fully functional and operational diving system. All testing and trials shall be carried out by a competent person in accordance with the User's Design Specification's stipulating acceptance criteria. In many cases a third party may be required to witness and certify that the testing meets the requirements of the jurisdictional authority.

If manned testing is to be performed, the following shall be conducted first:

(a) unmanned testing to ensure proper operational performance of the system

(b) a hazard analysis to identify and mitigate risks associated with manned testing

(c) a pretest safety meeting with all personnel involved with the test

As a minimum, the tests in [paras. 6-7.1](#) and [6-7.2](#) shall be performed after installation on board the vessel or facility.

6-7.1 System Pressure Tests

The following tests shall be performed:

(a) internal/external pressurization test to full operational pressure (external pressure test may be included on functional testing during sea trials)

(b) pressure test of all hatches, quick-acting closures, and sealing surfaces at maximum and minimum pressures

(c) pressurization/leak test of internal and external pressure-retaining components, including, but not limited to, control manifolds, interconnecting hoses and piping, air and gas storage systems, and all primary and emergency breathing systems

6-7.2 System Functional Tests

6-7.2.1 Handling Systems (Including Those for Diving Bells, Diving Stages, and HEUs)

(a) The fully assembled handling system shall be statically load tested to 100% of the design load of the handling system. After installation on board the vessel, the handling system shall be functionally tested at its rated load at the

² IMCA D051 provides interface standardization recommendations that address the following aspects: towing, lifting, locating, mating, and service connections.

maximum rated speed of the system. Satisfactory operation of the complete handling system, including the powered drives and brakes, shall be demonstrated, and shown to meet the requirements of [subsection 6-5](#) or [para. 6-6.4](#), as applicable.

(b) For diving bells and diving stages, functional testing shall be carried out to demonstrate and document proper operation of the secondary means of recovery.

(c) Testing shall be carried out to demonstrate the functioning of quick-acting closures under all operational conditions. This testing shall also demonstrate and document proper operation of interlock devices on the quick-acting closures.

(d) A test launch of the HEU shall be carried out to demonstrate and document proper mating, detachment, and deployment operations from the parent diving system, including detachment of the quick-acting closures and release hooks. The test shall be carried out with the HEU weighted to simulate the maximum load condition. The test shall demonstrate that the HEU remains upright and positively buoyant following release.

6-7.2.2 Piping, Electrical, and Control Systems

(a) Functional testing of the piping, electrical, and control systems shall be carried out to ensure proper functioning of all systems, including backup and emergency systems, and to demonstrate the absence of any unacceptable hazards as required in [subsection 1-11](#).


(b) A test shall be carried out to demonstrate the capacity of the heating/cooling system to maintain thermal balance over the range of environmental conditions as defined in the User's Design Specification.

(c) A test shall be carried out to demonstrate the capacity of the O₂ makeup system to compensate for the metabolic oxygen consumption of the maximum number of occupants for which the system is rated.

(d) A test shall be carried out to demonstrate the capacity of the primary CO₂ removal system to remove the total metabolic CO₂ output of the maximum number of occupants for which the system is rated.

(e) A test shall be carried out to demonstrate that the emergency evacuation life-support package (LSP) is able to be attached and used to maintain, monitor, and control the functional operation of the chamber including decompression.

Figure 6-6.2.2-1
Placement and Design of Markings for Hyperbaric Evacuation Units Designed to Float in Water



GENERAL NOTE: From IMO Resolution A.692(17).

Figure 6-6.2.2-2
Markings for Hyperbaric Evacuation Units Designed to Float in Water

UNLESS SPECIALIZED DIVING ASSISTANCE IS AVAILABLE:

DO NOT touch any valves or other controls

DO NOT take in tow unless in imminent danger

DO NOT try to get the occupants out

DO NOT connect any gas, air, water, or other supplies

DO NOT attempt to give food, drinks, or medical supplies to the occupants

DO NOT open any hatches

GENERAL NOTE: From IMO Resolution A.692(17).

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

Section 7

Submersibles

7-1 GENERAL

7-1.1 Scope

This Section, along with [Sections 1](#) through [4](#), provides the requirements for the design, assembly, inspection, testing, and certification of PVHOs used in manned submersibles including tourist submersibles. For diver lockout chambers, see [Section 6](#).

7-1.2 General Requirements

The PVHO shall be designed, fabricated, assembled, inspected, tested, and certified in accordance with this Section and [Sections 1](#) through [4](#).

7-1.2.1 Single Failure. The basic requirement for a submersible craft design is that, in the event of any single failure, the craft can return to the surface without external assistance. Appropriate backup systems and equipment shall be incorporated to meet this general design requirement.

7-1.2.2 Operating Conditions. The submersible shall be designed for, and be capable of, operating in the service conditions and temperature ranges envisaged both on the surface and under water.

The design criteria provided herein apply to submersibles operating in waters with a seabed depth not greater than the craft's rated depth. Consideration may be given for operations in areas with a greater seabed depth on the basis of safety evaluations demonstrating the adequacy of provisions and/or procedures.

7-1.3 User's Design Specification

The user, agent on the user's behalf, designer, or the manufacturer shall provide or cause to be written a User's Design Specification. This specification shall set forth the requirements as to the intended use of the submersible and operating and environmental conditions in such detail as to constitute an adequate basis for designing, fabricating, inspecting, and testing the system as necessary to comply with this Standard. The User's Design Specification shall include, as a minimum, the following:

- (a) maximum operating depth
- (b) maximum operating sea state
- (c) maximum operating current

(d) normal and maximum speed while surfaced and submerged

(e) minimum and maximum allowable operating temperatures (internal and external)

(f) minimum and maximum onboard personnel

(g) maximum mission time

(h) maximum lifting weight

(i) payload

(j) maximum towing speed

(k) normal, reserve, and emergency power capacities

(l) normal, reserve, and emergency life-support capacities

7-1.4 Design Certification

Conformance of the completed PVHO to the requirements of this Section and the User's Design Specification shall be established by one of the following procedures:

(a) *Professional Engineer Certification.* A Professional Engineer, registered in one or more of the U.S. states or the provinces of Canada, or the equivalent in other countries, experienced in the design of submarines, shall certify that the PVHO was designed either by the engineer or under the engineer's supervision, or that the engineer has thoroughly reviewed a design prepared by others, and that to the best of the engineer's knowledge, within the User's Design Specification, the PVHO design complies with this Section.

(b) *Independent Third-Party Certification.* The PVHO shall be reviewed by an independent classification society competent in pressure vessels for human occupancy,¹ and such organization shall provide a certification that, within the User's Design Specification, the PVHO design complies with this Section.

7-1.5 Documentation

The manufacturer shall retain a copy of the User's Design Specification, the Design Certification, and supporting data (test data and material test reports as required by the User's Design Specification, window certificates) for at least 5 yr.

A copy of the following shall be provided to the user:

- (a) User's Design Specification
- (b) window certificates
- (c) any classification society certifications

¹ Systems and manned submersibles.

- (d) vessel drawings necessary for the maintenance, inspection, and repair of the PVHO
- (e) operations manual

(23) 7-1.6 Operations Manual

An operations manual describing normal and emergency operational procedures shall be provided. In addition to items listed in [para. 7-1.3](#), the manual shall include

- (a) systems description
- (b) operational check-off list (list shall include equipment requiring operational status verification or inspection prior to each dive/operation)
- (c) special restrictions based on uniqueness of the design and operating conditions
- (d) life-support systems descriptions including capacities
- (e) electrical system description
- (f) ballast system description
- (g) fire-suppression system description
- (h) launch and recovery operation procedures
- (i) normal and emergency communications procedures
- (j) emergency response rescue plan (ERP)
 - (1) The ERP should include a list of potential emergency scenarios and actions to be taken, a contact list containing in-house and outside resources, a list of personnel and their roles and responsibilities, and reporting procedures. (Also see ASME PVHO-2, para. 3.2).
 - (2) The ERP should also take into consideration the following, as applicable:
 - (-a) availability of rescue equipment that is rated for the operating depths of the submersible
 - (-b) time necessary for the rescue equipment to reach the rescue site, be prepared for deployment, and descend or ascend through the water column
 - (k) emergency procedures for situations including, but not limited to, the following:
 - (1) power failure
 - (2) break in umbilical cord (if applicable)
 - (3) deballasting/jettisoning
 - (4) loss of communications
 - (5) life-support system malfunction
 - (6) fire
 - (7) entanglement
 - (8) high hydrogen level (if applicable)
 - (9) high oxygen level
 - (10) high carbon dioxide (CO₂) level
 - (11) internal and external oxygen leaks
 - (12) being stranded on the bottom
 - (13) minor flooding
 - (14) specific emergency conditions (characteristic of special types of systems)
 - (15) loss of propulsion
 - (16) deteriorated surface conditions during a dive

7-2 PRESSURE BOUNDARY

7-2.1 General

The pressure boundary of submersibles built to this Section shall be designed and constructed in accordance with [Section 1](#). Other recognized industry standards for the design, construction, and testing of manned submersibles that have been validated through testing and service and that are suitable for the intended service and acceptable to the jurisdiction may also be used where [Section 1](#) does not address industry-specific issues for the design of submersibles.

Testing of the PVHO shall be in accordance with the recognized engineering methods used. As a minimum requirement, such testing shall be 1.25 times the design pressure. The designer is cautioned that specific design requirements may be driven by depth, service, and environment. It is the designer's responsibility to provide a safe design.

7-2.2 Hatches

7-2.2.1 Number, Size, and Location. The following shall be considered when determining the number, size, and location of access hatches:

- (a) evacuation of crew and passengers in an emergency situation
- (b) risks such as fire, smoke, stability of the craft, and possible down-flooding due to adverse sea state

The number of hatches shall not be unnecessarily increased beyond the safe minimum as determined in [\(a\)](#) and [\(b\)](#).

7-2.2.2 Opening, Closing, and Securing. Opening and closing of hatches shall be possible by a single person, in all anticipated operating conditions.

Provisions shall be made for opening/closing hatches from both sides.

Two means, one of which should be visual, shall be available to ensure that hatches are closed and secured prior to diving.

Hatches shall have a means for securing them in the open and closed positions.

7-2.2.3 Equalization. Means shall be available to ensure that pressures on either side of the hatch are equalized prior to opening.

7-2.3 Viewports

Viewports shall comply with [Section 2](#).

7-2.4 Penetrators

7-2.4.1 Mechanical Penetrators. Mechanical penetrators shall be designed such that in the event of failure, the penetrator remains intact and does not allow leakage into the pressure hull.

7-2.4.2 Hull Shut-Off Valves. Any piping systems penetrating the pressure hull shall be equipped with a valve that can be operated manually. These valves shall be mounted directly on the inner side of the hull or on short and strong stub pieces (capable of withstanding anticipated mechanical and pressure loads) fitted between the valve and hull.

7-2.4.3 Testing Electrical Penetrators. Samples of penetrating devices conveying electricity through pressure boundaries shall be tested as indicated below, in the listed sequence of tests. Where applicable, penetrators shall be tested assembled with a length of cable of the type that will be used in the installation. The cable and penetrator assemblies are to show no sign of deficiency during or after the test.

(a) voltage test by separately applying 1 kV plus twice the design voltage for 1 min across each conductor and armor separately under the most unfavorable environmental condition they will be subjected to during service.

(b) hydrostatic test to a pressure of 1.5 times the design pressure repeated six times. The pressure shall be applied to the side that will be under pressure in the actual application and shall be maintained for 20 min after the last cycle.

(c) gas leakage test with cable cut open using air to twice the design pressure or helium to 1.5 times the design pressure.

(d) insulation test to 5 MO at design pressure applying salt water. Tests shall be made between each conductor and armor.

Electrical conductors within the penetrating device shall be of solid material.

(23) **7-2.4.4 Electrical Penetrators.** The positive and negative conductors from a power source shall be spaced sufficiently to prevent damaging currents, and shall not pass through the same penetrating device unless

(a) it can be shown that there is little risk of short circuiting or tracking between conductors

(b) the voltages and currents are of such an order that, in the event of failure in any way of the conductor insulation, the integrity of the penetrating device's water block is maintained

Electrical penetrating devices shall not have any pipes or other system passing through them. Different types of penetrating devices passing through a common plate are acceptable.

7-3 PIPING

7-3.1 Exceptions and Alternatives

7-3.1.1 Relieving Devices. In lieu of subsection 1-8, for PVHOs not internally pressurized, the following shall apply:

(a) A pressure-relieving device shall be used to ensure the internal pressure does not exceed that specified by the designer.

(b) A shutoff valve shall be installed upstream of the pressure-relieving device and shall be accessible to the attendant/pilot monitoring the operation of the PVHO.

(c) Rupture disks shall not be used.

7-3.1.2 User's Design Specification. In lieu of para. 4-1.2, the following information shall be documented on the system assembly drawing, in the operations manual, and/or in the User's Design Specification:

(a) the system maximum allowable working pressure (MAWP)

(b) conditions affecting the requirements for, and amounts of, stored gas reserves

7-3.1.3 Marking. Compliance with para. 4-2.4.4 is required with the exception that the hoses do not have to be tagged or marked with the test pressure or test dates. Hose assemblies shall be tested in accordance with para. 4-2.4.5. Hose testing shall be documented.

7-3.2 Internal and External Pressures

Systems, fittings, and equipment subject to internal or external pressure or a combination of both shall be designed for the worst combination of the above (e.g., external oxygen systems).

7-3.3 Ambient Pressure

Systems, piping, and equipment exposed to ambient sea pressure shall be suitable for the intended service and capable of withstanding all anticipated pressure differentials.

7-3.4 Inaccessible Spaces

Piping passing through spaces inaccessible for maintenance shall be of continuous pipe.

7-3.5 Hull Valves

For piping systems penetrating the occupied pressure hull and open to the sea, a nonreturn valve or shutoff valve shall be provided in addition to that provided in accordance with para. 7-2.4.2.

7-3.6 Plug Valves

Plug valves shall not be used.

7-3.7 Pressure Containers

The volume of a single internal gas source shall be limited in such a way that complete release of its contents will not increase the pressure beyond the safe limit for the craft and its occupants.

Cylinders and pressure vessels mounted externally, which may be depleted while at depth, shall be designed to withstand external pressures equal to the design depth of the submersible.

7-4 ELECTRICAL SYSTEMS

7-4.1 General

All power sources and electrical equipment shall be designed for the environment in which they will operate to minimize the risk of fire, explosion, electrical shock, and emission of toxic gases to personnel and passengers, and galvanic action of the submersible.

The designer shall consider pressure and pressure cycling, humidity, moisture, temperature, oxygen concentration, hydrogen concentration, and cable combustibility.

7-4.2 Power Supplies

7-4.2.1 General. The submersible shall have a separate main and an onboard emergency source of electrical power.

7-4.2.2 Main Power. The main source of electrical power shall have a reserve capacity beyond the normal mission time to supply, where and as appropriate, the following systems for a period of time consistent with the plan to rescue the submarine from its rated depth. The period of time shall in no case be less than 24 hr.

- (a) emergency lighting
- (b) communication equipment
- (c) life-support systems
- (d) environmental monitoring equipment
- (e) essential control systems
- (f) other equipment necessary to sustain life

7-4.2.3 Emergency Power. The emergency source of electrical power shall be located so as to ensure its functioning in the event of fire or other casualty causing failure to the main electrical power source.

The onboard emergency source of electrical power shall have the capacity to supply the systems listed in paras. 7-4.2.2(a), (b), and (d) through (f), plus the emergency life-support system, if electrically supplied, for 150% of the time normally required to reach the surface or 1 hr, whichever is greater, unless otherwise approved on the basis of special operating conditions.

(23) 7-4.3 Electrical Cables

7-4.3.1 Protection. Power cables shall have short-circuit and overload protection. The device connected to power cables passing through a pressure boundary shall have response characteristics that ensure watertight integrity of the electrical penetrators. Protection devices located in the battery compartment shall not provide an ignition source for the hydrogen gas.

7-4.3.2 Main and Emergency Cables. Cables and wiring of circuits supplied by different voltages and by main and emergency circuits shall be effectively separated from each other.

7-4.3.3 Pressure Boundary. The pressure boundary shall not be used as a current-carrying conductor.

7-4.3.4 Grounding. All electrical power distribution systems shall be ungrounded and insulated to minimize the occurrence of faults and stray currents that may create galvanic corrosion.

7-4.3.5 Insulation Material. Materials for uncompensated cable and wiring insulation subjected to external pressure shall be able to withstand a hydrostatic pressure of 1.5 times the design pressure of the submersible. Submerged cable assemblies shall be tested by the continuous application of an alternating current voltage of at least 500 V for 1 min. This shall be performed with the jacket exposed to seawater. The quality of the assembly shall be such that the leakage current will neither prevent proper operation of the systems nor expose personnel to unsafe voltages.

7-4.4 Battery Compartments

7-4.4.1 Sources of Ignition. Design or procedural precautions shall be taken to eliminate all potential sources of ignition within battery compartments.

7-4.4.2 Hydrogen Levels. Design features shall be in place to avoid the potential hazards arising from hydrogen accumulation.

For batteries located within the occupied pressure boundary, hydrogen gas concentrations shall be monitored and maintained at a level below the lower explosive limit.

7-4.5 Emergency Lighting

Internal emergency lighting that is switched on automatically if the main power supply fails shall be installed.

7-5 LIFE SUPPORT

7-5.1 General

The submersible shall be provided with systems and equipment necessary to ensure adequate life-support services during normal and emergency conditions.

A separate main and an onboard emergency life-support system shall be provided for maintaining the oxygen content of the breathing gas between 18% and 23% by volume and the concentration of carbon dioxide (CO₂) below 0.5% by volume under normal conditions and 1.5% by volume under emergency conditions.

7-5.2 Main Life Support

The main life-support system shall have sufficient capacity for the design mission time plus a period of time consistent with the plan to rescue the submarine from its rated depth. This period of time shall in no case be less than 24 hr and shall be consistent with the requirements of [para. 7-4.2.2](#).

7-5.3 Emergency Life Support

The capacity of the onboard emergency life-support system shall be sufficient for 150% of the time normally required to reach the surface or 1 hr, whichever is greater, unless otherwise approved on the basis of special operating conditions, and shall be consistent with the requirements of [para. 7-4.2.3](#).

(a) Emergency breathing gas shall be supplied through full-face masks, oral-nasal masks, self-contained rebreathers, or other means suitable for supporting life in a contaminated environment, including the by-products of an onboard fire. One mask per person shall be provided.

(b) The emergency life-support system shall be independent of any surface support systems and independent of the main life-support systems.

(c) Where open-circuit systems are used, the effects of increased compartment pressure shall be considered.

7-5.4 Consumption Rates

For calculating the required capacities of main and emergency life-support systems, the consumption of oxygen shall be at a rate of 1 ft³ (28.3 L) per hr per person and a carbon dioxide (CO₂) production rate of 0.115 lb (0.0523 kg) per hr per person, at 1 atm.

7-5.5 Oxygen Systems and Storage

(a) When oxygen storage containers are located inside the pressure hull, the volume of a single container shall be limited such that the release of its contents shall not increase the pressure in the occupied PVHO by more than 1 atm or raise the oxygen level above 25% by volume. The designer, as may be required by other constraints, shall limit the allowable pressure increase.

(b) When oxygen storage containers are stored outside the pressure hull, they shall be arranged in at least two banks with separate penetrations entering the submersible. The pressure containers shall be designed for an external pressure differential of not less than the rated depth of the submersible.

(c) In view of the hazards associated with oxygen systems, consideration shall be given to the selection of materials, equipment, installation, cleaning, and testing procedures.

7-5.6 Monitoring

Capability shall be available to the pilot for monitoring oxygen (O₂) levels, carbon dioxide (CO₂) concentrations, humidity, temperature, and pressure of all occupied spaces.

Means shall be provided, and/or operational procedures implemented, to notify of a malfunction of the life-support systems.

7-6 FIRE PROTECTION

7-6.1 Materials

The construction of the submersible shall minimize hazards of smoke and fire. All materials and equipment within the craft shall be nonflammable within the range of oxygen (O₂) levels envisaged.

7-6.2 Toxicity

Toxicity of burning materials and low flame-spread characteristics shall be taken into consideration.

7-6.3 Smoke Detectors

The designer shall consider the size of the submersible, usage of unoccupied spaces, and the ability of occupants to detect fire/smoke, in advance of an onboard detector, in determining the location and quantity of smoke detectors.

7-6.4 Extinguishers

All submersibles shall be equipped with a suitable means of fire extinguishing. This may consist of a permanently installed system and/or portable extinguishers. The design of the system and selection of the extinguishing medium shall consider type and location of fire anticipated, hazards to human health, and the effects of increased pressure. Carbon dioxide and seawater are considered unsuitable.

7-7 NAVIGATION

7-7.1 General

Submersible craft shall be provided with navigational equipment to enable safe operation under all design conditions. Equipment shall include, but not be limited to, the following:

- (a) directional indicator
- (b) depth indicator
- (c) depth sounder
- (d) clock
- (e) trim and heel indicator
- (f) underwater location device

7-7.2 Propulsion

Submersibles equipped with propulsion systems shall be provided with adequate controls and indicators to enable safe operation under all design conditions.

7-7.3 Depth Gauges

Two independent instruments for registration of depth shall be provided. At least one of these instruments shall be a pressure gauge capable of functioning in an emergency situation. If both are pressure gauges, they shall not have a common inlet.

7-7.4 Depth Alarm

Submersibles operating in water where the seabed depth is greater than the rated depth of the submersible shall have a depth alarm set at no greater than the rated depth of the craft.

7-7.5 Obstacle Avoidance

Operational procedures and/or onboard equipment shall be used to provide adequate means of avoiding obstacles under all anticipated operational conditions.

7-7.6 Surfaced Detection

Means shall be provided to render the submersible, while on the surface, readily visible to other vessels.

7-7.7 Submerged Detection

Means shall be provided to indicate the submersible's location while it is submerged.

Where a releasable location system is used, the release arrangement may be manual or hand-hydraulic. It shall not depend on electrical power for its operation and shall be able to operate at all anticipated angles of heel and trim. The size of the float and length of line shall be such that expected current action on the line does not prevent the float from coming to the surface.

7-8 COMMUNICATIONS

7-8.1 General

Each submersible shall be fitted with such equipment as is necessary for the crew to communicate with personnel at the support facility when on the surface and when submerged.

7-8.2 VHF Radio

Each submersible shall be equipped with at least one two-channel transmitter/receiver, one of the channels of which shall operate on safety channel 16-VHF, while the other is used as a "working channel" for communication between the submersible craft and its support facility.

7-8.3 Underwater Telephone (UWT)

Each submersible shall be equipped with at least one dual-channel underwater telephone system. This system shall enable two-way communications to be maintained with the support facility.

7-8.4 Pinger

In addition to the requirements of para. 7-7.7, each submersible shall be fitted with an acoustic underwater pinger, compatible with equipment available for executing an underwater search and rescue. The pinger shall remain operational in the event of loss of main power.

7-9 INSTRUMENTATION

7-9.1 General

The pilot shall be able to monitor the conditions affecting the safety of the submersible craft and its occupants.

7-9.2 Water Intrusion

An audio alarm indicating water leakage into the main pressure hull, battery pods, and other compartments, as may be deemed necessary, shall be incorporated into the design.

7-9.3 Power Levels

Visual indications of available power (fuel, electrical, etc.) shall be provided.

7-9.4 Voltage and Current Meters

Voltage of, and current from, each electrical source of power shall be provided.

7-9.5 Ground Faults

A ground/earth fault monitoring system shall be provided.

7-9.6 Ballast Water

Where water ballast systems are used, a visual display showing the quantities of ballast water onboard shall be provided.

7-10 BUOYANCY, STABILITY, EMERGENCY ASCENT, AND ENTANGLEMENT

7-10.1 General

Submersibles shall be able to ascend/descend in a safe and controlled manner throughout the craft's depth of operations.

(23)

The design of the surfacing and jettisoning systems should take into consideration the following, as applicable:

(a) loss of buoyancy due to elastic compression of the submersible at operating depths

(b) weight adjustments due to difference in seawater density and water temperature at the surface versus that at operating depths

Submersibles shall be able to maintain an acceptable stability and trim during ascent and descent, while submerged, and on the surface. Acceptable stability and trim shall be maintained during transit from a submerged to a surfaced condition, and vice versa. The submersible craft shall be capable of remaining on the surface with one or more hatches open during all anticipated design environmental and operating conditions without down-flooding.

The arrangements for blowing ballast tanks shall be such that overpressurization is not possible.

7-10.2 Underwater Operation

The submarine shall, under all conditions of loading and ballast, remain stable and in the upright condition with the center of gravity remaining below the center of buoyancy. The distance between the center of gravity and the center of buoyancy (GB), under all normal operating conditions, is the greater of 1.5 in. (38 mm) or as determined by the following:

$$GB = nwNd/W \tan \alpha$$

where

d = the interior distance within the main cabin accessible to onboard personnel, in. (mm)

N = total number of persons onboard the submarine

n = 0.1 (10% of the people aboard moving simultaneously)

W = the total weight of the fully loaded submarine, lb (kg)

w = 175 lb (79.5 kg) per person

α = 25 deg or less if required by other design features including battery spillage or malfunction of essential equipment

7-10.3 Surfacing

(a) A pilot-operated means that is independent of the jettison system required in [para. 7-10.4](#) shall be provided to bring the submersible to the surface in a stable condition.

(b) The submersible shall be equipped with at least two lifting points to which attachments may be secured to raise the vehicle to the surface in an emergency. The lugs and their connection to the vehicle structure shall be designed taking into account loads generated by forces of $2g$ vertical ($1g$ static plus $1g$ dynamic), $1g$ transversal, and $1g$ longitudinal acting simultaneously under the most severe

condition, or the submersible craft shall be provided with means of externally bringing the craft to the surface, in all anticipated operating and emergency conditions, without assistance from personnel inside of the submersible.

7-10.4 Jettisoning System

(23)

(a) Submersibles shall be provided with a means to jettison sufficient mass such that if the largest single floodable volume, other than personnel compartments, is flooded, an ascent rate approximating the normal ascent rate can be achieved. The jettisoned mass may consist of a drop weight, appendages subject to entanglement, or a combination of both. Alternatively, the passenger compartment may be provided with a means of separating it from all other parts of the system, including appendages, provided the personnel compartment is positively buoyant when released.

(b) Consideration shall be given to the jettisoning of appendages subject to entanglement including, but not limited to, thrusters, manipulators, cameras, and pan and tilt systems.

(c) Jettison systems shall require at least two positive manual actions to initiate actuation and shall be either

(1) operated independent of electric power.

(2) provided with two independent electrical systems, each of which shall be powered by a separate power source. The two electrical systems shall be routed separately to minimize the possibility that a single incident (e.g., collision or fire) would cause failure of both electrical systems.

(d) Submersibles shall have stability under any combination of jettisoned masses to provide safe recovery of personnel.

7-10.5 Entanglement

The possibility of entanglements shall be considered in the design of submersible craft. Design features, operational and emergency procedures, and/or means of jettisoning may be necessary.

7-11 EMERGENCY EQUIPMENT

7-11.1 Life Jackets

Life jackets shall be provided for, and accessible to, each person on the submersible. Personnel shall be able to disembark with a donned life jacket. Inflatable-type life jackets should be considered to facilitate disembarkation.

7-11.2 First Aid Kit

Submersibles shall be provided with a first aid kit appropriate for the environment and intended needs.

7-11.3 Thermal Protection

Submersibles operating in cold waters shall be equipped with sufficient emergency thermal protection for all occupants in consideration of the duration of onboard life-support systems.

7-11.4 Rations

Sufficient food and water rations shall be provided for each person onboard as may be required for normal and emergency operations.

7-11.5 Tow Point

An accessible towing point shall be provided.

(23) 7-12 HADAL-ZONE SUBMERSIBLES

The requirements of this subsection apply to submersibles designed for operation in the hadal zone [i.e., depths of 6 000 m seawater (MSW) to 11 000 MSW]. Hadal-zone submersibles shall comply with the requirements of subsections 7-1 through 7-11, with the following exceptions or additional requirements.

7-12.1 Reserve Power

In lieu of the duration specified under para. 7-4.2.2, the main power source shall have not less than 96 hr reserve capacity.

7-12.2 Reserve Life Support

In lieu of the duration specified under para. 7-5.2, the main life-support system shall have not less than 96 hr reserve capacity.

7-12.3 Buoyancy, Stability, Emergency Ascent, and Entanglement

7-12.3.1 General. The surfacing and jettisoning systems of hadal-zone submersibles should take into consideration the design of the submersible for rapid controlled vertical travel through the water column.

7-12.3.2 Additional Means of Surfacing. In addition to the primary means of surfacing specified in para. 7-10.3(a), a secondary pilot-operated means of surfacing shall be provided that is independent of both the primary means of surfacing and the jettison system specified in para. 7-10.4. This means of surfacing shall be capable of returning the submersible to the surface in a controlled manner while maintaining its stability.

MANDATORY APPENDIX I

REFERENCE CODES, STANDARDS, AND SPECIFICATIONS

(23)

Codes, standards, and specifications incorporated in this Standard by reference, and the names of the sponsoring organizations, are shown below. The most current edition, including addenda, of referenced codes, standards, and specifications shall be used.

21 CFR 820. Food and Drugs, Quality System Regulation. U.S. Government Publishing Office.

29 CFR 1910. Occupational Safety and Health Standards. U.S. Government Publishing Office.

ANSI/FCI 70-2. American National Standard for Control Valve Seat Leakage. Fluid Controls Institute.

ASME B1.20.1. Pipe Threads, General Purpose (Inch). The American Society of Mechanical Engineers.

ASME B31.1. Power Piping. The American Society of Mechanical Engineers.

ASME B36.10M. Welded and Seamless Wrought Steel Pipe. The American Society of Mechanical Engineers.

ASME B36.19M. Stainless Steel Pipe. The American Society of Mechanical Engineers.

ASME B40.1. Gauges: Pressure Indicating Dial Type — Elastic Element. The American Society of Mechanical Engineers.

ASME B40.7. Gauges: Pressure Digital Indicating. The American Society of Mechanical Engineers.

ASME Boiler and Pressure Vessel Code. The American Society of Mechanical Engineers.

ASME PVHO-2. Safety Standard for Pressure Vessels for Human Occupancy: In-Service Guidelines. The American Society of Mechanical Engineers.

ASTM B88. Specification for Seamless Copper Water Tube. American Society for Testing and Materials.

ASTM B154. Method of Mercurous Nitrate Test for Copper and Copper Alloys. American Society for Testing and Materials.

ASTM D256. Test Methods for Impact Resistance of Plastics and Electrical Insulating Materials. American Society for Testing and Materials.

ASTM D542. Test Methods for Index of Refraction of Transparent Organic Plastics. American Society for Testing and Materials.

ASTM D570. Test Method for Water Absorption of Plastics. American Society for Testing and Materials.

ASTM D638. Test Method for Tensile Properties of Plastics. American Society for Testing and Materials.

ASTM D648. Test Method for Deflection Temperature of Plastics Under Flexural Load. American Society for Testing and Materials.

ASTM D695. Test Method for Compressive Properties of Rigid Plastics. American Society for Testing and Materials.

ASTM D696. Test Method for Coefficient of Linear Thermal Expansion of Plastics. American Society for Testing and Materials.

ASTM D732. Test Method for Shear Strength of Plastics by Punch Tool. American Society for Testing and Materials.

ASTM D785. Test Method for Rockwell Hardness of Plastics and Electrical Insulating Materials. American Society for Testing and Materials.

ASTM D790. Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials. American Society for Testing and Materials.

ASTM D792. Test Method for Specific Gravity (Relative Density) and Density of Plastics by Displacement. American Society for Testing and Materials.

ASTM E208. Method for Conducting Drop-Weight Test to Determine Nil-Ductility Transition Temperature of Ferritic Steels. American Society for Testing and Materials.

ASTM E308. Method for Computing the Colors of Objects by Using the CIE System. American Society for Testing and Materials.

ASTM G63. Standard Guide for Evaluating Nonmetallic Materials for Oxygen Service. American Society for Testing and Materials.

ASTM G88. Standard Guide for Designing Systems for Oxygen Service. American Society for Testing and Materials.

ASTM Manual 36. Safe Use of Oxygen and Oxygen Systems: Guidelines for Oxygen System Design, Materials Selection, Operations, Storage, and Transportation. American Society for Testing and Materials.

CGA G-4.4. Oxygen Pipeline Systems. Compressed Gas Association.

IMCA D051. Hyperbaric Evacuation Systems (HES) Interface Recommendations. International Marine Contractors Association.

ISO 9001. Quality management systems — Requirements.¹ International Organization for Standardization.
ISO 13485. Medical devices — Quality management systems — Requirements for regulatory purposes.¹ International Organization for Standardization.
NASA Technical Manual TMX 64711 (1972, October 1). Compatibility of Materials With Liquid Oxygen. Marshall Space Flight Center.

Naval Ships' Technical Manual NAVSEA S9086-H7-STM-010/CH-262R6. Chapter 262, Lubricating Oils, Greases, Specialty Lubricants, and Lubrication Systems. Commander Naval Sea Systems Command.
NFPA 99. Standards for Health Care Facilities. National Fire Protection Association.
Threshold Limit Values for Chemical Substances. American Conference of Governmental Industrial Hygienists.

ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

¹This publication may also be obtained from the American National Standards Institute (ANSI): www.ansi.org.

MANDATORY APPENDIX II

DEFINITIONS

(23)

ACGIH: American Conference of Governmental Industrial Hygienists.

acrylic: a methyl methacrylate polymer possessing physical and mechanical properties shown in [Tables 2-3.4-1](#) and [2-3.4-2](#).

air-ventilated PVHO: a PVHO in which a flow of breathing air is supplied to the PVHO and exhausted to the atmosphere for the purpose of maintaining life-sustaining conditions.

ballast tank: a compartment/tank used to control the buoyancy of a submersible PVHO.

brazed fitting: any tube or pipe fitting that is attached to the pipe or tube by means of a brazing process.

breathing device: the appliance used to deliver a breathing gas to a PVHO occupant. The gas may be different from the chamber atmosphere.

breathing gas: any gas intended for use as a respirable gas.

breathing gas service: any line that carries gas that is intended for use as a respirable environmental gas in an occupied space or is intended for use in some type of breathing apparatus.

breathing gas system: any system that is used to handle gas (including air) intended for human respiration. All oxygen systems are considered breathing gas systems.

chamber: a pressure vessel intended for occupancy by humans.

chamber system: one or more chambers intended to function as an operational unit.

chip: a small fracture flaw in the window surface (most typically, the result of impact with a hard object).

closure: a mechanism that allows opening and/or closing for attachment or disconnection of an associated PVHO, hatch, or door. Includes both fixed clamps and quick-opening clamps.

clump weight: the weight attached to and deployed by the guide wire system.

component: an item such as, but not limited to, pipe, piping subassemblies, parts, valves, strainers, relief devices, and fittings.

compression fitting: any tube fitting that grips the tube by means of one or more ferrules that compress or swage the end of the tube without creating a definite notch in the tube wall.

conical frustum window: a flat, circular window geometry with a conic section bearing edge.

contamination: a noticeable local discoloration or opacity without well-defined boundaries on the surface or body of the acrylic window.

conversion factor (CF): for windows, an empirical ratio of short-term critical pressure to design pressure for a given temperature.

crack: a discontinuity in the acrylic indicating local failure of the acrylic window. A crack is characterized by its length and depth.

crazing: a haze on the surface of the window made up of a multitude of very fine, hair-like straight or randomly oriented cracks that become clearly visible if illuminated at an angle by a bright light. Crazing is an indication of surface degradation that may be thermally, mechanically, radiation, or chemically induced.

critical density of population: the number of significant inclusions or scratches per specified contiguous area or volume of window that cannot be exceeded in a finished window.

critical dimension: the maximum dimension of discontinuity on the surface or in the body of an acrylic window. For inclusions, it is the effective diameter, whereas for scratches, it is the depth.

critical locations: locations on the surface or interior of the window where no discontinuities or artifacts are permitted.

critical pressure: pressure that, acting on one side of the window, causes it to lose structural integrity.

critical size of population: the total number of inclusions or total length of scratches with significant dimensions that cannot be exceeded in a finished window.

critical spacing: the minimum allowable spacing between peripheries of inclusions or scratches with significant dimensions in a finished window.

custom casting: a casting of any shape window that is not carried as a standard production item.

cyclic design life: the number of pressure cycles that a window is projected to withstand without catastrophic failure when pressure cycled, at 4 hr per cycle, to design pressure at design temperature.

cyclic proof pressure (CPP): the pressure that a window shall withstand without cracking under intermittent pressurization.

cylindrical window: a window consisting of a tube with circular cross section.

deck decompression chamber: a PVHO used for operational recompression, barotrauma treatment, and decompression of divers.

design cycle: the steps used as the basis for the development of the conversion factors used herein for windows. For the purpose of this Standard, it is a pressure excursion at design temperature to the design pressure and returning to ambient. Pressure is held for 4 hr at both the design and ambient pressures.

design depth: the maximum depth to which the submersible PVHO is designed to operate.

design life: the period of time or number of design cycles or both assumed for a window complying with this Standard. The window design life may be different for different types of windows. The design life has three aspects: total time under pressure, cyclic design life, and total chronological time from the date of initial manufacture.

design pressure: the highest pressure that shall be reached in the pressure vessel including coincident static head in the operating position and at the most severe combination of pressure and temperature expected in normal operations. For this condition the maximum differences in pressure between the inside and outside of a pressure vessel, or between any two chambers or a combination unit, shall be considered.

design qualification: an experimental procedure for verifying the conformance of a nonstandard window design to mandatory structural requirements of this Standard.

design temperature: the maximum and minimum temperatures for which a pressure component is designed.

ding: a crater-like, shallow, crack-free indentation in the window surface resulting from impact. The depth of the indentation is typically less than the diameter of the crater at the window surface.

diving system: a PVHO system that is used for diving, support of diving operations, or diving training.

drop weight: one or more releasable weights attached to the diving bell.

elastomer: a natural or synthetic material that is elastic or resilient and in general resembles rubber in its deformation under tensile or compressive stresses (i.e., at least 50% elastic compression and 70% elastic extension).

examination: the process of determining the condition of an area of interest by nondestructive means measured against established acceptance or rejection criteria. Examination is generally performed using nondestructive examination methods, e.g., visual, liquid penetrant, radiographic, or ultrasonic.

fabricator: an individual or organization that creates a component, part, or product from raw materials meeting one or more material and design specifications.

flammable: a material capable, when ignited, of maintaining combustion under specific environmental conditions.

flare fitting: any tube fitting that grips the tube by means of a flare that is applied to the end of the tube by mechanical means.

flat disk window: a plane, circular window geometry.

F_p: the adjustment factor to be multiplied by the ACGIH TLV when the anticipated duration of manned occupation is in excess of 8 hr.

full-scale window: a window whose dimensions are identical to the window in actual service.

gas chromatography/mass spectrometry (GC/MS): methods of identifying and quantifying volatile hydrocarbons using a combination of gas chromatography and mass spectrometry.

gas container: a pressure vessel for the storage and transport of gases under pressure.

gouge: a wide, V-shaped, crack-free discontinuity in the window surface resulting from the movement of a rough, hard object across the surface of the window. The depth of the gouge is typically less than or equal to the width of the discontinuity.

guide wire: an independent system of wires used to deploy a clump weight that provides vertical and rotational stability to the diving bell. These are typically connected at two or four points on the diving bell protection frame. Connection is by means of special clamps designed to allow the diving bell to run freely up and down the guide wires.

handling system: a system to support the launch, recovery, and other handling operations of diving bells that may include cranes, booms, masts, frames, winches, and associated hydraulic and electrical systems as necessary for the intended operations.

handling system design load: the maximum expected load on the handling system. It consists of a combination of the rated load; the dynamic effects of pitch, roll, and heave; the weight of the rigging (hooks, blocks, deployed rope, etc.); and other applicable loads, e.g., wind load, drag, added mass effect, and weight of entrained mud and water.

harmful chemicals: liquid, solid, or gaseous substances that, upon contact with surfaces of stressed acrylic windows, initiate crazing (e.g., alcohols, acetone, ether, methyl ethyl ketone, and adhesive tapes).

helium service: any portion of a piping system that may contain gases containing helium shall be considered to be in helium service.

hemispherical window: a geometry that depicts a half-spherical window shape.

high-pressure face: the viewing surface of the window that while in service is acted upon by the pressure loading on the window.

hydrocarbon: all organic compounds detectable by a total hydrocarbon analyzer.

hyperbaric stretcher: a portable monoplace PVHO approved for transfer under pressure.

hyperhemispherical window: a spherical acrylic shell having an included angle greater than 180 deg, a single penetration, and a conical bearing surface.

inclusion: a foreign substance or void in the body of an acrylic window with a dimension measured as the diameter of a sphere having an equivalent volume of the inclusion.

inclusion-fiber: a nonmetallic fiber in an acrylic casting (e.g., individual hair or fiber of cotton, polyester, or nylon) with diameter <0.005 in. (<0.125 mm).

inspection: activities performed to verify that materials, fabrication, construction, examinations, testing, repairs, etc., conform to one or more of the following: the applicable code, engineering requirements, or the owner's written procedures.

inventory control identification: an identifier assigned to a single sheet or custom casting by the fabricator of windows when lot identification is not provided by the manufacturer of plastic.

life-sensitive system: any system where an interruption of service represents a hazard to the health and well-being of the chamber occupants.

life-support system: the equipment and systems required to maintain a habitable atmosphere in the PVHO in all anticipated operating conditions.

lock: a chamber compartment that can be maintained at a pressure different from other connected compartments (e.g., inner lock, outer lock, entry lock, med/service lock).

long-term proof pressure (LTPP): pressure that a window shall withstand without catastrophic failure under sustained pressurization of 80,000-hr duration in design temperature ambient environment. This Standard defines long-term proof pressure as equal to design pressure.

lot identification: an identifier affixed by the manufacturer of plastic to all castings constituting a lot of material for windows.

lot of material: a unit of window manufacture consisting of a single production run poured from the same mix of monometric material and made at the same time, undergoing identical processing from monomer to polymer.

low-pressure face: the viewing surface of the window that while in service is not acted upon by the pressure applied to the window.

manufacturer: an individual or organization responsible for the repeated production of a product (e.g., multiple pressure vessels of the same design, windows, valves, and other components), or referenced as the entity responsible for a uniquely specified product on a form, nameplate, or report, in accordance with the rules of ASME PVHO-1 and the User's Design Specification.

marine system: a chamber or chamber system that is to be used in a marine environment. For the purposes of this Standard, all chambers and chamber systems that are not exclusively land-based are considered marine systems.

marking: the identification on the window's bearing surface or edge denoting that the window met ASME PVHO-1 requirements for the specified design temperature and pressure. The fabricator's identification symbol, serial number, and year of fabrication are also part of the marking.

material manufacturer: an organization that

(a) produces the raw materials or products or both that meet the requirements of a material specification

(b) accepts the responsibility for any statements or data in any required certificate of compliance or Material Test Report representing the material

material specification: a description of the identifying characteristics of a material (product, form, ranges of composition, mechanical properties, methods of production, etc.) together with sampling, testing, and examination procedures to be applied to production lots of such material to verify acceptable conformance to the intended characteristics.

material testing laboratory: the party who tests material specimens for windows cut from plastic casting and provides Material Testing Certification for Acrylic (see PVHO-1 Form VP-4).

maximum allowable working pressure (MAWP): the maximum rated pressure for a component.

maximum operating pressure: the maximum pressure in which a system (pressure vessel, supporting controls, and instrumentation) shall be operated.

medical chamber: a chamber or chamber system that is intended for use in a clinical setting for administering hyperbaric oxygen therapy or other hyperbaric medical treatments.

medical lock: a small compartment that penetrates the pressure hull of the PVHO, allowing items to be transferred into and out of a PVHO under pressure.

megapascal (MPa): the SI unit of pressure equal to 10 bar, or 145 psi.

model-scale window: a window whose dimensions are all scaled down linearly from the window in actual service.

monoplace chamber: a PVHO designed to accommodate a single person.

multiplace chamber: a PVHO designed to accommodate two or more people.

NEMO window: a spherical acrylic shell with two or more conical penetrations whose edges are supported by inserts with conical edges.

nominal values: specified dimensions or angles for components of a chamber to which dimensional tolerances are subsequently applied on fabrication drawings.

nonstandard window geometry: unproven window geometry that must first be experimentally qualified for the intended design pressure and temperatures.

operating pressure: the pressure at which the PVHO and its subsystems are designed to operate. This shall not exceed the maximum allowable working pressure (as defined in the current edition of ASME BPVC and ASME B31.1) of the PVHO or any of its subsystems. The operating pressure is usually kept at a suitable level below the setting of the pressure relief device or devices to prevent its frequent opening.

operational temperature range: the range of ambient temperatures to which the chamber can be subjected while pressurized.

oxygen service: any portion of a piping system internally pressurized with a gas containing more than 25% oxygen by volume.

payload: the weight the submersible PVHO is capable of carrying in addition to its permanently fitted equipment.

permissible exposure limit (PEL): nomenclature used by the Occupational Safety and Health Administration (OSHA) to express allowable airborne concentration for a conventional 8-hr workday and a 40-hr workweek.

pilot: a person appointed and trained to command a submersible PVHO.

pipe: a tube with a circular cross section conforming to the dimensional requirements for nominal pipe size as tabulated in ASME B36.10M, Table 1 and ASME B36.19M, Table 1. For special pipe having a diameter not listed in these tables, and also for round tube, the nominal diameter corresponds with the outside diameter. The fundamental difference between pipe and tube is the dimensional standard to which each is manufactured.

piping: all circular cross-section conduits. The term *piping* is used generically to include both pipe and tube used for the transmission of fluids. The use of noncircular tubing for pressure piping within the scope of this Standard is not permitted.

piping system: the assembly of piping and components required to form a functional system.

ppm: the concentration in air expressed as parts per million, on a volumetric basis.

pressure control valve: a valve used to reduce or maintain the pressure in a piping system by admitting or releasing fluid pressure, as required, to maintain pressure at or near a designated setpoint. Also called *pressure-reducing valve*, *pressure regulator*, or *back-pressure regulator*.

pressure testing certification: certification that the newly manufactured window has successfully met the mandatory requirements of ASME PVHO-1.

pressure testing laboratory: the party who pressure tests windows installed in viewport flanges and provides pressure testing certification.

pressure vessel for human occupancy (PVHO): a chamber, including all components required to complete the pressure boundary, that encloses a human being while the chamber is under internal or external pressure.

Professional Engineer: an individual who has fulfilled education, experience, and testing requirements that, under applicable jurisdictional engineering licensure or chartering laws, permit the engineer to have technical authority according to the jurisdiction.

PVHO manufacturer: the person, group, or corporate entity that constructs or assembles a pressure vessel for human occupancy in accordance with the provisions of ASME PVHO-1 and the User's Design Specification.

PVHO system: a system comprising a minimum of one pressure vessel for human occupancy along with its ancillary systems (i.e., control, electrical, breathing gas, life support, handling system, emergency, etc.) designed and operated for the intended application (i.e., medical per [Section 5](#), diving per [Section 6](#), submersible per [Section 7](#), altitude, tunneling, etc.) in accordance with ASME PVHO-1, the User's Design Specification, and manufacturer's Data Reports and maintained in accordance with ASME PVHO-2.

PVHO system boundary: a virtual limit to which the pressure vessel for human occupancy system extends in order to encompass all items required to support the unique capability that it was designed to provide. This limit is intended to separate other systems that may be sharing a common space. See also *PVHO system*.

qualified person: someone who, by possession of a recognized degree, certificate, or professional standing, or who, by knowledge, training, and experience, has successfully demonstrated the ability to perform the assigned duties.

quality assurance program: a documented systematic organization of policies and procedures to ensure that the product or service delivered meets all customer and design specifications.

rated depth: the maximum depth to which the submersible craft is certified to operate.

rated load: the maximum load that the assembled handling system is certified to lift at its maximum rated speed when the outermost layer of rope or umbilical is being wound on the winch drum, under the parameters specified in the User's Design Specification (e.g., hydraulic pressures and electrical currents/voltages). Also called *safe working load*.

risk: the combination of the probability of occurrence of harm and the severity of that harm.

risk analysis: the systematic use of available information to identify hazards and to eliminate the risk.

saturation diving: a diving procedure by which the diver is continuously subjected to a pressure greater than atmospheric so that the diver's body tissue and blood become saturated with the inert element of the breathing gas at the elevated ambient pressure.

scratch: a crack-free discontinuity on the surface of the acrylic window that is the result of foreign objects coming in contact with the acrylic surface. For the purpose of evaluation, gouges and dings shall be considered scratches. The dimension of a scratch is the depth of the sharp surface discontinuity measured from the window surface to the bottom of the scratch.

service life: the period of time or number of cycles or both that a window may be permitted to remain in service. The window service life may be shorter or longer than the window design life due to variations in the conditions of service, latent manufacturing defects, or other factors. (For additional information regarding the service life of windows, see ASME PVHO-2.)

service locks: compartments not intended for human occupancy that are used for transferring supplies and materials into and out of a PVHO while the occupants remain under pressure.

shall: the term used to indicate that a provision is mandatory.

sheet castings: sheets of plastic cast on a production line basis and carried as a standard production item in a manufacturer's sales catalog.

short-term critical pressure (STCP): the pressure required to catastrophically fail a window at a 650-psi/min (4.5-MPa/min) rate in design temperature ambient environment.

short-term proof pressure (STPP): the pressure that a window shall withstand without catastrophic failure under short-term pressurization at 650 psi/min

(4.5 MPa/min) in design temperature ambient environment. This Standard defines short-term proof pressure as equal to 4 times the design pressure.

should: the term used to indicate that a provision is not mandatory but is recommended as good practice.

significant dimension: when the dimension of an inclusion or a scratch exceeds a specified value and is considered as being present in the window for inspection purposes.

soft goods: O-rings, gaskets, seals, and other polymer or elastomer components used in a PVHO system.

spherical sector window: a geometry that depicts a spherical window shape.

standard temperature: the range of material temperatures from 70°F to 75°F (21°C to 24°C) at which all the dimensions in this Standard are specified.

standard window geometry: proven window geometry that, because of its safe service record, has been incorporated in this Standard. Windows with standard geometries may be used in pressure vessels for human occupancy without having to undergo experimental design qualification.

submersible: a manned, self-contained, mobile vessel that primarily operates under water and relies on surface support (e.g., a surface ship or shore-based facilities) for monitoring and for one or more of the following:

- (a) recharging of power supply
- (b) recharging high-pressure air
- (c) recharging life support

submersible diving chamber (SDC): commonly called a diving bell; used to transport divers under pressure to a work site.

supplier: the party who supplies finished windows with all required certifications to the chamber manufacturer (original equipment) or user (replacement). There is nothing in this Standard prohibiting the supplier from performing the functions of plastic manufacturer, material testing laboratory, window designer, window fabricator, and pressure testing laboratory, provided that these functions generate the required certifications.

support facility: a surface craft or shore-based facility providing support to the submersible PVHO.

systems integrator: a person, company, or manufacturer that brings together component subsystems and ensures that the overall system and all of its subsystems function safely together.

testing: within this Standard, either pressure testing (hydrostatic, pneumatic, or a combination hydrostatic pneumatic) or mechanical testing performed to determine such data as material hardness, strength, and notch toughness. Testing, however, does not refer to nondestructive examination using methods such as liquid penetrant or radiography. See *examination*.

thickness of a vessel wall:

design thickness: the sum of the required thickness and the corrosion allowance.

nominal thickness: the thickness selected as commercially available and supplied to the manufacturer. For plate material used in formed shapes, the nominal thickness shall be, at the manufacturer's option, either the thickness shown on the Material Test Report before forming or the thickness of the plate at the joint or location under consideration.

required thickness: that thickness computed from the maximum design pressure and other loading criteria prior to the corrosion allowance being applied.

third-party inspection agency: an individual or organization, independent of the designer, fabricator, and user, who is qualified through education, test, or experience to perform the inspection.

threshold limit values (TLV): nomenclature used by the American Conference of Governmental Industrial Hygienists (ACGIH) to express allowable airborne concentration for a conventional 8-hr workday and a 40-hr workweek.

total hydrocarbon analyzer: any suitable process analyzer employing a hydrogen flame ionization detector (FID) having a range of 0 mg/m³ to at least 1 000 mg/m³ methane equivalents.

trunk: any void that creates a volume between two or more doors or hatches. Also called *tunnel*.

tube: a hollow product of circular or any other cross section having a continuous periphery. Circular tube size may be specified with respect to any two, but not all three, of the following: outside diameter, inside diameter, and wall thickness; types K, L, and M copper tube may also be specified by nominal size and type only. Dimensions and permissible variations (tolerances) are specified in the appropriate ASTM or ASME standard specifications.

tube fitting: any tube fitting that grips the tube by means of one or more teeth that bite or dig into the outside diameter of the tube creating a definite notch. Also called *pipe fitting* or *bite-type fitting*.

viewport: a penetration in the pressure vessel including the window, flange, retaining rings, and seals.

void: a hollow cavity in the body of the acrylic casting.

welded fitting: any tube or pipe fitting that is attached to the tube or pipe by means of a welding process.

window: a transparent, impermeable, and pressure-resistant insert in the viewport.

window fabricator: person, group, or corporate entity that fabricates PVHO windows in accordance with the requirements of ASME PVHO-1 and the User's Design Specification.

NONMANDATORY APPENDIX A

DESIGN OF SUPPORTS AND LIFTING ATTACHMENTS

The designer should consider using the provisions of the following studies, which appear in Pressure Vessels and Piping: Design and Analysis, Volume Two — Components and Structural Dynamics (1972). The American Society of Mechanical Engineers:

(a) Wichman, K. R., Hopper, A. G., and Mershon, J. L. (1965). Local Stresses in Spherical and Cylindrical Shells due to External Loadings (Bulletin 107). Welding Research Council.

(b) Zick, L. P. (1971). Stresses in Large Horizontal Cylindrical Pressure Vessels on Two Saddle Supports. Welding Journal Research Supplement.

The use of these provisions shall not negate Code requirements.

ASME PVHO-1-2023
Click to view the full PDF of ASME PVHO-1 2023
ASME NORMDOC.COM

NONMANDATORY APPENDIX B

RECOMMENDATIONS FOR THE DESIGN OF THROUGH-PRESSURE BOUNDARY PENETRATIONS

B-1 GENERAL

This Appendix provides several basic designs of through-pressure boundary piping penetration designs that have been found to give good service. Acceptable designs of through-pressure boundary piping systems are not necessarily limited to the designs shown. All pressure boundary penetrations shall meet the reinforcement and weld detail requirements of ASME PVHO-1 and ASME BPVC, Section VIII, Division 1 or Division 2, as appropriate.

B-2 PENETRATOR DESIGNS

Figure B-2-1 shows four basic penetrator designs intended principally for services as follows:

(a) full coupling intended for standard threaded pipe couplings or a special coupling dictated by the User's Design Specification. For most applications, a standard 6,000-psi NPT coupling is acceptable in 316 or 316L stainless steel.

(b) half-coupling, full-penetration weld installation. This is generally used for pressure equalization in supply locks and transfer tunnels and can also be used for pressure gauge penetrators.

(c) special forging. This category is intended for fully radiographable penetrators, generally to comply with ASME BPVC, Section VIII, Division 2.

(d) flush-mount coupling. This category is generally a 6,000-psi or special forging type coupling. This configuration is used where a full coupling with internal and external threads is required, or where there are chamber drains and supply lock and tunnel equalizations, or in other applications where a flush internal mount is required.

B-3 COUPLING DETAILS

Figure B-3-1 shows four acceptable coupling details.

B-3.1 Threaded Couplings

(a) *NPT (National Pipe Thread) 6,000-psi Coupling.* For marine systems the coupling material should be a stainless steel per para. B-4. The heavy wall of the 6,000-psi coupling normally permits at least one field rethreading should the original threads be damaged.

(b) *Special Coupling With an SAE or MS (Military Standard) Straight Thread O-Ring Boss.* This design is recommended over pipe threads when the contained fluid may be helium.


B-3.2 Threaded Insert Couplings

These are generally smooth bore couplings with threaded, flanged inserts with either pipe threads or straight thread O-ring seals. This installation can be sealed and secured with a fillet weld or assembled with a flat washer and locking nut with O-ring seals as shown in Figure B-3-1. The latter installation is preferred but its cost often makes it impractical.

B-4 MATERIALS


Practical experience has shown that unthreaded (i.e., smooth bore) couplings in marine systems may be any Code-approved forged steel while threaded couplings and inserts should be of approved stainless steel (316 or 316L), brass, or bronze. Corrosion-resistant alloys are strongly recommended to eliminate cleaning, maintenance, and material compatibility problems. Threaded couplings and inserts in land-based chambers may be of any Code-approved material.

Figure B-2-1
Acceptable Weld Nozzle Penetrators



GENERAL NOTE: This figure refers to pipes 2 in. (50 mm) and under.

Figure B-3-1
Acceptable Threads and Inserts



NONMANDATORY APPENDIX C

RECOMMENDED PRACTICES FOR COLOR CODING AND LABELING

All piping and gas storage bottles should be colored and labeled to indicate content, maximum allowable working pressure, and direction of flow. Except for certain pipe materials such as stainless steel, the color should be a continuous coat of paint. For stainless steel and similar corrosion-resistant materials, color coding may be a 1-in. (25-mm) band of paint or tape. Bands should be applied at every bend and intersection, and at each side of obstructions. To aid in tracing the pipe, a minimum of three bands should be visible at any location.

In addition to color coding, piping should be labeled with the name and/or symbol of its contents, direction of flow, and maximum allowable working pressure. This labeling should be applied at every intersection and at each side of obstructions. For labeling, a color that contrasts with that of the pipe should be used. [Tables C-1](#) and [C-2](#) give the color codes required by the U.S. Navy and the International Maritime Organization (IMO), respectively. Other color codes may also be used.

Table C-1
U.S. Navy Color Codes

Name	Designation	Color
Oxygen	O ₂	Green
Nitrogen	N	Light gray
Air (low pressure)	ALP	Black
Air (high pressure)	AHP	Black
Helium	He	Buff
Helium-oxygen mix	He-O ₂	Buff and green

GENERAL NOTE: Adapted from NAVSHIPS 0994-001-9010. U.S. Navy Diving Manual. Navy Department.

Table C-2
IMO Color Codes

Name	Symbol	Color
Oxygen	O ₂	White
Nitrogen	N ₂	Black
Air	Air	White and black
Carbon dioxide	CO ₂	Gray
Helium	He	Brown
Oxygen-helium mix	O ₂ -He	White and brown

GENERAL NOTE: Adapted from IMO Resolution A536. Code of Safety for Diving Systems. International Maritime Organization.

NONMANDATORY APPENDIX D

GUIDELINES FOR THE SUBMISSION OF A CASE FOR THE USE OF NONSTANDARD DESIGNS, MATERIALS, AND CONSTRUCTION FOR NON-FLEXIBLE PVHO CHAMBER FABRICATION

PVHO chambers using nonstandard materials, design, and/or construction techniques may be constructed under the requirements of ASME PVHO-1 if a Case describing all exceptions and additions to ASME PVHO-1 has been reviewed and approved by the PVHO Consensus Committee (hereinafter referred to as the Committee) in accordance with Committee Procedures. The following provides a general outline of the information and format that should be included in the proposed Case inquiry (hereinafter referred to as the Case).

The issuance of a PVHO Case should not be construed as approval of a specific design. It is the intent of the Committee to provide performance-based criteria that are applicable to similar nonstandard features. The Case method permits the Committee to assess the inherent safety of the nonstandard feature prior to adoption into ASME PVHO-1. It is the Committee's objective to ensure that a nonstandard PVHO provides equivalent safety as a standard PVHO.

D-1 INTRODUCTION

The intention of a Case is to ensure that alternative approaches are implemented with design margins and quality assurance commensurate with those set forth for recognized materials and established geometry. Minor changes to the requirements in ASME PVHO-1 may not require the extensive analysis and testing described below. Radically different designs may require additional considerations. For this reason, the applicant is cautioned not to fabricate and test a PVHO in accordance with these guidelines and then submit the results with a request for review. Rather, submittal of the Case in the format recommended provides a baseline for the Committee to make an initial assessment of the inherent technical merit and, if warranted, offer appropriate recommendations regarding revision. Should the applicant wish to conduct testing prior to submitting a Case, the Committee reserves the right to require additional tests.

Once a Case is published, it may then be used in accordance with the provisions and limitations defined in the Case.

A Case is normally issued for a limited period of time, after which it may be reaffirmed, incorporated into the Standard, revised, or allowed to expire. The Committee may also act to revoke a Case prior to its normally scheduled expiration, if deemed necessary.

D-2 GENERAL

The formal written inquiry to the Committee should provide background information describing the new or novel design and/or material being proposed for consideration. An explanation of what is being proposed, why this proposal is being presented for consideration, and how the new design and/or material is to be used should be provided.

All proposed PVHO Cases, including proposed reaffirmations of existing PVHO Cases, must be prepared in accordance with the latest published edition of the relevant PVHO standard, which must be noted in the Case itself.

The applicant should clearly and concisely present all exceptions to ASME PVHO-1 that are being sought. Requirements in addition to those in ASME PVHO-1 that are proposed to ensure that the nonstandard PVHO provides equivalent safety to a standard PVHO should also be stated.

The following information shall be provided:

- (a) the maximum allowable working pressure (MAWP)
- (b) a description of the configuration, shape, and dimensions of the vessel complete with enclosures, windows, etc.
- (c) the maximum number of occupants
- (d) the design temperature limits
- (e) the design life expectancy of the vessel, yr
- (f) the design number of pressure cycles

When an existing PVHO Case is being proposed for reaffirmation, documentation shall be provided identifying any and all changes made since the edition to which it

was approved and the latest published edition of the applicable PVHO standard.

NOTE: All PVHO Cases (new, revised, and reaffirmed), once approved, shall show, on the Case itself, the edition of the relevant PVHO standard to which it was approved. A PVHO Case is valid for 6 yr from the date of approval.

D-3 MATERIALS

All materials shall comply with ASME PVHO-1 requirements or a recognized international material standard. Detailed specifications shall be submitted for nonstandard ASME PVHO-1 materials. Supporting information for nonstandard materials, including testing specifications and material properties, operational limitations, and inspection criteria, shall be provided for such materials. The shelf life, cyclic life, temperature limitations, and other relevant critical properties of all nonstandard materials shall be provided.

All materials and material specifications used in the manufacture of the PVHO shall have supporting documentation certifying that each lot used in the manufacture of the PVHO meets ASME PVHO-1 and/or a recognized international materials standard.

As a minimum, the following data shall be provided for proposed alternative materials:

- (a) test data to corroborate the specification data
- (b) strength and elongation data at the maximum and minimum design temperatures, if material properties are temperature dependent
- (c) cyclic life data at the maximum and minimum design temperatures, if material is temperature dependent
- (d) creep and cyclic creep data, if material properties are time dependent
- (e) shelf life, corrosion properties, and any other data that can establish the limitations of the material for the intended use

D-4 DESIGN

For a nonstandard design, the Case submittal shall include a detailed stress analysis performed by a licensed engineer or an independent third-party inspection agency that is experienced in pressure vessel design using the materials proposed.

D-4.1 Design Analysis

The design analysis shall consider the effects of aging and all applicable environmental considerations, both operational and nonoperational. The effects of minimum and maximum temperatures, time under pressure, large displacements associated with deployment (such as collapsible chambers), and long-term storage between usages shall be considered.

D-4.2 Maximum Allowable Working Pressure

The MAWP and associated maximum and minimum design temperatures shall be based on the results of the prototype testing.

D-4.3 Design Certification

Conformance of the design of the PVHO to the requirements of ASME PVHO-1 shall be established by either of the following procedures:

(a) A Professional Engineer registered in one or more of the U.S. states or the provinces of Canada, or licensed by any other country that has equivalent licensing procedures, experienced in relevant pressure vessel design, shall certify that the PVHO was designed either by the engineer or under the engineer's direct supervision, or that the engineer has thoroughly reviewed a design prepared by others, and to the best of the engineer's knowledge, the PVHO complies with ASME PVHO-1 and the Case.

(b) The design of the PVHO shall be reviewed by an independent third-party agency competent in PVHO systems. A certificate that the PVHO complies with ASME PVHO-1 and the Case shall be provided.

D-4.4 Unusual Design Features

If the proposed PVHO exhibits unusual characteristics for a pressure vessel, these shall be described, and a design criteria shall be proposed.

D-5 TESTING

In lieu of the requirements of [paras. 1-7.7](#) and [1-7.8](#), a proposed testing program may be presented with the Case.

All tests shall be witnessed and documented by an independent third-party agency. The inspector shall certify that the test results comply with the testing requirements of the Case.

Testing shall be conducted at the most critical temperature or temperatures for which the PVHO is designed.

Alternative testing procedures may be proposed that meet the intent of the PVHO Standard and the intended use of the PVHO. These procedures shall be based on statistically significant sampling, recognized engineering practices, or a recognized standard acceptable to the Committee.

Any design changes or fabrication process changes shall require full prototype retesting.

D-5.1 Prototype Testing

PVHOs used for prototype testing cannot be used other than for testing.

D-5.1.1.1 Proof Pressure Test. Pressure tests shall be conducted on a minimum of three full-scale prototype chambers. These prototype vessels do not have to be completely outfitted. They shall be full size and of identical construction to the end item, with all fabrication completed that in any manner may affect the integrity of the pressure boundary. If desired, prototype chambers that have already been cyclic pressure tested (see [para. D-5.1.3](#)) may be used.

For materials whose strength is temperature sensitive, the tests shall be performed at the most critical service temperature.

The pressurization rate used for proof pressure and cyclic testing shall be in accordance with that stated in the User's Design Specification. The pressurization rate shall not exceed 650 psi/min (4.5 MPa/min).

Except as permitted by [para. D-5.1.5](#), failure of a vessel shall not occur at a pressure of less than 6 times the rated pressure (MAWP) of the PVHO. The final test pressure shall be held for a minimum of 30 min.

D-5.1.2 Extended-Duration (Creep-Rupture) Testing. For materials that exhibit time-dependent deformation (creep), the long-term strength of the PVHO at maximum design temperature shall be empirically verified using model-scale or full-scale PVHOs.

The use of model-scale PVHOs for extended-duration testing is permitted only if the short-term strength of the model is equivalent to that obtained for the full-scale PVHO. To verify model-scale equivalence, the proof pressure test in [para. D-5.1.1](#) shall be performed on a model-scale PVHO, and the failure pressure obtained shall lie within the range obtained on the full-scale PVHOs. The same conditions of temperature and rate of pressurization used for full-scale PVHOs shall be applied to the model-scale PVHO. If the model-scale test does not meet these criteria, full-scale PVHOs shall be required for extended-duration tests.

D-5.1.2.1 Extended-duration creep-rupture tests shall be performed as follows:

(a) The PVHOs shall be individually subjected to sustained pressure at the maximum design temperature until catastrophic failure occurs.

(b) Each PVHO shall be subjected to a different hydrostatic pressure with sustained temperature, pressure, and duration being recorded.

(c) At least one data point shall be obtained for each of the following log-time cycles: 1 hr to 10 hr, 10 hr to 100 hr, 100 hr to 1,000 hr, and 1,000 hr to 10,000 hr.

(d) The best-fit straight-line log-log plot of pressure versus time shall be constructed based on all extended-duration test data points.

(e) The extrapolated failure at 80,000 hr continuous sustained loading at maximum design temperature shall be greater than twice the MAWP as obtained per [para. D-5.1.1](#); otherwise MAWP shall be reduced to a

value that is 50% of the extrapolated failure pressure at 80,000 hr duration.

D-5.1.2.2 As an alternative, the PVHOs may be subjected to sustained pressure at maximum design temperature for 10,000 hr without failure per any one of the following, where MAWP is determined in accordance with [para. D-5.1.1](#):

- (a) quantity 1 at $3.00 \times \text{MAWP}$
- (b) quantity 2 at $2.75 \times \text{MAWP}$
- (c) quantity 3 at $2.50 \times \text{MAWP}$
- (d) quantity 4 at $2.25 \times \text{MAWP}$
- (e) quantity 5 at $2.00 \times \text{MAWP}$

D-5.1.3 Cyclic Pressure Testing. The maximum permissible number of operational pressurizations shall be determined by cyclic testing of a full-scale PVHO. The pressure test cycles shall be from 1 atm ambient to MAWP and back to ambient. The time at MAWP for each cycle shall not be less than 20 min. If the material strength is temperature sensitive, cycling shall be performed at the most critical service temperature.

The number of approved operational cycles (CA) shall be computed as

$$CA = (CT/2) - 1,000$$

where

CT = total number of test cycles performed

Upon completion of testing, the PVHO shall be visually inspected for cracks. The requirement for acceptance of the cyclic pressure test is that no cracks shall be visibly detectable, using methods that are normally used for visual inspection of the applicable PVHO material.

D-5.1.4 Other Tests. Other testing may be required specific to the intended use of the PVHO. For example, a drop test of portable units or expansion-compression tests of collapsible units may be required.

D-5.1.5 Statistical Analysis. If the applicant desires, statistical analysis may be used in the determination of MAWP.

The test data shall be first checked for normal distribution using Method I of [para. D-7.1](#). If the data passes the normality check, MAWP shall be determined using Method II of [para. D-7.2](#). If the data set does not pass the normality check, MAWP shall be determined using Method III of [para. D-7.3](#). Under no circumstances shall any data points be censored (eliminated from the test database).

If test to failure is not practical (due to economic or other reasons) and the material of construction does not exhibit creep, short-term proof pressure testing of less than failure may be permitted. In such special cases (requiring advance Committee approval), the MAWP shall be determined in accordance with Method IV of [para. D-7.4](#).

In all cases, the statistical methods set forth above for determining MAWP are restricted to materials that do not exhibit creep. For materials that do creep, the testing and determination of MAWP shall be performed as set forth in para. D-5.1.2.

D-5.2 Production Proof Pressure Testing

All production units shall be subjected to a hydrostatic or pneumatic test of 1.5 times the MAWP to be held for a minimum of 1 hr. The maximum allowable pressure loss shall not exceed 1% of the rated pressure. Internal and external temperatures shall be measured and recorded at the beginning and end of each test so that compensation can be made for any temperature differences.

Every PVHO shall be examined visually and dimensionally for damage following each test. Any signs of cracks, permanent deformation, or other signs of damage shall be cause for rejection of the PVHO.

Tests shall be witnessed and documented by an independent third-party agency. The inspector shall certify the test results and that they comply with the testing requirements of the Case.

D-6 QUALITY ASSURANCE OVERVIEW BY AN INDEPENDENT THIRD-PARTY AGENT

An independent third-party agency shall be used to ensure that all PVHOs intended to be classified under ASME PVHO-1 are manufactured and tested to ASME PVHO-1 or the Case submittal.

This shall include, but is not restricted to, the following:

- (a) The manufacturer is working to the requirements of the quality assurance systems as described in Section 3.
- (b) The materials used in construction of the PVHO comply with approved procedures as required by ASME PVHO-1 or the Case submittal.
- (c) All manufacturing operations are conducted in accordance with approved procedures by qualified operators as required in ASME PVHO-1.
- (d) All defects are recorded and acceptably repaired and documented.
- (e) All prototype and production testing has been performed and witnessed as required by ASME PVHO-1 and the Case.
- (f) The PVHO is marked in accordance with ASME PVHO-1 and the Case.
- (g) An inspection of the PVHO is conducted to confirm that there are no material defects or dimensional discrepancies.

D-7 STATISTICAL ANALYSIS

D-7.1 Method I: Check of Data Set for Normal Distribution ($3 < n \leq 50$)

The prescribed check is the "W-test," which is mathematically expressed as follows:

$$W = b^2 / \sum_{i=1}^n e_i^2$$

where

$$b = \sum_{i=1}^u a_i [e_{(n-i+1)} - e_i]$$

and

e = residual values = $x - X$ (signed $\pm$)

n = number of tests to failure

u = largest integer of $n/2$

X = mean value of pressure at failure = $\Sigma(x/n)$

x = pressure values at failure

The a_i values are listed in Table D-7.1-1, and W calculated must be $> W_{\min}$ from Table D-7.1-1. (An example data set is as follows: x values 100, 105, 95, 87, 108; $n = 5$; $X = 99$.)

Step 1. List x values in ascending order, along with e , e^2 , and Σe^2 as follows:

EXAMPLE:

x	87	95	100	105	108	($X = 99$)
e	-12	-4	+1	+6	+9	(value $x - X$)
e^2	144	16	1	36	81	$\Sigma e^2 = 278$

Step 2. Find a -value coefficients from Table D-7.1-1 and compute b -value as follows:

$$b = a_1(\text{last } e - \text{first } e) + a_2(\text{second-to-last } e - \text{second } e) + \dots$$

(Note that for n odd, there will be a center value of e left over in the expansion.)

EXAMPLE: From Table D-7.1-1 for $n = 5$, $a_1 = 0.665$ and $a_2 = 0.241$ such that

$$b = 0.665[9 - (-12)] + 0.241[6 - (-4)] = 0.665(21) + 0.241(10) = 16.375$$

Step 3. Compute $W = b^2 / \Sigma e^2$.

EXAMPLE:

$$W = (16.375)^2 / 278 = 0.9645$$

Step 4. Compare to $W_{\min}$ from Table D-7.1-1 (the computed value must be greater).

EXAMPLE:

$$W_{\min} = 0.762 \text{ vs. } 0.9645$$

(consider the data set normal)

D-7.2 Method II: MAWP Based on Normally Distributed Proof Test Data

s = standard deviation (of sample)
 $= [\sum(x - \bar{X})^2 / (n - 1)]^{1/2}$

Step 1. Compute $X - (s)(k)$ for each of the following where

(a) 95% CI is simply the lower 95% confidence interval

(b) 95% CI at 0.9P is the lower 95% confidence interval with a probability of 0.9

(c) 95% CI at 0.99P is the lower 95% confidence interval with a probability of 0.99

n	k (95% CI)	k (95% CI at 0.9P)	k (95% CI at 0.99P)
3	2.484	6.155	10.553
4	1.591	4.162	7.042
5	1.241	3.407	5.741
6	1.050	3.006	5.062
7	0.925	2.755	4.642
8	0.836	2.582	4.354
9	0.769	2.454	4.143
10	0.715	2.355	3.981
11	0.664	2.275	3.852
12	0.635	2.210	3.747
13	0.604	2.155	3.659
14	0.577	2.109	3.585
15	0.544	2.068	3.520
>15	eq. (1)	eq. (2)	eq. (3)

$$k \approx 2.35/n^{0.535} \quad (1)$$

$$k \approx 1.282 + e^{(0.958 - 0.520 \ln n + 3.19/n)} \quad (2)$$

$$k \approx 2.326 + e^{(1.34 - 5.22 \ln n + 3.87/n)} \quad (3)$$

NOTE: Although values exist for $n = 2$, they are excessively large (i.e., 8.984, 20.581, and 37.094, respectively), and $n \geq 3$ is required for testing per para. D-7.1.

Step 2. Apply the following additional safety factors:

MAWP = lower 95% CI/5

MAWP = lower 95% CI at 0.9P/4

MAWP = lower 95% CI at 0.99P/3

Step 3. Use the highest of the three values computed.

EXAMPLE: Using the previous set of numbers in the Example of para. D-7.1

$n = 5$

$s = 8.337$

$X = 99$

MAWP 95% CI = $[99 - (8.337)(1.241)]/5$
 $= 17.73$

MAWP 95% CI
 at 0.9P = $[99 - (8.337)(3.407)]/4$
 $= 17.65$

MAWP 95% CI
 at 0.99P = $[99 - (8.337)(5.741)]/3$
 $= 17.04$

Use MAWP = 17.73.

NOTE: The highest of the three values will vary depending on n and the standard deviation of the data.

D-7.3 Method III: Nonparametric Determination of MAWP From Proof Tests

n	6 MAWP	5 MAWP	4 MAWP
≤ 5	No statistical significance	95% CI	95% CI at 0.9P
6-8	...	1	...
9-11	...	2	...
12-14	...	3	...
15-16	...	4	...
17-19	...	5	...
20-22	...	6	...
23-24	...	7	...
25-27	...	8	...
28-29	...	9	1
30-32	...	10	2
33-34	...	11	2
35-36	...	12	2
37-39	...	13	2
40-41	...	14	2
42-43	...	15	2
44-45	...	16	2
46-50	...	17	3

The integers listed are the ranking from the lowest failure pressure value recorded. For example, for $n = 7$, the MAWP equals the lowest recorded failure pressure divided by 5. Similarly, in the case of $n = 10$, the MAWP equals the second lowest value divided by 5. If $n > 27$, compute both MAWP values, and use the larger of the two values obtained.

EXAMPLE: If the data in the Examples for Methods I and II had not been normally distributed (and lacking statistical significance with $n = 5$), the MAWP would have been $87/6 = 14.5$. Similarly, if there had been a sixth data point greater than 87 (and the data had not been normally distributed but with a nonparametric CI of 95% based on the lowest value for $n = 6$), the MAWP would have

been $87/5 = 17.4$. Alternatively, if the sixth data point had been less than 87, the MAWP would have been the sixth data point divided by 5.

NOTE: For nonparametric analysis, 95% CI at $0.99P$ requires $n \geq 299$.

D-7.4 Method IV: MAWP Determination Based on Nonfailure Test Pressure

$$\text{MAWP} = [(\text{test pressure})(n^{1/8})]/6$$

which provides the following, where n = number of prototypes tested to a specific pressure:

n	MAWP
1	Test pressure/6
2	Test pressure/5.5
3	Test pressure/5.25
4	Test pressure/5
10	Test pressure/4.5
25	Test pressure/4
75	Test pressure/3.5
300	Test pressure/3

Similar to the other methods, Safety Factor 6 lacks statistical significance, and Safety Factors 5, 4, and 3 are based on 95% CI at $0.5P$, $0.9P$, and $0.99P$, respectively, where confidence = $1 - p^n$ for a pass/fail basis.

NOTE: Per [para. D-5.1.5](#), prototype testing at pressures less than that incurring failure is limited to special cases requiring advance Committee approval. The “test pressure” is the lowest test pressure used (if different for multiple prototypes of the same design and method of fabrication). None of the prototypes tested are permitted to fail. If any prototype using this method does fail, then Method III shall be used to determine MAWP.

ASME PVHO-1 2023
 ASMENORMDOC.COM : Click to view the full PDF of ASME PVHO-1 2023

Table D-7.1-1
Tabulated Data for Performance of “W-Test” for Normality of Data Set

<i>n</i>	<i>W</i> _{min}	<i>a</i> ₁	<i>a</i> ₂	<i>a</i> ₃	<i>a</i> ₄	<i>a</i> ₅	<i>a</i> ₆	<i>a</i> ₇	<i>a</i> ₈	<i>a</i> ₉	<i>a</i> ₁₀	<i>a</i> ₁₁	<i>a</i> ₁₂	<i>a</i> ₁₃	<i>a</i> ₁₄	<i>a</i> ₁₅	<i>a</i> ₁₆	<i>a</i> ₁₇	<i>a</i> ₁₈	<i>a</i> ₁₉	<i>a</i> ₂₀	<i>a</i> ₂₁	<i>a</i> ₂₂	<i>a</i> ₂₃	<i>a</i> ₂₄	<i>a</i> ₂₅
3	0.767	0.707	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
4	0.748	0.687	0.168	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
5	0.762	0.665	0.241	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
6	0.788	0.643	0.281	0.088	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
7	0.803	0.623	0.303	0.140	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
8	0.818	0.605	0.316	0.174	0.056	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
9	0.829	0.589	0.324	0.198	0.095	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
10	0.842	0.574	0.329	0.214	0.122	0.040	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
11	0.850	0.560	0.332	0.226	0.143	0.070	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
12	0.859	0.548	0.332	0.235	0.159	0.092	0.030	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
13	0.866	0.536	0.332	0.241	0.171	0.110	0.054	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
14	0.874	0.525	0.332	0.246	0.180	0.124	0.073	0.024	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
15	0.881	0.515	0.331	0.250	0.188	0.135	0.088	0.043	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
16	0.887	0.506	0.329	0.252	0.194	0.145	0.100	0.059	0.020	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
17	0.892	0.497	0.327	0.254	0.199	0.152	0.111	0.072	0.036	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
18	0.897	0.489	0.325	0.255	0.203	0.159	0.120	0.084	0.050	0.016	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
19	0.901	0.481	0.323	0.256	0.206	0.164	0.127	0.093	0.061	0.030	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
20	0.905	0.473	0.321	0.256	0.208	0.169	0.133	0.101	0.071	0.042	0.014	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
21	0.908	0.464	0.318	0.258	0.212	0.174	0.140	0.109	0.080	0.053	0.026	...	...	...	...	...	...	...	...	...	...	...	...	...	...	...
22	0.911	0.459	0.316	0.257	0.213	0.176	0.144	0.115	0.088	0.062	0.037	0.012	...	...	...	...	...	...	...	...	...	...	...	...	...	...
23	0.914	0.454	0.313	0.256	0.214	0.179	0.148	0.120	0.094	0.070	0.046	0.023	...	...	...	...	...	...	...	...	...	...	...	...	...	...
24	0.916	0.449	0.310	0.255	0.214	0.181	0.151	0.124	0.100	0.076	0.054	0.032	0.011	...	...	...	...	...	...	...	...	...	...	...	...	...
25	0.918	0.445	0.307	0.254	0.215	0.182	0.154	0.128	0.105	0.082	0.061	0.040	0.020	...	...	...	...	...	...	...	...	...	...	...	...	...
30	0.927	0.425	0.294	0.249	0.215	0.187	0.163	0.142	0.122	0.104	0.086	0.070	0.054	0.038	0.023	0.008	...	...	...	...	...	...	...	...	...	...
35	0.934	0.410	0.283	0.243	0.213	0.188	0.167	0.149	0.132	0.116	0.101	0.087	0.074	0.061	0.048	0.036	0.024	0.012	...	...	...	...	...	...	...	...
40	0.940	0.396	0.274	0.237	0.210	0.188	0.169	0.153	0.138	0.124	0.111	0.099	0.087	0.076	0.065	0.055	0.044	0.034	0.024	0.015	0.005	...	...	...	...	...
45	0.945	0.385	0.265	0.231	0.206	0.186	0.170	0.154	0.141	0.129	0.117	0.106	0.096	0.086	0.076	0.067	0.058	0.050	0.041	0.033	0.024	0.016	0.008	...	...	...
50	0.947	0.375	0.257	0.226	0.203	0.185	0.169	0.155	0.143	0.132	0.121	0.111	0.102	0.093	0.085	0.076	0.068	0.061	0.053	0.046	0.039	0.031	0.024	0.017	0.010	0.004

GENERAL NOTES:

(a) Coefficient values have been rounded to the closest thousandth.

(b) This table has been adapted from Shapiro and Wilk, “An analysis of variance test for normality (complete samples),” *Biometrika*, December 1965, Volume 52, Issue 3-4, pp. 591–611, Tables A-1 and A-2, by permission of Oxford University Press.