

NFPA®

80A

Recommended Practice for
Protection of Buildings from
Exterior Fire Exposures

2022



NFPA® 80A

Recommended Practice for Protection of Buildings from Exterior Fire Exposures

2022 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2021 National Fire Protection Association®. All Rights Reserved.

NFPA® 80A

Recommended Practice for

Protection of Buildings from Exterior Fire Exposures

2022 Edition

This edition of NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*, was prepared by the Technical Committee on Exposure Fire Protection. It was issued by the Standards Council on March 18, 2021, with an effective date of April 8, 2021, and supersedes all previous editions.

This edition of NFPA 80A was approved as an American National Standard on April 8, 2021.

Origin and Development of NFPA 80A

In 1924, the NFPA Committee on Protection of Openings in Walls and Partitions developed *Suggested Practice for Protection Against Exposure of Openings in Fire-Resistive Walls* to meet the demand for a method of evaluating the severity of exposure and a uniform practice for specifying protection. It was submitted as a tentative recommended practice and adopted by NFPA in 1925 as NFPA 80A.

In 1930, the pamphlet was added to *Standard for the Protection of Openings in Walls and Partitions Against Fire* as an appendix, but it was not published until the 1944 edition of the *National Fire Codes*®, Vol. III, except as part of the “NFPA Proceedings.” It also was summarized in the 9th edition (1941) of the *Handbook of Fire Protection*.

In 1963, the NFPA Committee on Exposure Fire Protection was formed and charged with the task of updating the 1925 edition of NFPA 80A. The committee submitted a complete revision of the 1925 text to the Association for tentative adoption in 1967 and a revision of the tentative text for official adoption in 1970 with the title *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*.

In the 1987 edition, there were substantive and editorial changes. In 1993, revisions continued to examine the effect of fire on an exposed structure and calculative methods to help ensure a reduction in fire impact due to exposure fires.

In the 1996 edition, some editorial changes were made in addition to changes in the example in Appendix B.

Revisions for the 2001 edition were mainly editorial to comply with the 2000 edition of the NFPA *Manual of Style* for technical committee documents. Language was added to recognize new technology, such as listed window sprinklers.

Revisions in the 2007 edition included a change to the definition of *noncombustible material*, which accomplished two objectives. First, it removed technical requirements from the definition in accordance with the *Manual of Style for NFPA Technical Committee Documents*, and second, it allowed the technical committee responsible for NFPA 220, *Standard on Types of Building Construction*, which owns the definition, to make changes to the technical criteria if and when they deem appropriate, without having the changes “cascade” across other documents. Other changes were made to clarify the committee’s intent in a number of sections.

Revisions in the 2012 edition included replacing the reference to NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, which was withdrawn in Fall 2009, with UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials*. The definition of *noncombustible material* was revised to reflect that it is extracted from NFPA 220, and the terms *radiant heat* and *indexes* replaced outdated terms in a number of locations. In addition, some other minor changes were made.

Revisions in the 2017 edition were minor and included updating referenced standards, deleting NFPA 220 as the source for the extracted definition of *noncombustible material*, and moving the second sentence of the definition for *noncombustible material* to Annex A.

Revisions to the 2022 edition include updating reference standards; in Chapter 3, replacing the definition of *noncombustible material* with a pointer to new requirements in Chapter 4; and in Chapter 4, providing requirements for materials that are considered noncombustible as well as provisions for classification of light severity interior wall and ceiling finishes in accordance with NFPA 286.

Technical Committee on Exposure Fire Protection

Nicholas A. Dawe, Chair

Cobb County Fire Marshal's Office, GA [E]

Jon R. Ackley, Dalmatian Fire, IN [M]

Kenneth E. Bland, American Wood Council, VA [M]
Rep. American Wood Council

Jason W. Butler, Bernie Till and Associates LLC, SC [SE]

Patrick J. Conroy, Liberty Mutual Insurance Company, WA [I]

Mark E. Fessenden, Johnson Controls, WI [M]

Steven C. Hahn, Lawrence Roll-Up Doors, Inc., CA [M]
Rep. Door & Access Systems Manufacturers Assn. International

Eric J. Hall, City of Des Peres, MO [E]

Robert E. Hanson, Savannah River Nuclear Solutions, GA [U]

David Hintz, Jensen Hughes, IL [SE]

Robert Malanga, Fire and Risk Engineering, NJ [SE]
Rep. Fairmount Fire Company No. 1

Jeramie W. Morris, Dow, Inc., MI [M]

Thomas William Noble, American Fire Sprinkler Association, TX [IM]

Carl L. Osberg, CH2M HILL, FL [SE]

Joel E. Sipe, Exponent, Inc., CA [SE]

William Skene, FM Global, CT [I]

Austin L. Smith, Consolidated Nuclear Security, LLC, Y-12, TN [U]

Jon S. Traw, Traw Associates Consulting, CA [SE]

Christopher Willms, Sea Girt Fire Company #1, NJ [E]

Alternates

Phillip J. Bistany, Liberty Mutual Property, MA [I]
(Alt. to Patrick J. Conroy)

David Dawdy, Cornell Iron Works, Inc., PA [M]
(Alt. to Steven C. Hahn)

Ernesto Rodriguez, Jr., Wiginton Fire Protection Engineering, Inc., FL [M]
(Alt. to Jon R. Ackley)

Jen Sisco, NFPA Staff Liaison

Andrew Thomas Tinsley, Consolidated Nuclear Security, TN [U]
(Alt. to Austin L. Smith)

David P. Tyree, American Wood Council, CO [M]
(Alt. to Kenneth E. Bland)

Frank Velardi, Johnson Controls, NJ [M]
(Alt. to Mark E. Fessenden)

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on protection of buildings from fire exposure, excluding installation details for outside sprinklers, which are handled by the Technical Committee on Automatic Sprinklers.

Contents

Chapter 1 Administration	80A- 5	4.2 Exposures.	80A- 6
1.1 Scope.	80A- 5	4.3 Exposure from Buildings of Greater or Equal Height	80A- 6
1.2 Purpose.	80A- 5	4.4 Minimum Separation Distance.	80A- 6
1.3 Application.	80A- 5		
1.4 Units and Formulas.	80A- 5	Chapter 5 Means of Protection	80A- 8
Chapter 2 Referenced Publications	80A- 5	5.1 Types.	80A- 8
2.1 General.	80A- 5	5.2 Additional Protection.	80A- 8
2.2 NFPA Publications.	80A- 5	5.3 Evaluation of Protection.	80A- 8
2.3 Other Publications.	80A- 5	5.4 Selecting the Means of Protection.	80A- 8
2.4 References for Extracts in Recommendations Sections. (Reserved)	80A- 5	5.5 Manual Operation.	80A- 8
		5.6 Application of Means of Protection.	80A- 8
Chapter 3 Definitions	80A- 5	Annex A Explanatory Material	80A- 10
3.1 General.	80A- 5	Annex B Example	80A- 12
3.2 NFPA Official Definitions.	80A- 6	Annex C Informational References	80A- 14
3.3 General Definitions.	80A- 6	Index	80A- 16
Chapter 4 Classification of Exposures and Recommended Separation Distances	80A- 6		
4.1 Noncombustible Material.	80A- 6		

NFPA 80A

Recommended Practice for

Protection of Buildings from Exterior Fire Exposures

2022 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex C.

Chapter 1 Administration

1.1 Scope. This recommended practice addresses separation distances between buildings to limit exterior fire spread based on exterior openings and other construction features.

1.2 Purpose. These recommendations are intended to provide a reasonable level of protection for combustibles within and on the exterior of a building exposed to an external building fire while effective fire-fighting activity is being contemplated.

1.3 Application. The hazards of exposure to a structure from adjacent exposing fires and the multiple conditions under which such exposure can occur make it impossible to develop a table, formula, or set of rules that adequately covers all conditions. The user of this recommended practice should become familiar with the general theory of radiation exposure hazard as outlined in A.3.3.2.

1.4 Units and Formulas. Metric units of measurement in this recommended practice are in accordance with the modernized

metric system known as the International System of Units (SI). The liter unit, which is outside of but recognized by SI, is commonly used in fire protection and is therefore used in this recommended practice. In this document, values for measurements are expressed in SI units followed by an equivalent English unit. The first stated value should be regarded as the recommendation because the given equivalent value might be approximate.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this recommended practice and should be considered part of the recommendations of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2022 edition.

NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, 2022 edition.

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2019 edition.

2.3 Other Publications.

2.3.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, 2020.

ASTM E136, *Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C*, 2019a.

ASTM E2652, *Standard Test Method for Assessing Combustibility of Materials Using a Tube Furnace with a Cone-shaped Airflow Stabilizer, at 750°C*, 2018.

2.3.2 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

UL 723, *Test for Surface Burning Characteristics of Building Materials*, 2018.

2.3.3 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Recommendations Sections. (Reserved)

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter apply to the terms used in this recommended practice. Where terms are not defined in this chapter or within another chapter, they should be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, is the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Should. Indicates a recommendation or that which is advised but not required.

3.3 General Definitions.

3.3.1 Exposure. The heat effect from an external fire that might cause ignition of, or damage to, an exposed building or its contents.

3.3.2* Exposure Severity. The intensity of an exposing fire.

3.3.3* Noncombustible Material. See Section 4.1.

3.3.4* Pilot Ignition. The ignition of a material by radiation where a local high-temperature igniting source is located in the stream of gases and volatiles issuing from the exposed material.

Chapter 4 Classification of Exposures and Recommended Separation Distances

N 4.1 Noncombustible Material. A material that complies with any of the following is considered a noncombustible material:

- (1)* A material that, in the form in which it is used and under the conditions anticipated, will not ignite, burn, support combustion, or release flammable vapors when subjected to fire or heat
- (2) A material that is reported as passing ASTM E136
- (3) A material that is reported as complying with the pass/fail criteria of ASTM E136 when tested in accordance with the test method and procedure in ASTM E2652

4.2 Exposures. Two types of exposure should be considered, as described in 4.2.1 and 4.2.2.

4.2.1 Exposure to Radiant Heat. Exposure to radiant heat results from any of the following:

- (1) Radiant heat passing through windows or other openings in the façade of a burning building
- (2) Flames issuing from the windows of a burning building
- (3) Flames issuing from the burning façade of a building

4.2.2 Exposure to Flames. Exposure to flames results from flames issuing from the roof or top of a burning building in cases where the exposed building is higher than the burning building.

4.3 Exposure from Buildings of Greater or Equal Height.

4.3.1 Where a building is exposed by a building of greater or equal height, only the thermal radiation from the walls or wall openings of the exposing building should be considered.

4.3.2 Separation distances should be determined so that pilot ignition of the exposed building or its contents is unlikely, assuming no means of protection are installed in connection with either building.

4.4 Minimum Separation Distance.

4.4.1 General. The minimum separation distances between buildings should be determined using 4.4.2 through 4.4.8 and Table 4.4.7.3 and Table 4.4.8.2.

Δ 4.4.2 Width of Exposing Fire.

4.4.2.1 The width of the exposing fire should be considered to be the length in meters (feet) of the exposing wall between interior fire separations (such as partition walls or fire walls) or between exterior end walls where no fire separations exist.

4.4.2.2 Fire separations should have sufficient fire resistance to contain the expected fire.

4.4.3 Height of Exposing Fire.

4.4.3.1 The height of the exposing fire should be regarded as the height in meters (feet) of the number of stories involved in the exposing fire, considering such factors as the building construction, closure of vertical openings, and fire resistance of floors.

4.4.3.2 The relevant fire separations should have a fire resistance sufficient to contain the expected fire.

4.4.4 Percentage of Opening in Exposing Wall Area. The percentage of opening in the exposing wall area should be regarded as the percentage of the exposing wall made up of doors, windows, or other openings within the assumed height and width of the exposing fire.

4.4.4.1 Walls without the ability to withstand fire penetration in excess of 20 minutes should be treated as having 100 percent openings.

4.4.4.2 Walls having the ability to withstand fire penetration for not less than 20 minutes but not exceeding the expected duration of the fire should be treated as having 75 percent openings or the actual percentage of openings, whichever is greater.

4.4.5 Severity.

4.4.5.1 Three levels of exposure severity should be assumed: light, moderate, and severe. Two important properties influencing fire severity are as follows:

- (1) The average combustible load per unit of floor area
- (2) The characteristics and average flame spread indexes of the interior wall and ceiling finishes

4.4.5.2 Table 4.4.5.2(a) and Table 4.4.5.2(b) should be used to assess severity based on the properties described in 4.4.5.1, and the more severe of the two classifications should govern.

Δ Table 4.4.5.2(a) Severity of Fire Load

Fire Loading of Floor Area		Classification of Severity
kg/m ²	lb/ft ²	
0–34	0–7*	Light
35–73	8–15	Moderate
≥74	≥16	Severe

*Excluding any appreciable quantities of rapidly burning materials such as certain foamed plastics, excelsior, or flammable liquids. Where these materials are found in substantial quantities, the severity should be classified as moderate or severe.

Table 4.4.5.2(b) Severity of Interior Wall and Ceiling Finish

Average Flame Spread Index of Interior Wall and Ceiling Finish*	Classification of Severity [†]
0–25	Light
26–75	Moderate
≥76	Severe

*See ASTM E84 or UL 723.

[†]Where only a portion of the exposing building has combustible interior finish (e.g., some rooms only, ceiling only, some walls only), this factor is considered when judging severity classification.

N 4.4.5.3* As an alternative to classification of severity based on tests to ASTM E84 or UL 723, interior wall and ceiling finish materials that comply with the following requirements, when tested in accordance with NFPA 286, should be classified as materials associated with light severity:

- (1) During the 40 kW exposure, flames should not spread to the ceiling.
- (2) The flame should not spread to the outer extremity of the sample on any wall or ceiling.
- (3) Flashover, as described in NFPA 286, should not occur.
- (4) The peak heat release rate throughout the test should not exceed 800 kW (760 Btu/s).
- (5) The total smoke released throughout the test should not exceed 1000 m³ (10,800 ft³).

4.4.5.4 Where all openings in the façade of the exposing building are equipped with opening protectives having a fire protection rating equal to or greater than the expected duration of the fire, the following adjustments can be applied. Severity classifications of moderate and severe determined in accordance with 4.4.5.2 can be reduced to light and moderate, respectively, for use in Table 4.4.7.3. Where the severity classification determined in accordance with 4.4.5.2 is light, the percentage of openings for use to Table 4.4.7.3 can be 50 percent of the actual value.

4.4.6 Width/Height or Height/Width.

4.4.6.1 Width versus height, w/h , or height versus width, h/w , should be determined as a measure of the configuration of the exposing face and should be expressed as a ratio.

4.4.6.2 The larger of w/h or h/w values should be used.

4.4.7* Determination of Separation Distances.

4.4.7.1 To determine distances, the lesser dimension of either width, w , or height, h , should be multiplied by the guide number. Where all openings are not equipped with opening protectives having a fire protection rating equal to or greater than the expected duration of the fire, 1.5 m (5 ft) is added to the result.

4.4.7.2 Where non-cellulosic combustible materials are installed on the façade of the exposed building, the material should be subjected to appropriate tests to determine the minimum value of I at which it will ignite in the presence of a pilot flame. Where the I value for the non-cellulosic combustible materials used is indicated by appropriate tests to be less than 12.5 kW/m² (1.10 Btu/ft²·sec), the percentage of openings should be decreased by multiplying by the ratio $I/12.5$ kW/m² (1.10 Btu/ft²·sec). Where I is indicated by appropriate tests to be greater than 12.5 kW/m² (1.10 Btu/ft²·sec) and there are no openings in the façade of the exposed building, the percentage of openings can be increased by multiplying by the ratio $I/12.5$ kW/m² (1.10 Btu/ft²·sec).

4.4.7.3 Recommended separation distances assume fire department response. Where no organized fire-fighting facilities are available, the distances derived from the guide numbers in Table 4.4.7.3 should be increased by a factor of 3 or less.

4.4.8* Exposure from Buildings of Lesser Height.

4.4.8.1 Where the exposing building is of lesser height than the exposed building, the separation distance first should be determined from Table 4.4.7.3.

Table 4.4.7.3 Guide Numbers for Minimum Separation Distances

Severity			Width/Height or Height/Width																
Percentage of Openings*			Guide Number [multiply by lesser dimension, add 1.5 m (5 ft) [†] to obtain building-to-building separation]																
Light	Moderate	Severe	1.0	1.3	1.6	2.0	2.5	3.2	4	5	6	8	10	13	16	20	25	32	40
20	10	5	0.36	0.40	0.44	0.46	0.48	0.49	0.50	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51	0.51
30	15	7.5	0.60	0.66	0.73	0.79	0.84	0.88	0.90	0.92	0.93	0.94	0.94	0.95	0.95	0.95	0.95	0.95	0.95
40	20	10	0.76	0.85	0.94	1.02	1.10	1.17	1.23	1.27	1.30	1.32	1.33	1.33	1.34	1.34	1.34	1.34	1.34
50	25	12.5	0.90	1.00	1.11	1.22	1.33	1.42	1.51	1.58	1.63	1.66	1.69	1.70	1.71	1.71	1.71	1.71	1.71
60	30	15	1.02	1.14	1.26	1.39	1.52	1.64	1.76	1.85	1.93	1.99	2.03	2.05	2.07	2.08	2.08	2.08	2.08
80	40	20	1.22	1.37	1.52	1.68	1.85	2.02	2.18	2.34	2.48	2.59	2.67	2.73	2.77	2.79	2.80	2.81	2.81
100	50	25	1.39	1.56	1.74	1.93	2.13	2.34	2.55	2.76	2.95	3.12	3.26	3.36	3.43	3.48	3.51	3.52	3.53
—	60	30	1.55	1.73	1.94	2.15	2.38	2.63	2.88	3.13	3.37	3.60	3.79	3.95	4.07	4.15	4.20	4.22	4.24
—	80	40	1.82	2.04	2.28	2.54	2.82	3.12	3.44	3.77	4.11	4.43	4.74	5.01	5.24	5.41	5.52	5.60	5.64
—	100	50	2.05	2.30	2.57	2.87	3.20	3.55	3.93	4.33	4.74	5.16	5.56	5.95	6.29	6.56	6.77	6.92	7.01
—	—	60	2.26	2.54	2.84	3.17	3.54	3.93	4.36	4.82	5.30	5.80	6.30	6.78	7.23	7.63	7.94	8.18	8.34
—	—	80	2.63	2.95	3.31	3.70	4.13	4.61	5.12	5.68	6.28	6.91	7.57	8.24	8.89	9.51	10.05	10.50	10.84
—	—	100	2.96	3.32	3.72	4.16	4.65	5.19	5.78	6.43	7.13	7.88	8.67	9.50	10.33	11.15	11.91	12.59	13.15

*Where the percentage of openings or width/height or height/width ratio is between table values provided, interpolation between respective guide numbers should be made. See A.4.4.7 for treatment of unequally distributed windows.

[†]Where openings in exterior walls are equipped with opening protectives, see 4.4.7.1.

4.4.8.2 Where the roof assembly of the exposing building is combustible and has no fire resistance rating, means of protection should be provided above the roof level of the exposing building in accordance with Table 4.4.8.2.

Table 4.4.8.2 Minimum Separation Distance for Exposing Buildings with Combustible/Nonrated Roof Assemblies

Number of Stories Likely to Contribute to Flaming Through the Roof	Horizontal Separation Distance or Height of Protection Above Exposing Fire	
	m	ft
1	7.5	25
2	10	33
3	12.5	41
4	15	49

4.4.8.3 Where separation distances derived from Table 4.4.7.3 do not exceed the distances indicated in Table 4.4.8.2, means of protection should be applied on the exposed building wall to a height equal to the separation distance, commencing at the height of the roof of the exposing building.

4.4.8.4 Where the roof of the exposing building has a fire resistance rating sufficient to contain the expected fire (based on the fire loading within the area), no exposure hazard is considered to exist throughout the roof.

4.4.8.5 Where the roof has a fire resistance rating less than necessary to contain an expected fire, means of protection should be provided in accordance with Table 4.4.8.2, taking into consideration the fire stability of the roof assembly involved, the fuel it could contribute, including roof insulation and covering, and its tendency to inhibit flaming through the roof.

4.4.8.6 Subject to 4.4.8.4 and 4.4.8.5, the number of stories expected to contribute to flaming through the roof should be considered to be the top story together with those stories that are successively located beneath the top story and are not separated from it, as indicated in 4.4.3.

4.4.8.7 High attic spaces should be counted as a story and be subject to 4.4.8.4 and 4.4.8.5. Where the height of the attic is low, interpolation between the values provided in Table 4.4.8.2 should be made.

Chapter 5 Means of Protection

5.1 Types. Various means of protecting buildings from fire damage resulting from exterior exposure, listed as follows in no specific order with regard to adequacy, should be considered:

- (1) Buildings
 - (a) Clear space between buildings
 - (b) Total automatic sprinkler protection
- (2) Walls
 - (a) Blank walls of noncombustible materials
 - (b) Barrier walls (self-supporting) between the building and exposure
 - (c) Extension of exterior masonry walls to form parapets or wings

- (d) Automatic exposure protection sprinkler systems for combustible walls
- (3) Wall openings
 - (a) Elimination of openings by filling with equivalent construction
 - (b) Glass block panels in openings
 - (c) Wired glass in steel sash (fixed or automatic closing) in openings
 - (d) Automatic exposure protection sprinkler systems
 - (e) Listed automatic window sprinklers
 - (f) Automatic (rolling steel) fire shutters on openings
 - (g) Automatic fire doors on door openings
 - (h) Automatic fire dampers on wall openings
 - (i) Fire window assembly

5.2 Additional Protection.

5.2.1 Additional means of protection that can be developed, such as double-glazed glass in metal sash, flame-retardant coatings, and other arrangements, also should be considered.

5.2.2 Any additional means of protection should be approved before being implemented.

5.3 Evaluation of Protection. Evaluation of the suitability of any of the types of protection specified in Section 5.1 should consider the adverse effects of convected heat, flame impingement, and small flying brands associated with winds, as well as the beneficial effects of fire department operations. Large flying brands are not considered.

5.4 Selecting the Means of Protection. The means of protection selected should be approved for the individual application and should be installed in accordance with appropriate standards (e.g., fire doors installed in accordance with NFPA 80 and automatic sprinklers installed in accordance with NFPA 13).

5.5 Manual Operation. Manually operated window shutters or sprinklers should not be used. The excessive time needed to close or activate them at the time of a fire incident and the fact that the property exposed could be vacant or uninhabited at the time of the fire incident make their value questionable.

5.6 Application of Means of Protection. The various means of protection to reduce the separation distances indicated in Table 4.4.7.3 and Table 4.4.8.2 should be applied in accordance with the guidelines provided in 5.6.1.

5.6.1 Separation Adjustments. Table 5.6.1(a) through Table 5.6.1(e) should be used for adjusting the separation distances derived from Table 4.4.7.3 and Table 4.4.8.2.

5.6.2 Combustible Eaves. Combustible eaves, cornices, and other exterior ornamentation on exposed buildings should be treated as unprotected openings, in accordance with 5.6.1.

5.6.3* Exposing Building. Where the exposing building or structure is protected throughout by an approved, properly maintained automatic sprinkler system or other approved automatic fire suppression system of adequate design for the hazard involved, no exposure hazard should be considered to exist.

5.6.4* Exposed Building. Where the exposed building or structure is protected throughout by an approved, properly maintained automatic sprinkler system or other approved automatic fire suppression system of adequate design for the hazard involved, the exposure hazard to the total exposed building and its contents should be considered to be substantially reduced, depending upon the construction of the exterior wall.

Table 5.6.1(a) Frame or Combustible Exposed Exterior Walls

Means of Protection	Separation Distance Adjustment
Replace with blank fire-resistive wall (3-hour minimum)	Reduce to 0 m (0 ft)
Install automatic exposure protection sprinkler systems over entire wall with no windows, with wired glass windows, or with windows closed by ¾-hour protection	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems over entire wall with ordinary glass windows	Reduce by 50 percent

Table 5.6.1(b) Frame or Combustible Exposed Exterior Wall [Greater Than 12.5 kW/m² (0.3 cal/cm²·sec, or 66 Btu/ft²·min)] with Openings

Means of Protection	Separation Distance Adjustment
Replace with blank fire-resistive wall (3-hour minimum)	Reduce to 0 m (0 ft)
Install automatic exposure protection sprinkler systems over entire wall with no windows, with wired glass windows, or with windows closed by ¾-hour protection	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems over entire wall with ordinary glass windows	Reduce by 50 percent
Close all wall openings with material equivalent to wall or with ¾-hour protection and eliminate combustible projections that have <i>I</i> less than wall	Reduce in accordance with 4.4.7.2

Table 5.6.1(c) Noncombustible Exposed Exterior Wall (Fire Resistance Less Than 3 Hours)

Means of Protection	Separation Distance Adjustment
Replace wall with blank fire-resistive wall (3-hour minimum)	Reduce to 0 m (0 ft)
Close all wall openings with material equivalent to wall or with ¾-hour protection and eliminate combustible projections	Reduce by 50 percent
Install automatic exposure protection sprinkler systems over entire wall with no windows, with wired glass windows, or with windows closed by ¾-hour protection	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems on all wall openings equipped with ordinary glass and on combustible projections	Reduce by 50 percent
Install listed automatic window sprinklers in accordance with their listings	Reduce by 50 percent

Table 5.6.1(d) Veneered Exposed Exterior Wall [Combustible Construction Covered by a Minimum of 100 mm (4 in.) of Masonry]

Means of Protection	Separation Distance Adjustment
Replace wall with blank fire-resistive wall (3-hour minimum)	Reduce to 0 m (0 ft)
Close all wall openings with ¾-hour protection and eliminate combustible projections	Reduce by 50 percent
Close all wall openings with material equivalent to wall construction and eliminate combustible projections	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems over windows equipped with wired glass or over ¾-hour closed openings and on combustible projections	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems over windows equipped with ordinary glass and on combustible projections	Reduce by 50 percent
Install listed automatic window sprinklers in accordance with their listings	Reduce to 1.5 m (5 ft)

Table 5.6.1(e) Fire-Resistive Exposed Exterior Wall (Minimum 3-Hour Rating)

Means of Protection	Separation Distance Adjustment
Close all openings with material equivalent to wall or protect all wall openings with 3-hour protection	Reduce to 0 m (0 ft)
Protect all openings with ¾-hour protection	Reduce by 75 percent [max. recommended adjustment = 3 m (10 ft)]
Protect all wall openings with ¾-hour protection	Reduce by 50 percent [max. recommended adjustment = 6 m (20 ft)]
Install automatic exposure protection sprinkler systems on all wall openings with wired glass or with ¾-hour or 1½-hour protection	Reduce to 1.5 m (5 ft)
Install automatic exposure protection sprinkler systems on all wall openings equipped with ordinary glass	Reduce by 50 percent
Install listed automatic window sprinklers in accordance with their listings	Reduce by 75 percent

Annex A Explanatory Material

Annex A is not a part of the recommendations of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction;

at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.3.2 Exposure Severity. For the purposes of this document, *exposure severity* has been defined as “the intensity of an exposing fire.” Exposure severity is intended to be a measure of the radiation level developed per unit window area by the exposing fire. It represents a combination of radiation emitted through the window itself as well as that produced from the flames that project out the window and up the front of the building. Thus, because radiant transfer from the flames as well as from the interior room walls is involved, the flame emissivity, dependent on fuel character as well as flame dimensions, could be of great importance. It is generally assumed for radiation calculation purposes that emissivity, ϵ , is 1.0.

The emission of flames and hot gases from the window of a room or building compartment during a fire could result from the establishment of a thermal pump. The pump is created by buoyancy differences between the hot combustion products and the surrounding outside ambient air, and it provides a positive means for furnishing fresh air to the fire and discharging flames and combustion products through the window. If the room involved is provided with only a single window and no internal source of air, the window serves the dual purpose as a passage for the entry of fresh air and for the discharge of flames and other hot combustion products. If, however, an internal duct or passage is available for the supply of fresh air to the fire room, a much larger fraction of the window can be used effectively for the discharge of flaming gases. Winds also could significantly influence the ventilation behavior of a building fire and thus the exposure severity.

In addition to ventilation, a number of other system variables influence exposure severity. The most important of these are as follows:

- (1) The combustible load, including both the occupancy and building construction combustibles
- (2) The fuel dispersion or surface-to-volume ratio of the fuel
- (3) The size, geometry, and surface-to-volume ratio of the room involved
- (4) The thermal properties, conductivity, specific heat, and density of the interior finish

The current state of the art of fire protection engineering is such that it is not possible to define clearly how all or even a few of these variables interact to influence exposure severity. However, this general discussion provides a guide to trends.

A.3.3.3 Noncombustible Material. Materials that are reported as passing ASTM E136, *Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C*, are considered noncombustible materials.

A.3.3.4 Pilot Ignition. In practice, a glowing ember or a flash of flame could constitute a high-temperature ignition source, which often serves to ignite the flammable gases and volatiles. This mechanism differs from spontaneous ignition by radiation, in which there is no local high-temperature igniting source and for which higher intensities of radiation are necessary.

N A.4.1(1) The provisions of Section 4.1 do not require inherently noncombustible materials to be tested in order to be classified as noncombustible materials.

▲ **A.4.4.7** Table 4.4.7.3 determines the separation distance necessary between two buildings so that pilot ignition of combustibles on the façade of the exposed building or its contents is unlikely, assuming no means of protection are installed in connection with either building. Guide numbers are obtained from this table.

Table 4.4.7.3 is based on a maximum tolerable level of incident radiation (I) at the façade of an exposed building of 12.5 kW/m^2 ($0.3 \text{ cal/cm}^2\cdot\text{sec}$ or $66 \text{ Btu/ft}^2\cdot\text{min}$), assuming the façade is constructed of typical cellulosic materials.

Derivation of Table 4.4.7.3. The principles underlying the derivation of the separations specified in Table 4.4.7.3 are discussed in detail in "Fire and the Spatial Separation of Buildings" (McGuire, 1966).

The spread of fire from one building to another across a vacant space can be caused by convective or radiative heat transfer or flying brands. The hazard created by large flying brands was not a consideration in these recommendations. Convective heat transfer is also disregarded where the source of hazard is associated with openings in the façade of the exposing building, because ignition by radiation can occur at distances substantially greater than those at which flame impingement and convective heat transfer usually constitute a hazard. Therefore, ignition as a result of radiative heat transfer is the event that these recommendations are intended to combat.

The applicable equation that expresses the relationship for radiant heat transfer is $I = I_o\Phi$, or the unit intensity at an exposed building (I) is equal to the unit intensity at the exposing building (I_o) multiplied by the configuration factor (Φ), which is based on radiator size, geometry, and spatial distance. The radiation intensity per unit area at the exposure building (I_o) is calculated as follows:

[A.4.4.7a]

$$I_o = \varepsilon \sigma T^4$$

where:

ε = emissivity of flames (generally assumed to be 1.0)

σ = Stefan-Boltzmann constant ($5.67 \times 10^{-11} \text{ kW/m}^2\cdot\text{K}^4$)

T = absolute temperature of the flames in degrees K (degrees K = degrees C + 273)

The maximum tolerable level of radiation at the façade of an exposed building (I) has been established as 12.5 kW/m^2 ($0.3 \text{ cal/cm}^2\cdot\text{sec}$ or $66 \text{ Btu/ft}^2\cdot\text{min}$). This value, originally derived from work of the Joint Fire Research Organization in the United Kingdom, is now generally accepted as that below which the pilot ignition of most cellulosic materials is unlikely to occur. Substantially higher levels of radiation are necessary to cause spontaneous ignition. It is believed that a local high-temperature ignition source usually is present; thus, the selection of pilot ignition is indicated. Where materials are located in an enclosure irradiated through a small opening, appreciably lower levels can cause ignition. This factor has been ignored because irradiation times of more than 30 minutes usually are involved.

Since Table 4.4.7.3 was created, new building materials, other than cellulosic products (wood), having greater or lesser ability to resist ignition have been developed. Greater separation distances or fewer openings are needed for materials with

greater propensity to ignite. Those offering greater resistance to ignition can be separated at lesser distances or more openings can be permitted.

Information on the radiation levels near burning buildings (I_o) was established by a number of case histories and by a series of experimental burns known as the "St. Lawrence Burns." The most important findings of the latter experiments were that radiation levels were related to the percentage of openings in building walls and that combustible interior walls or ceiling linings give rise to particularly high levels of radiation outside the building.

Another notable conclusion of the St. Lawrence Burns was that maximum radiation levels were not greatly affected by the type of exterior covering. In all the experiments, the exterior walls were not close to penetration by the fire during times of maximum radiation.

The St. Lawrence Burns produced maximum levels of radiation so high that protection against them would involve unduly large distances of separation. However, much lower levels prevailed for at least the first 20 minutes. It was decided to base separation distance recommendations on these lower values. It was believed that the likelihood of fire department attendance at an early stage of a fire justified this approach. Subsequently, a field incident has confirmed that the recommended separations cannot be considered universally adequate and that an unusual combination of adverse conditions could allow fire spread even where the recommended separation distances are used.

In calculating the recommended separations, a rectangular radiator has been assumed, with a uniform emissive power being taken as proportional to the percentage of window openings. The expression for the configuration factor (Φ) of a rectangular radiator at an elemental receiving surface (i.e., the ratio of the radiant intensity at the receiver to that at the radiator) is as follows:

[A.4.4.7b]

$$\Phi = \frac{2}{\pi} \left[\frac{x}{\sqrt{x^2 + y^2}} \arctan \left(\frac{z}{\sqrt{x^2 + y^2}} \right) + \frac{z}{\sqrt{y^2 + z^2}} \arctan \left(\frac{x}{\sqrt{y^2 + z^2}} \right) \right]$$

where:

x = half-length of rectangular radiating surface

z = half-height of rectangular radiating surface

y = separation distance between radiator and receiving surface

Three levels of radiation hazard from a burning building were considered: light, moderate, and severe. For light, moderate, and severe hazard levels, configuration factors (Φ) of 0.14, 0.07, and 0.035, respectively, were adopted.

Using the relationship $I = I_o\Phi$ and setting $I = 12.5$, the hypothetical radiation intensities at the exposing building (I_o) assumed in developing the guide numbers are 89.3 kW/m^2 ($472 \text{ Btu/min}\cdot\text{ft}^2$), 178.6 kW/m^2 ($943 \text{ Btu/min}\cdot\text{ft}^2$), and 357.1 kW/m^2 ($1886 \text{ Btu/min}\cdot\text{ft}^2$), respectively.

An additional value of 1.5 m (5 ft) was added to the computed values of separation distance to account for the horizontal projection of flames from unprotected windows and doors, and to guard against the risk of ignition by direct flame impingement where small separations are involved.

Uniformity of Openings. The derivation of Table 4.4.7.3 assumes that openings are uniformly distributed on the façade and that the separation distance (blank wall) between openings is small (i.e., no more than one-third of the separation distance between the buildings). Where this is not the case, insufficient spatial separations can be predicted. The following measures remedy this deficiency substantially:

- (1) Where the openings in the façade are not uniformly distributed and a small portion of the façade includes a large number of windows, a separate calculation should be made with respect to the smallest rectangle conveniently including all the windows in this area. In many cases, a single window constitutes this rectangle. The spatial separation chosen for this area should be the largest value determined by any of the calculations involving the windows for the area.
- (2) Where the separation distance (blank wall) between openings is appreciably more than one-third of the separation distance between the buildings (as provisionally estimated), an additional calculation for a single window should be made. If a higher building spatial separation results, this value should be used.

It is fundamental to the derivation of Table 4.4.7.3 that a row of results relating to a percentage of window openings of less than 20 percent (severe hazard), 10 percent (moderate hazard), or 5 percent (light hazard) is not valid for inclusion in the table.

Separations less than those provided by the first row of the table can, however, often be derived by considering individual windows or groups of windows. The radiation level at the exposed building opposite a particular point on a façade of the exposing building is hardly influenced by radiation from a region of the exposing building façade removed from the point further than twice the estimated separation between buildings recommended. If windows or groups of windows are separated by more than this distance (which is likely if the percentage of openings is small), individual calculations are considered to be valid. The resulting building separations then can be used even though they need to be lower than those that would be predicted in association with a large area of façade and the smallest percentage opening area provided by the table.

A.4.4.8 NFPA searched its photographic records of building fires in which flames penetrated the roof. Of the thousands of photographs examined, 176 showed flames above roofs at what appeared to be maximum or near-maximum heights. No significant correlation between flame height and occupancy was apparent. In fact, the principal relationship was the number of stories involved in the fire. Table A.4.4.8 provides the average of the flame heights illustrated in some of the records. This table is reproduced from the May 1968 issue of *Fire Journal*.

The relationships shown in Table A.4.4.8 do not agree with those suggested by British and Japanese work based on theory and experiments, which, in general, would produce much higher values. The NFPA study does indicate that flame heights can be great under unusual circumstances, such as the heavy involvement of liquid fuels. The recommendations provided here are not intended to provide adequate protection under such circumstances.

In the event of a moderate wind, flames can be expected to extend horizontally for as great a distance as they might otherwise extend upward. For this reason, protection is recommen-

Table A.4.4.8 Average Heights of Flames Penetrating Roofs

Number of Stories Burning	Flame Height Above Roof (in Stories)
1	1.4
2	1.8
3	2.2
4	2.6
5	2.9
6	3.1

ded where the separation between two buildings is no more than the height to which the flames could otherwise extend.

Varying reductions in separation distance for blank fire-resistive walls with less than 3-hour ratings have not been made, because current test data are insufficient to evaluate appropriate reductions properly. It is hoped that future studies and tests will produce varying reductions with varying resistance ratings. Walls with 3-hour fire resistance ratings are assumed to be clad with noncombustible material.

N A.4.4.5.3 Codes have identified that interior wall and ceiling materials that comply with the requirements indicated are acceptable as materials that comply with a flame spread index of 25 and a smoke developed index of 450 (Class A) when tested to ASTM E84 or UL 723.

A.5.6.3 Where the exposing building is properly protected by automatic sprinklers, a fire in that building is assumed to be controlled; therefore, exposure also is assumed to be controlled.

A.5.6.4 Where the exposed building is properly protected by automatic sprinklers, ignition within the exposed building is possible where separation distances are less than those recommended or where means of protection are not provided on exposed openings, walls, or projections with lesser separation distances. Such an ignition, however, is assumed to be controlled by sprinklers in the exposed structures.

Where automatic exposure protection is provided for exposed openings in sprinklered buildings, as recommended in 5.6.1, such sprinklers could be located on the inside of the building, adjacent to the opening being protected and in a position where the sprinkler can sense the exposing fire. Under these conditions, such sprinklers could be of the closed type supplied by the wet pipe system within the building. Their water demand, however, should be calculated in addition to or separate from the demand of the remainder of the system.

Annex B Example

This annex is not a part of the recommendations of this NFPA document but is included for informational purposes only.

B.1 Application of NFPA 80A. Annex B provides an example of the application of NFPA 80A to a typical building exposure scenario as shown in Figure B.1.

Construction:

- Walls: North — 4-hour openings as illustrated
- South — 4-hour openings as illustrated